



SURFACE RESTORATION TO MATCH EXISTING OR AS SPECIFIED ON CONTACT DRAWINGS.

APPROVED NATIVE BACKFILL COMPACTED TO 90% MODIFIED PROCTOR DENSITY. NO STONES OVER 150mmØ. NO ORGANICS PERMITTED.

TRENCH TO BE BACKFILLED IN 300mm LAYERS.

SELECT NATIVE MATERIAL OR IMPORTED GRANULAR BACKFILL PLACED IN 300mm LAYERS AND COMPACTED TO 95% MODIFIED PROCTOR DENSITY.

SUBGRADE IS TO CONTAIN NO ORGANICS OR STONES OVER 150mmØ

TRACER WIRE SHALL BE INSTALLED PER THE MANUFACTURER'S SPECIFICATIONS

APPROVED GRANULAR PIPE BEDDING COMPACTED TO 95% MPD. 100mm MIN BEDDING UNDER PIPE AND 150mm MIN OVER ROCK OR BLASTED ROCK.

NOTES:

1. "D" = OUTSIDE DIAMETER OF THE PIPE AT ITS LARGEST SECTION.
2. TRENCHING TO COMPLY WITH ALL REQUIREMENTS OF THE WCB.



RESORT MUNICIPALITY of WHISTLER

TYPICAL TRENCH SECTION

DRAWN BY: BL

DATE: APRIL 2016

SCALE: N.T.S.

DWG. NO.: G4