

2016 Annual Drinking Water Summary

Resort Municipality of Whistler

Infrastructure Services



The following is the 2016 Annual Water System Summary for the Resort Municipality of Whistler (RMOW).

This summary summarizes the Conditions of the permit to operate by Vancouver Coastal Health for the Emerald and Community Water System. The summary will also expand on the Vancouver Coastal Health drinking water fillable form requirements.

Table of Contents

- 1. Permit to Operate – RMOW Community Water System..... i
 - 1.1 Conditions of Permit..... i
- 2. Permit To Operate – Emerald Estates Water System i
- 3. Water System Emergency Response and Contingency Plan.....ii
- 4. Source Water Protection Plan (SWPP).....ii

1. Permit to Operate – RMOW Community Water System

Revised Date: April 6, 2016

1.1 Conditions of Permit

- Implement your Cross-Connection Control Plan **(Compliant)**
 - The Cross-Connection Control Plan is an ongoing project with two more high-risk ICI locations (Husky Gas Station and Whistler Golf Course) having implemented their back-flow prevention devices within the last few months.
 - The RMOW continues to work with community stakeholders to install necessary back-flow prevention devices and comply with necessary premise isolation requirements
- Maintain the Uni-Directional Flushing Program annually. **(Compliant)**
 - Completed
- Maintain a Drinking Water Quality Sampling Program as prescribed. **(Compliant)**
 - Regular sampling, review, and reporting procedures are in place to ensure safe and clean groundwater supply.
- Minimum bacteriology sampling frequency is 25 per month (distribution). **(Compliant)**
 - The RMOW samples on average 36 times per month.
- Implement the Ground Water Resource Protection Plan **(Compliant)**
 - See attached “2016 Groundwater Monitoring Summary”.
- Review the Emergency Response Plan and update annually. **(In Progress)**
 - [2015 ERCP is currently in effect](#) with 2016 ERCP in progress.
- Blackcomb Creek source may not be used without prior authorization from VCH **(Compliant)**
 - Blackcomb Creek was not used in 2016.
- Implement your Source Protection Plan for 21 Mile Creek Supply. **(Compliant)**
 - See [Source Water Protection Plan \(SWPP\)](#).

2. Permit To Operate – Emerald Estates Water System

Revised March 25, 2014

- Confirm Well W201-2 is not GUDI or provide enhanced disinfection. **(In Progress)**
 - The Emerald UV station is scheduled for completion in March 2018.
- Implement your Cross-Connection Control Plan **(Compliant)**
 - The Cross-Connection Control Plan is an ongoing project with two more high-risk ICI locations (Husky Gas Station and Whistler Golf Course) having implemented their back-flow prevention devices within the last few months.
 - The RMOW continues to work with community stakeholders to install necessary back-flow prevention devices and comply with necessary premise isolation requirements
- Maintain the Uni-Directional Flushing Program annually. **(Compliant)**
 - Completed
- Maintain a Drinking Water Quality Sampling Program as prescribed. **(Compliant)**
 - Regular sampling, review, and reporting procedures are in place to ensure safe and clean groundwater supply.
- Minimum bacteriology sampling frequency is 4 per month (distribution). **(Compliant)**
 - The RMOW samples on average 4 times per month.
- Implement the Ground Water Resource Protection Plan **(Compliant)**

- See attached “2016 Groundwater Monitoring Summary”.
- Review the Emergency Response Plan and update annually **(In Progress)**
 - [2015 ERCP is currently in effect](#) with 2016 ERCP in progress.
- Maintain FAC level at 0.4 ppm minimum post reservoir. **(94% Compliant)**
 - 3/48 samples tested below 0.4 ppm (94% compliance) post reservoir assuming STP.
 - The new Emerald UV station will eliminate this requirement.

3. Water System Emergency Response and Contingency Plan

The 2015 Water System Emergency Response Plan details the plan of action for staff in the event of an emergency situation, disruption in service, or threat to the health of people drawing from the distribution system. The plan provides staff with an understanding of the resources available to them, instructions on when to operate the Emergency Operations Center (EOC) and identifies external resources that can be called upon if required. The Water System Emergency Response Plan was updated in 2015 and supplied to all utilities staff and personnel who are required to act in the case of a water emergency. A sample version of the 2015 Emergency Response Plan is included as Appendix B.

If it is known that a contaminant has entered the water supply or it is suspected that one has, and it poses a potentially significant threat to public health, the Supervisor on duty/call must immediately notify the Drinking Water Officer and the public. If there is a suspicion of a potentially modest threat to the drinking water supply the Drinking Water Officer should also be notified and will advise on the appropriate public notification advisory.

4. Source Water Protection Plan (SWPP)

The primary objectives of the Source Water Protection Plan (SWPP) required by the Vancouver Coastal Health Authority (VCHA) operational permit are to ensure that exposure to unacceptable concentrations of contaminants in the source water are minimized, to implement procedures and policies that will support the long-term sustainability of the surface water resource, and to maintain public confidence in Whistler’s drinking water quality.

The full scope of the plan includes: a long term sustainability plan beyond 2030, review of current water quality and future treatment recommendations, compliance with BC’s Comprehensive Drinking Water Source-to-Tap Assessment Guide, working closely with the Vancouver Coastal Health Authority, public consultation, and ultimately the implementation of a fully comprehensive action plan.

In an effort to facilitate stakeholder involvement, the 21-Mile Creek Technical Advisory Committee (TAC) was formed to guide the development and implement the risk mitigation actions documented in the SWPP. The TAC consists of members from VCHA (Drinking Water Officer) MFLNRO (crown land

use), RMOW Parks (Rainbow Lake Trail maintenance), RMOW Parks Planning (resort experience), RMOW Environmental Stewardship (community forests) and RMOW Utilities Group (water supply). These parties met and held multiple collaborative discussions in 2015.

The RMOW has improved budget and planning measures to better mitigate impacts on the Twenty-One Mile Creek watershed. In 2014 the RMOW commissioned Urban Systems to: (1) identify and evaluate potential hazards to the drinking water supply quality and quantity, (2) characterize the risks, (3) propose several next step risk management strategies. The 2015 Twenty-One Mile Creek Source Water Assessment report made several recommendations to keeping the Twenty-One Mile Creek water quality as high as possible. The report identified five intrinsic risks, four anthropogenic risks, and strategies to address these risks (Table 9.).

Table 9. Twenty-One Mile Creek Source Water Assessment identified strategies to be addressed.

<i>Intrinsic Risk Strategies</i>		
Hazard (source)	Contaminant	Preliminary Risk Managements Possible Strategies
Natural snowmelt and rainfall (peak flows)	Sedimentation, turbidity, coloration	Monitor water quality upstream of slumping to compare to quality at intake.
		Install a second intake further upstream of the slumping.
		Install an off-stream reservoir (storage). Install an off-stream settling basin.
Slope instability Debris flows	Sedimentation, turbidity, coloration	Slope stabilization.
Wildfire	Sedimentation, turbidity, coloration, organic content	Fuel thinning activities have been outcomes of the recent wildfire studies: consider expanding to Twenty-One Mile Creek watershed. Update the wildfire protection plan to account for the Twenty-One Mile Creek watershed's natural infrastructure/assets.
		Bacteria, protozoa
Climate change	Impacts to water quantity, quality, wildfire risk	Conduct a climate change impact and response study that considers both natural and built assets and infrastructure, and anticipates potential (future) permitting constraints under the new Water Sustainability Act; e.g., environmental flow needs. Address water demands through greater water conservation efforts.
<i>Anthropogenic Risk Strategies</i>		
Hazard (source)	Contaminant	Preliminary Risk Managements Possible Strategies
Non-motorized trail use	Sedimentation, turbidity, coloration	Expand MFLNRO's approach to monitoring/reporting snowmobile use to trail use and presence of dogs in the watershed.
		Engage trail users in identifying responses to risks:
Domestic pets	Bacteria, protozoa	Increase education efforts with trail users. Seek input on enhanced signage to inform users of drinking water source (Community Watershed).

Snowmobiling	Petroleum products	Continue MFLNRO's approach to monitoring and reporting snowmobile use
.Heli-skiing	Petroleum products	Do not permit flying directly over Rainbow Lake, Gin and Tonic Lakes, or Twenty-One Mile Creek. Inform heli-skiing operators of the hazards posed by helicopters to the drinking water source.
High user demands	Impacts water availability	Implement water use restrictions through bylaw. Implement water conservation measures. Inform users of importance of conservation.

Escherichia coli / E. coli (counts)(Lab Data Transfer)	Criteria	Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
01/05/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Mount Fee Rd	1		
01/05/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
01/05/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Block Alta Lake Rd - SS#482	1		
01/05/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
01/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
01/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
01/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
01/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
01/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
01/11/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8925 Hwy. 99 - S137	1		
01/11/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
01/12/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
01/12/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2773 Cheakamus Way - S121- SS#477	1		
01/12/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	5438 Stonebridge drive - P275	1		
01/12/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
01/13/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
01/13/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4335 Main Street - Main St. - SS#450	1		
01/19/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	3333 Carleton Way - S104 - SS#459	1		
01/19/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Mount Fee Rd	1		
01/19/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
01/19/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		



Escherichia coli / E. coli (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
01/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
01/20/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
01/20/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
01/20/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
01/20/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
01/20/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
01/25/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
01/26/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
01/26/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
01/26/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
01/26/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
01/26/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
01/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
01/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
02/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Mount Fee Rd	1		
02/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
02/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
02/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
02/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
02/03/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
02/03/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		

Escherichia coli / E. coli (counts)(Lab Data Transfer)	Criteria	Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
02/03/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1	
02/03/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	8319 Mountianview Dr.- P245 - SS#412	1	
02/03/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1	
02/09/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	3840 Sunridge Drive - P265 - SS#456	1	
02/09/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	5438 Stonebridge drive - P275	1	
02/09/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	2773 Cheakamus Way - S121- SS#477	1	
02/09/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	2149 Lake Placid Rd - S106 - SS#471	1	
02/10/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1	
02/10/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	8925 Hwy. 99 - S137	1	
02/10/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	4335 Main Street - Main St. - SS#450	1	
02/16/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	1300 Block Alta Lake Rd - SS#482	1	
02/16/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	2400 Taluswood Pl. - P270 - SS#465	1	
02/16/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	3333 Carleton Way - S104 - SS#459	1	
02/16/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	1300 Mount Fee Rd	1	
02/16/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1	
02/17/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	4700 Glacier Dr. - P256 - SS#441	1	
02/17/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1	
02/17/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	8319 Mountianview Dr.- P245 - SS#412	1	
02/17/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1	
02/18/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1	
02/23/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	2149 Lake Placid Rd - S106 - SS#471	1	

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
02/23/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
02/23/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
02/23/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
02/24/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
02/24/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
02/24/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
02/24/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
03/01/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Mount Fee Rd	1		
03/01/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
03/01/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
03/01/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
03/01/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
03/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
03/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
03/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
03/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
03/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
03/08/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
03/08/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
03/08/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
03/08/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	5438 Stonebridge drive - P275	1		

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
03/08/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
03/09/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
03/09/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
03/09/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
03/15/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Mount Fee Rd	1		
03/15/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
03/15/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
03/15/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
03/15/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
03/15/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
03/16/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
03/16/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
03/16/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
03/17/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
03/22/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
03/22/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
03/22/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
03/22/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
03/23/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
03/23/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
03/23/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
03/23/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
03/29/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
03/29/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Mount Fee Rd	1		
03/29/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
03/29/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
03/29/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
03/29/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
03/30/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
03/30/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
03/30/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
03/30/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
04/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
04/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
04/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
04/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
04/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
04/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
04/05/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
04/05/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
04/12/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
04/13/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
04/13/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
04/13/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Mount Fee Rd	1		

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
04/13/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
04/13/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
04/13/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
04/13/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
04/13/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
04/13/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
04/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
04/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
04/26/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Mount Fee Rd	1		
04/26/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
04/26/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
04/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
04/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
04/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
04/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
04/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
04/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
04/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
05/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
05/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		

Escherichia coli / E. coli (counts)(Lab Data Transfer)	Criteria	Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
05/04/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4335 Main Street - Main St. - SS#450	1		
05/04/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
05/04/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2773 Cheakamus Way - S121- SS#477	1		
05/04/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8925 Hwy. 99 - S137	1		
05/10/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Mount Fee Rd	1		
05/10/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	3333 Carleton Way - S104 - SS#459	1		
05/10/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Block Alta Lake Rd - SS#482	1		
05/10/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
05/10/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
05/11/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
05/11/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
05/11/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8319 Mountainview Dr.- P245 - SS#412	1		
05/11/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
05/12/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
05/16/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
05/16/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	5438 Stonebridge drive - P275	1		
05/17/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
05/17/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
05/17/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8925 Hwy. 99 - S137	1		
05/17/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
05/17/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2773 Cheakamus Way - S121- SS#477	1		
05/18/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4335 Main Street - Main St. - SS#450	1		



Escherichia coli / E. coli (counts)(Lab Data Transfer)	Criteria	Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
05/24/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
05/24/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
05/24/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Block Alta Lake Rd - SS#482	1		
05/24/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	3333 Carleton Way - S104 - SS#459	1		
05/24/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Mount Fee Rd	1		
05/24/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
05/24/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
05/24/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
05/24/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
05/24/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
05/30/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	5438 Stonebridge drive - P275	1		
05/30/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2773 Cheakamus Way - S121- SS#477	1		
05/31/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
05/31/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
05/31/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4335 Main Street - Main St. - SS#450	1		
05/31/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
05/31/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8925 Hwy. 99 - S137	1		
06/01/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
06/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
06/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
06/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	3333 Carleton Way - S104 - SS#459	1		
06/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Mount Fee Rd	1		



Escherichia coli / E. coli (counts)(Lab Data Transfer)	Criteria	Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
06/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
06/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
06/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
06/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
06/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
06/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Block Alta Lake Rd - SS#482	1		
06/13/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	5438 Stonebridge drive - P275	1		
06/13/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4335 Main Street - Main St. - SS#450	1		
06/13/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
06/14/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8925 Hwy. 99 - S137	1		
06/14/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
06/14/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2773 Cheakamus Way - S121- SS#477	1		
06/14/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
06/20/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
06/20/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
06/20/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
06/20/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
06/20/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Block Alta Lake Rd - SS#482	1		
06/20/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Mount Fee Rd	1		
06/20/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
06/21/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
06/21/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
06/21/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
06/23/2016 14:15	< 1 counts/100mL	<=0, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
06/28/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
06/28/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
06/28/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
06/28/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
06/28/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
06/28/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
06/28/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
06/29/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
07/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
07/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Mount Fee Rd	1		
07/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
07/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
07/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Mount Fee Rd	1		
07/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
07/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
07/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
07/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
07/11/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
07/11/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
07/11/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
07/12/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
07/12/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
07/12/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
07/12/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
07/12/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
07/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
07/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
07/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
07/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Mount Fee Rd	1		
07/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
07/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
07/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
07/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
07/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
07/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8319 Mountainview Dr.- P245 - SS#412	1		
07/25/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
07/25/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
07/25/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
07/25/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
07/25/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8925 Hwy. 99 - S137	1		

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
07/25/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
07/25/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
07/26/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
08/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
08/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
08/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
08/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Mount Fee Rd	1		
08/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
08/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
08/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
08/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
08/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
08/03/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
08/09/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
08/09/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
08/09/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
08/09/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
08/10/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
08/10/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
08/10/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
08/10/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
08/16/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Mount Fee Rd	1		

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
08/16/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
08/16/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
08/16/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
08/16/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
08/17/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
08/17/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
08/17/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
08/17/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
08/17/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
08/22/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
08/23/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
08/23/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
08/23/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
08/23/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
08/23/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
08/23/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
08/23/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
08/30/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
08/30/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
08/30/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
08/30/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		

Escherichia coli / E. coli (counts)(Lab Data Transfer)	Criteria	Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
08/30/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Mount Fee Rd	1		
08/31/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	3333 Carleton Way - S104 - SS#459	1		
08/31/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
08/31/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
08/31/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
08/31/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
09/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	5438 Stonebridge drive - P275	1		
09/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2773 Cheakamus Way - S121- SS#477	1		
09/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
09/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4335 Main Street - Main St. - SS#450	1		
09/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
09/06/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
09/07/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8925 Hwy. 99 - S137	1		
09/07/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
09/13/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Mount Fee Rd	1		
09/13/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
09/14/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Block Alta Lake Rd - SS#482	1		
09/14/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
09/14/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
09/14/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
09/14/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	3333 Carleton Way - S104 - SS#459	1		
09/14/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
09/14/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
09/14/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
09/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
09/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
09/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
09/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
09/20/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
09/20/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
09/20/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
09/21/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
09/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
09/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Mount Fee Rd	1		
09/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
09/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
09/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
09/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
09/28/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
09/28/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
09/28/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
10/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
10/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		

Escherichia coli / E. coli (counts)(Lab Data Transfer)	Criteria	Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
10/04/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
10/04/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	5438 Stonebridge drive - P275	1		
10/04/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2773 Cheakamus Way - S121- SS#477	1		
10/05/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4335 Main Street - Main St. - SS#450	1		
10/05/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8925 Hwy. 99 - S137	1		
10/05/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
10/12/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	3333 Carleton Way - S104 - SS#459	1		
10/12/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
10/12/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
10/12/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
10/12/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
10/12/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
10/12/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Block Alta Lake Rd - SS#482	1		
10/12/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
10/12/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
10/12/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Mount Fee Rd	1		
10/18/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
10/18/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	5438 Stonebridge drive - P275	1		
10/18/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
10/18/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2773 Cheakamus Way - S121- SS#477	1		
10/18/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4335 Main Street - Main St. - SS#450	1		



Escherichia coli / E. coli (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
10/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
10/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
10/19/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
10/24/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
10/24/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
10/24/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Mount Fee Rd	1		
10/24/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
10/24/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
10/24/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
10/24/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
10/24/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
10/25/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
10/25/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
10/31/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
10/31/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
11/01/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
11/01/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
11/01/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
11/01/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
11/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
11/02/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
11/08/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		

Escherichia coli / E. coli (counts)(Lab Data Transfer)	Criteria	Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
11/08/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Mount Fee Rd	1		
11/08/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
11/08/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
11/09/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Block Alta Lake Rd - SS#482	1		
11/09/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
11/09/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	3333 Carleton Way - S104 - SS#459	1		
11/09/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
11/09/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
11/09/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
11/16/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
11/16/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8925 Hwy. 99 - S137	1		
11/22/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
11/22/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
11/22/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Mount Fee Rd	1		
11/22/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	1300 Block Alta Lake Rd - SS#482	1		
11/23/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	3333 Carleton Way - S104 - SS#459	1		
11/23/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
11/23/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
11/23/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
11/23/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
11/23/2016 00:00 < 1 counts/100mL	<=0, OG, P User-Defined	4700 Glacier Dr. - P256 - SS#441	1		

Escherichia coli / E. coli (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
11/28/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
11/28/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
11/29/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
11/29/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
11/29/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
11/29/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
11/29/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
11/30/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
12/05/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
12/05/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
12/05/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
12/05/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
12/06/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
12/06/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
12/06/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Mount Fee Rd	1		
12/06/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
12/06/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
12/06/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
12/12/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
12/12/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
12/12/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		

Escherichia coli / E. coli (counts)(Lab Data Transfer)	Criteria	Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
12/12/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	2149 Lake Placid Rd - S106 - SS#471	1	
12/12/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	8925 Hwy. 99 - S137	1	
12/12/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	5438 Stonebridge drive - P275	1	
12/14/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	4335 Main Street - Main St. - SS#450	1	
12/14/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	3840 Sunridge Drive - P265 - SS#456	1	
12/20/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	1300 Mount Fee Rd	1	
12/20/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	1300 Block Alta Lake Rd - SS#482	1	
12/20/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1	
12/20/2016 00:00	< 1 counts/100mL	<=0, OG, P User-Defined	2400 Taluswood Pl. - P270 - SS#465	1	

# samples:	436	min:	< 1 counts/100mL
# detects:	0	max:	< 1 counts/100mL
# non-detects:	436	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)(Laboratory Report)	Criteria	Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
07/04/2016 11:05	< 1 counts/100mL	<=0, OG, P User-Defined	1300 Block Alta Lake Rd - SS#482	1	
11/15/2016 10:00	< 1 counts/100mL	<=0, OG, P User-Defined	5438 Stonebridge drive - P275	1	
11/15/2016 11:15	< 1 counts/100mL	<=0, OG, P User-Defined	2773 Cheakamus Way - S121- SS#477	1	
11/15/2016 11:45	< 1 counts/100mL	<=0, OG, P User-Defined	2149 Lake Placid Rd - S106 - SS#471	1	
11/15/2016 12:00	< 1 counts/100mL	<=0, OG, P User-Defined	3840 Sunridge Drive - P265 - SS#456	1	
11/15/2016 12:30	ND counts/100mL	<=0, OG, P User-Defined	4335 Main Street - Main St. - SS#450		
11/15/2016 12:50	< 1 counts/100mL	<=0, OG, P User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1	

# samples:	7	min:	< 1 counts/100mL
# detects:	0	max:	< 1 counts/100mL
# non-detects:	7	Geometric Mean:	n/a (based on 0 numerical results)



of Exceedences: 0

Total Coliforms (counts)(Lab Data Transfer)	Criteria	Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
01/05/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	2400 Taluswood Pl. - P270 - SS#465	1	
01/05/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1	
01/05/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	1300 Block Alta Lake Rd - SS#482	1	
01/05/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	1300 Mount Fee Rd	1	
01/06/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1	
01/06/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	8319 Mountianview Dr.- P245 - SS#412	1	
01/06/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1	
01/06/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	4700 Glacier Dr. - P256 - SS#441	1	
01/06/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1	
01/11/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	8330 Rainbow Dr.- S101 - SS#421	1	
01/11/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	8925 Hwy. 99 - S137	1	
01/12/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	5438 Stonebridge drive - P275	1	
01/12/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	2149 Lake Placid Rd - S106 - SS#471	1	
01/12/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	2773 Cheakamus Way - S121- SS#477	1	
01/12/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	3840 Sunridge Drive - P265 - SS#456	1	
01/13/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	4335 Main Street - Main St. - SS#450	1	
01/13/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1	
01/19/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	1300 Mount Fee Rd	1	
01/19/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	2400 Taluswood Pl. - P270 - SS#465	1	
01/19/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	3333 Carleton Way - S104 - SS#459	1	
01/19/2016 00:00	< 1 counts/100mL	<=10, OG, P User-Defined	1300 Block Alta Lake Rd - SS#482	1	



Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
01/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
01/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
01/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
01/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
01/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
01/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
01/25/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
01/26/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
01/26/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
01/26/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
01/26/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
01/26/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
01/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
01/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
02/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
02/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
02/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
02/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
02/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
02/03/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
02/03/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
02/03/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
02/03/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
02/03/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
02/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
02/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
02/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
02/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
02/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
02/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
02/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
02/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
02/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
02/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
02/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
02/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
02/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
02/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
02/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
02/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
02/18/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
02/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
02/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
02/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
02/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
02/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
02/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
02/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
02/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
03/01/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
03/01/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
03/01/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
03/01/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
03/01/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
03/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
03/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
03/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
03/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
03/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
03/08/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
03/08/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
03/08/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
03/08/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
03/08/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
03/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
03/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
03/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
03/15/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
03/15/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
03/15/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
03/15/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
03/15/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
03/15/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
03/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
03/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
03/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
03/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
03/22/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
03/22/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
03/22/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
03/22/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
03/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
03/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
03/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
03/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis E Date/Time
03/29/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
03/29/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
03/29/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
03/29/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
03/29/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
03/29/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
03/30/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
03/30/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
03/30/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
03/30/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
04/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
04/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
04/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
04/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
04/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
04/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
04/05/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
04/05/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
04/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
04/13/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
04/13/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
04/13/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
04/13/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
04/13/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
04/13/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
04/13/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
04/13/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
04/13/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
04/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
04/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
04/26/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
04/26/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
04/26/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
04/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
04/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
04/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
04/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
04/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
04/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
04/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
05/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
05/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
05/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis E Date/Time
05/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
05/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
05/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
05/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
05/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
05/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
05/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
05/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
05/11/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
05/11/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
05/11/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
05/11/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
05/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
05/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
05/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
05/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
05/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
05/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
05/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
05/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
05/18/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis E Date/Time
05/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
05/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
05/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
05/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
05/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
05/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
05/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
05/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
05/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
05/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
05/30/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
05/30/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
05/31/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
05/31/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
05/31/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
05/31/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
05/31/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
06/01/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
06/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
06/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
06/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
06/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis E Date/Time
06/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
06/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
06/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
06/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
06/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
06/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
06/13/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
06/13/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
06/13/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
06/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
06/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
06/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
06/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
06/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
06/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
06/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
06/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
06/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
06/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
06/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
06/21/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis E Date/Time
06/21/2016 00:00	1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459			
06/21/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
06/23/2016 14:15	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
06/28/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
06/28/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
06/28/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
06/28/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
06/28/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
06/28/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
06/28/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
06/29/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
07/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
07/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
07/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
07/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
07/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
07/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
07/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
07/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
07/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
07/11/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
07/11/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis E Date/Time
07/11/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
07/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
07/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
07/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
07/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
07/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
07/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
07/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
07/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
07/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
07/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
07/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
07/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
07/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
07/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
07/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
07/25/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
07/25/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
07/25/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
07/25/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
07/25/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis E Date/Time
07/25/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
07/25/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
07/26/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
08/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
08/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
08/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
08/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
08/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
08/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
08/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
08/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
08/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
08/03/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
08/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
08/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
08/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
08/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
08/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
08/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
08/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
08/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis E Date/Time
08/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
08/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
08/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
08/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
08/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
08/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
08/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
08/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
08/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
08/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
08/22/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
08/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
08/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
08/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
08/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
08/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
08/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
08/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
08/30/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
08/30/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
08/30/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
08/30/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis E Date/Time
08/30/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
08/31/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
08/31/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
08/31/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
08/31/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
08/31/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
09/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
09/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
09/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
09/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
09/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
09/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
09/07/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
09/07/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
09/13/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
09/13/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
09/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
09/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
09/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
09/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
09/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis E Date/Time
09/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
09/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
09/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
09/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
09/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
09/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
09/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
09/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
09/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
09/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
09/21/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
09/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
09/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
09/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
09/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
09/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
09/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
09/28/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
09/28/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
09/28/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
10/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
10/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
10/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
10/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
10/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
10/05/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
10/05/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
10/05/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
10/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
10/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
10/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
10/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
10/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
10/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
10/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
10/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
10/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
10/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
10/18/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
10/18/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
10/18/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
10/18/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
10/18/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
10/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
10/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
10/19/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
10/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
10/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
10/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
10/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
10/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
10/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
10/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
10/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
10/25/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
10/25/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
10/31/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
10/31/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
11/01/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
11/01/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
11/01/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
11/01/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
11/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
11/02/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis E Date/Time
11/08/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
11/08/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
11/08/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
11/08/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
11/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
11/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
11/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
11/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
11/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
11/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
11/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
11/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
11/22/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
11/22/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
11/22/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
11/22/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
11/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
11/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
11/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
11/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
11/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
11/23/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
11/28/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
11/28/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		
11/29/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
11/29/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
11/29/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
11/29/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
11/29/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
11/30/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
12/05/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3333 Carleton Way - S104 - SS#459	1		
12/05/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424	1		
12/05/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4297 Mountain Square - Mountain Ln - SS#453	1		
12/05/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430	1		
12/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
12/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
12/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8319 Mountianview Dr.- P245 - SS#412	1		
12/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
12/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
12/06/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4700 Glacier Dr. - P256 - SS#441	1		
12/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
12/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8330 Rainbow Dr.- S101 - SS#421	1		

Total Coliforms (counts)(Lab Data Transfer)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
12/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
12/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		
12/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	8925 Hwy. 99 - S137	1		
12/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
12/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
12/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
12/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480	1		
12/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Mount Fee Rd	1		
12/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	2400 Taluswood Pl. - P270 - SS#465	1		
12/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		

# samples:	436	min:	< 1 counts/100mL
# detects:	1	max:	1 counts/100mL
# non-detects:	435	Geometric Mean:	1.000 counts/100mL (based on 1 numerical results)
# of Exceedences:	0		

Total Coliforms (counts)(Laboratory Report)		Criteria		Sampling Point Name	Detection Limit/MDL	Analysis Start Date/Time	Analysis End Date/Time
07/04/2016 11:05	< 1 counts/100mL	<=10, OG, P	User-Defined	1300 Block Alta Lake Rd - SS#482	1		
11/15/2016 10:00	< 1 counts/100mL	<=10, OG, P	User-Defined	5438 Stonebridge drive - P275	1		
11/15/2016 11:15	< 1 counts/100mL	<=10, OG, P	User-Defined	2773 Cheakamus Way - S121- SS#477	1		
11/15/2016 11:45	< 1 counts/100mL	<=10, OG, P	User-Defined	2149 Lake Placid Rd - S106 - SS#471	1		
11/15/2016 12:00	< 1 counts/100mL	<=10, OG, P	User-Defined	3840 Sunridge Drive - P265 - SS#456	1		
11/15/2016 12:30	< 1 counts/100mL	<=10, OG, P	User-Defined	4335 Main Street - Main St. - SS#450	1		
11/15/2016 12:50	< 1 counts/100mL	<=10, OG, P	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427	1		

# samples:	7	min:	< 1 counts/100mL
-------------------	---	-------------	------------------



# detects:	0	max:	< 1 counts/100mL
# non-detects:	7	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, U=non-detect, OR=over-range, OG=overgrown,
TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

< means less than lower detection limit shown

> means greater than upper detection limit shown

« means detected & less than number shown

» means detected & greater than number shown

* **Indicates Criteria is exceeded**

Alkalinity (bicarbonate, as CaCO3)		Criteria	Detection Limit/MDL	Sampling Point Name
01/11/2016 12:35	21 mg/L		1	8319 Mountianview Dr.- P245 - SS#412
01/11/2016 13:10	29 mg/L		1	8330 Rainbow Dr.- S101 - SS#421
01/11/2016 13:35	20 mg/L		1	8925 Hwy. 99 - S137
11/17/2016 13:00	34 mg/L		1	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	30 mg/L		1	8925 Hwy. 99 - S137
# samples:	5	min:	20 mg/L	
# detects:	5	max:	34 mg/L	
# non-detects:	0	avg:	26.800 mg/L (based on 5 numerical results)	
# of Exceedences:	0			

Alkalinity (carbonate, as CaCO3)		Criteria	Detection Limit/MDL	Sampling Point Name
01/11/2016 12:35	< 1 mg/L		1	8319 Mountianview Dr.- P245 - SS#412
01/11/2016 13:10	< 1 mg/L		1	8330 Rainbow Dr.- S101 - SS#421
01/11/2016 13:35	< 1 mg/L		1	8925 Hwy. 99 - S137
11/17/2016 13:00	< 1 mg/L		1	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	< 1 mg/L		1	8925 Hwy. 99 - S137
# samples:	5	min:	< 1 mg/L	
# detects:	0	max:	< 1 mg/L	
# non-detects:	5	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Alkalinity (hydroxide, as CaCO3)		Criteria	Detection Limit/MDL	Sampling Point Name
01/11/2016 12:35	< 1 mg/L		1	8319 Mountianview Dr.- P245 - SS#412
01/11/2016 13:10	< 1 mg/L		1	8330 Rainbow Dr.- S101 - SS#421
01/11/2016 13:35	< 1 mg/L		1	8925 Hwy. 99 - S137
11/17/2016 13:00	< 1 mg/L		1	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	< 1 mg/L		1	8925 Hwy. 99 - S137



# samples:	5	min:	< 1 mg/L
# detects:	0	max:	< 1 mg/L
# non-detects:	5	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Alkalinity (phenolphthalein, as CaCO3)	Criteria	Detection Limit/MDL	Sampling Point Name
01/11/2016 12:35	< 1 mg/L	1	8319 Mountianview Dr.- P245 - SS#412
01/11/2016 13:10	< 1 mg/L	1	8330 Rainbow Dr.- S101 - SS#421
01/11/2016 13:35	< 1 mg/L	1	8925 Hwy. 99 - S137
11/17/2016 13:00	< 1 mg/L	1	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	< 1 mg/L	1	8925 Hwy. 99 - S137

# samples:	5	min:	< 1 mg/L
# detects:	0	max:	< 1 mg/L
# non-detects:	5	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Alkalinity (total, as CaCO3)	Criteria	Detection Limit/MDL	Sampling Point Name
01/11/2016 12:35	21 mg/L	1	8319 Mountianview Dr.- P245 - SS#412
01/11/2016 13:10	29 mg/L	1	8330 Rainbow Dr.- S101 - SS#421
01/11/2016 13:35	20 mg/L	1	8925 Hwy. 99 - S137
11/17/2016 13:00	34 mg/L	1	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	30 mg/L	1	8925 Hwy. 99 - S137

# samples:	5	min:	20 mg/L
# detects:	5	max:	34 mg/L
# non-detects:	0	avg:	26.800 mg/L (based on 5 numerical results)
# of Exceedences:	0		

Aluminum (total)	Criteria	Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	0.006 mg/L	0.005	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	< 0.005 mg/L	0.005	8925 Hwy. 99 - S137

# samples:	2	min:	< 0.005 mg/L
# detects:	1	max:	0.006 mg/L
# non-detects:	1	avg:	0.006 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Antimony (total)		Criteria		Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	< 0.0001 mg/L	<=0.006	MAC	0.0001	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	< 0.0001 mg/L	<=0.006	MAC	0.0001	8925 Hwy. 99 - S137

# samples:	2	min:	< 0.0001 mg/L
# detects:	0	max:	< 0.0001 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Arsenic (total)		Criteria		Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	< 0.0005 mg/L	<=0.010	MAC	0.0005	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	< 0.0005 mg/L	<=0.010	MAC	0.0005	8925 Hwy. 99 - S137

# samples:	2	min:	< 0.0005 mg/L
# detects:	0	max:	< 0.0005 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Barium (total)		Criteria		Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	0.039 mg/L	<=1.0	MAC	0.005	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	0.017 mg/L	<=1.0	MAC	0.005	8925 Hwy. 99 - S137

# samples:	2	min:	0.017 mg/L
# detects:	2	max:	0.039 mg/L
# non-detects:	0	avg:	0.028 mg/L (based on 2 numerical results)
# of Exceedences:	0		

Boron (total)		Criteria		Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	0.008 mg/L	<=5	MAC	0.004	2601 Gondola Way - R228 - SS#474

Boron (total)		Criteria	Detection Limit/MDL	Sampling Point Name	
12/14/2016 10:50	< 0.004 mg/L	<=5	MAC	0.004	8925 Hwy. 99 - S137
# samples:	2	min:	< 0.004 mg/L		
# detects:	1	max:	0.008 mg/L		
# non-detects:	1	avg:	0.008 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Bromodichloromethane		Criteria	Detection Limit/MDL	Sampling Point Name	
01/15/2016 10:00	1 ug/L	<=90	User-Defined	1	1300 Mount Fee Rd
01/15/2016 12:30	< 1 ug/L	<=90	User-Defined	1	4335 Main Street - Main St. - SS#450
01/15/2016 13:30	1 ug/L	<=90	User-Defined	1	4700 Glacier Dr. - P256 - SS#441
04/01/2016 08:00	1 ug/L	<=90	User-Defined	1	1300 Mount Fee Rd
04/01/2016 09:30	< 1 ug/L	<=90	User-Defined	1	7314 Blackcomb Way - P267/S126 - SS#427
04/01/2016 11:25	< 1 ug/L	<=90	User-Defined	1	2642 Whistler Road - P264 - SS#462
04/01/2016 11:55	1 ug/L	<=90	User-Defined	1	4335 Main Street - Main St. - SS#450
04/01/2016 12:15	2 ug/L	<=90	User-Defined	1	4700 Glacier Dr. - P256 - SS#441
06/22/2016 11:45	< 1 ug/L	<=90	User-Defined	1	7314 Blackcomb Way - P267/S126 - SS#427
06/22/2016 13:30	1 ug/L	<=90	User-Defined	1	1300 Mount Fee Rd
06/23/2016 08:50	< 1 ug/L	<=90	User-Defined	1	2642 Whistler Road - P264 - SS#462
06/28/2016 13:45	< 1 ug/L	<=90	User-Defined	1	4335 Main Street - Main St. - SS#450
06/28/2016 14:00	3 ug/L	<=90	User-Defined	1	4700 Glacier Dr. - P256 - SS#441
09/15/2016 13:00	< 1 ug/L	<=90	User-Defined	1	1300 Mount Fee Rd
10/12/2016 11:35	< 1 ug/L	<=90	User-Defined	1	2642 Whistler Road - P264 - SS#462
10/12/2016 12:45	< 1 ug/L	<=90	User-Defined	1	4335 Main Street - Main St. - SS#450
10/12/2016 13:00	< 1 ug/L	<=90	User-Defined	1	4700 Glacier Dr. - P256 - SS#441
10/13/2016 13:50	< 1 ug/L	<=90	User-Defined	1	7314 Blackcomb Way - P267/S126 - SS#427

# samples:	18	min:	< 1 ug/L
# detects:	7	max:	3 ug/L
# non-detects:	11	avg:	1.429 ug/L (based on 7 numerical results)
# of Exceedences:	0		

Bromoform		Criteria		Detection Limit/MDL	Sampling Point Name
01/15/2016 10:00	< 1 ug/L	<=90	User-Defined	1	1300 Mount Fee Rd
01/15/2016 12:30	< 1 ug/L	<=90	User-Defined	1	4335 Main Street - Main St. - SS#450
01/15/2016 13:30	< 1 ug/L	<=90	User-Defined	1	4700 Glacier Dr. - P256 - SS#441
04/01/2016 08:00	< 1 ug/L	<=90	User-Defined	1	1300 Mount Fee Rd
04/01/2016 09:30	< 1 ug/L	<=90	User-Defined	1	7314 Blackcomb Way - P267/S126 - SS#427
04/01/2016 11:25	< 1 ug/L	<=90	User-Defined	1	2642 Whistler Road - P264 - SS#462
04/01/2016 11:55	< 1 ug/L	<=90	User-Defined	1	4335 Main Street - Main St. - SS#450
04/01/2016 12:15	< 1 ug/L	<=90	User-Defined	1	4700 Glacier Dr. - P256 - SS#441
06/22/2016 11:45	< 1 ug/L	<=90	User-Defined	1	7314 Blackcomb Way - P267/S126 - SS#427
06/22/2016 13:30	< 1 ug/L	<=90	User-Defined	1	1300 Mount Fee Rd
06/23/2016 08:50	< 1 ug/L	<=90	User-Defined	1	2642 Whistler Road - P264 - SS#462
06/28/2016 13:45	< 1 ug/L	<=90	User-Defined	1	4335 Main Street - Main St. - SS#450
06/28/2016 14:00	< 1 ug/L	<=90	User-Defined	1	4700 Glacier Dr. - P256 - SS#441
09/15/2016 13:00	< 1 ug/L	<=90	User-Defined	1	1300 Mount Fee Rd
10/12/2016 11:35	< 1 ug/L	<=90	User-Defined	1	2642 Whistler Road - P264 - SS#462
10/12/2016 12:45	< 1 ug/L	<=90	User-Defined	1	4335 Main Street - Main St. - SS#450
10/12/2016 13:00	< 1 ug/L	<=90	User-Defined	1	4700 Glacier Dr. - P256 - SS#441
10/13/2016 13:50	< 1 ug/L	<=90	User-Defined	1	7314 Blackcomb Way - P267/S126 - SS#427

# samples:	18	min:	< 1 ug/L
# detects:	0	max:	< 1 ug/L
# non-detects:	18	avg:	n/a (based on 0 numerical results)



of Exceedences: 0

Cadmium (total)		Criteria		Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	< 0.00001 mg/L	<=0.005	MAC	0.00001	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	0.00002 mg/L	<=0.005	MAC	0.00001	8925 Hwy. 99 - S137
# samples:	2	min:	< 0.00001 mg/L		
# detects:	1	max:	0.00002 mg/L		
# non-detects:	1	avg:	0.00002 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Calcium (total)		Criteria		Detection Limit/MDL	Sampling Point Name
01/11/2016 12:35	10.0 mg/L			2.0	8319 Mountainview Dr.- P245 - SS#412
01/11/2016 13:10	19.4 mg/L			2.0	8330 Rainbow Dr.- S101 - SS#421
01/11/2016 13:35	10.5 mg/L			2.0	8925 Hwy. 99 - S137
11/17/2016 13:00	13.7 mg/L			0.2	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	16.6 mg/L			0.2	8925 Hwy. 99 - S137
# samples:	5	min:	10.0 mg/L		
# detects:	5	max:	19.4 mg/L		
# non-detects:	0	avg:	14.040 mg/L (based on 5 numerical results)		
# of Exceedences:	0				

Chloride		Criteria		Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	40.1 mg/L	<=250	AO	1.00	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	4.47 mg/L	<=250	AO	0.10	8925 Hwy. 99 - S137
# samples:	2	min:	4.47 mg/L		
# detects:	2	max:	40.1 mg/L		
# non-detects:	0	avg:	22.285 mg/L (based on 2 numerical results)		
# of Exceedences:	0				

Chlorine (free)		Criteria		Detection Limit/MDL	Sampling Point Name
01/05/2016 10:30	0.25 mg/L	>=0.2, <=0.6	User-Defined		1300 Mount Fee Rd
01/05/2016 12:30	0.33 mg/L	>=0.2, <=0.6	User-Defined		1559 Spring Creek Rd - P273/S132 - SS#480
01/05/2016 12:55	0.43 mg/L	>=0.2, <=0.6	User-Defined		4297 Mountain Square - Mountain Ln - SS#453
01/05/2016 13:10	0.21 mg/L	>=0.2, <=0.6	User-Defined		1300 Block Alta Lake Rd - SS#482
01/05/2016 13:20	0.38 mg/L	>=0.2, <=0.6	User-Defined		4700 Glacier Dr. - P256 - SS#441
01/05/2016 13:40	0.50 mg/L	>=0.2, <=0.6	User-Defined		2400 Taluswood Pl. - P270 - SS#465
01/06/2016 11:30	0.23 mg/L	>=0.2, <=0.6	User-Defined		8319 Mountianview Dr.- P245 - SS#412
01/06/2016 12:00	0.22 mg/L	>=0.2, <=0.6	User-Defined		8407 Golden Bear Pl. - P266/S123 - SS#424
01/06/2016 12:25	0.26 mg/L	>=0.2, <=0.6	User-Defined		6295 Palmer Dr. - Snowflake Park - SS#430
01/11/2016 13:10	0.42 mg/L	>=0.2, <=0.6	User-Defined		8330 Rainbow Dr.- S101 - SS#421
* 01/11/2016 13:35	0.02 mg/L	>=0.2, <=0.6	User-Defined		8925 Hwy. 99 - S137
01/12/2016 10:30	0.24 mg/L	>=0.2, <=0.6	User-Defined		2773 Cheakamus Way - S121- SS#477
* 01/12/2016 11:00	0.03 mg/L	>=0.2, <=0.6	User-Defined		5438 Stonebridge drive - P275
01/12/2016 13:00	0.47 mg/L	>=0.2, <=0.6	User-Defined		2149 Lake Placid Rd - S106 - SS#471
01/12/2016 13:30	0.44 mg/L	>=0.2, <=0.6	User-Defined		3840 Sunridge Drive - P265 - SS#456
01/13/2016 11:30	0.55 mg/L	>=0.2, <=0.6	User-Defined		4335 Main Street - Main St. - SS#450
01/13/2016 12:20	0.60 mg/L	>=0.2, <=0.6	User-Defined		7314 Blackcomb Way - P267/S126 - SS#427
01/19/2016 10:20	0.34 mg/L	>=0.2, <=0.6	User-Defined		1300 Mount Fee Rd
01/19/2016 11:30	0.28 mg/L	>=0.2, <=0.6	User-Defined		1559 Spring Creek Rd - P273/S132 - SS#480
* 01/19/2016 12:05	0.14 mg/L	>=0.2, <=0.6	User-Defined		2400 Taluswood Pl. - P270 - SS#465
* 01/19/2016 12:35	0.12 mg/L	>=0.2, <=0.6	User-Defined		1300 Block Alta Lake Rd - SS#482

Chlorine (free)		Criteria	Detection Limit/MDL	Sampling Point Name
01/19/2016 13:45	0.45 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
01/20/2016 09:45	0.26 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountianview Dr.- P245 - SS#412
01/20/2016 10:10	0.28 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
01/20/2016 10:35	0.29 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
01/20/2016 11:10	0.37 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
01/20/2016 11:40	0.37 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
* 01/25/2016 11:20	0.09 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
01/26/2016 09:40	0.38 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
01/26/2016 10:10	0.34 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
01/26/2016 10:45	0.33 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
01/26/2016 12:00	0.53 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
01/26/2016 12:35	0.41 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
01/27/2016 09:10	0.54 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 01/27/2016 09:40	0.09 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
02/02/2016 10:15	0.33 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
02/02/2016 12:00	0.34 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
* 02/02/2016 13:00	0.17 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
02/02/2016 13:25	0.31 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
02/02/2016 13:50	0.26 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
* 02/03/2016 09:50	0.13 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountianview Dr.- P245 - SS#412
02/03/2016 10:45	0.22 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424

Chlorine (free)		Criteria	Detection Limit/MDL	Sampling Point Name
02/03/2016 12:10	0.20 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
* 02/03/2016 12:50	0.10 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
02/03/2016 13:20	0.42 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
* 02/09/2016 11:00	0.05 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
02/09/2016 13:00	0.24 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
02/09/2016 13:25	0.32 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
02/09/2016 13:50	0.26 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
02/10/2016 08:20	0.32 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
02/10/2016 08:50	0.32 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
02/10/2016 11:40	0.20 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
02/16/2016 10:30	0.24 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
02/16/2016 11:00	0.39 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
02/16/2016 11:35	0.28 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
02/16/2016 13:00	0.48 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
02/16/2016 13:45	0.39 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
02/17/2016 09:00	0.54 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
02/17/2016 10:40	0.31 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountainview Dr.- P245 - SS#412
02/17/2016 11:30	0.53 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
02/17/2016 12:30	0.40 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
02/17/2016 13:00	0.46 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
02/23/2016 08:40	0.41 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275

Chlorine (free)		Criteria	Detection Limit/MDL	Sampling Point Name
02/23/2016 11:00	0.33 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
02/23/2016 12:00	0.44 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
02/23/2016 12:30	0.35 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
02/24/2016 07:30	0.44 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 02/24/2016 10:15	0.15 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
02/24/2016 10:40	0.46 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
02/24/2016 11:15	0.38 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
03/01/2016 08:15	0.32 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountainview Dr.- P245 - SS#412
03/01/2016 10:30	0.41 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
03/01/2016 11:40	0.37 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
03/01/2016 12:15	0.29 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
03/01/2016 12:45	0.42 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
03/02/2016 08:45	0.37 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
03/02/2016 11:25	0.23 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
03/02/2016 11:50	0.27 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
03/02/2016 12:30	0.34 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
03/02/2016 13:00	0.40 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
03/08/2016 08:30	0.23 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
03/08/2016 11:40	0.39 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
03/08/2016 12:00	0.41 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
03/08/2016 12:25	0.49 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456

Chlorine (free)		Criteria	Detection Limit/MDL	Sampling Point Name
03/08/2016 13:15	0.49 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 03/09/2016 09:45	0.02 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
03/09/2016 10:15	0.31 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
03/09/2016 12:25	0.48 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
03/22/2016 08:45	0.44 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
03/22/2016 09:30	0.39 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 03/22/2016 10:50	0.14 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
03/22/2016 13:30	0.27 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
03/23/2016 10:00	0.31 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
03/23/2016 10:45	0.47 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
03/23/2016 11:05	0.43 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
* 03/23/2016 11:30	0.69 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
03/29/2016 09:40	0.58 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
03/29/2016 10:00	0.25 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
03/29/2016 10:45	0.36 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
03/29/2016 11:00	0.23 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
03/29/2016 11:50	0.49 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
03/29/2016 13:05	0.49 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
03/29/2016 13:35	0.40 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
03/30/2016 09:00	0.20 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
03/30/2016 10:15	0.22 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482

Chlorine (free)	Criteria	Detection Limit/MDL	Sampling Point Name	
03/30/2016 11:15	0.26 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountianview Dr.- P245 - SS#412
* 04/04/2016 08:30	0.12 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
* 04/04/2016 09:40	0.15 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
04/04/2016 11:00	0.36 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
04/04/2016 11:30	0.51 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
04/04/2016 11:50	0.23 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
04/04/2016 12:15	0.52 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
04/05/2016 09:20	0.55 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 04/05/2016 10:15	0.06 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
04/12/2016 09:30	0.29 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountianview Dr.- P245 - SS#412
04/13/2016 08:10	0.51 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
04/13/2016 08:45	0.50 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
04/13/2016 10:35	0.45 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
04/13/2016 11:00	0.45 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
04/13/2016 11:35	0.50 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
04/13/2016 11:55	0.35 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
04/13/2016 12:20	0.50 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
04/13/2016 13:30	0.50 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
04/13/2016 13:45	0.52 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
04/19/2016 13:05	0.33 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 04/19/2016 13:30	0.61 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450

Chlorine (free)		Criteria	Detection Limit/MDL	Sampling Point Name
04/20/2016 09:00	0.22 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
04/20/2016 10:45	0.60 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
04/20/2016 11:40	0.43 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
04/20/2016 12:00	0.37 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
* 04/20/2016 12:25	0.18 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
04/27/2016 08:00	0.20 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
* 04/27/2016 09:00	0.04 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
04/27/2016 09:25	0.35 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
04/27/2016 10:20	0.41 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
04/27/2016 11:00	0.30 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
04/27/2016 11:10	0.33 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountainview Dr.- P245 - SS#412
04/27/2016 11:26	0.27 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
04/27/2016 11:43	0.37 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
04/27/2016 12:37	0.26 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
04/27/2016 12:57	0.42 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
* 05/04/2016 08:30	0.14 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
05/04/2016 09:00	0.24 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 05/04/2016 09:30	0.03 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
* 05/04/2016 11:40	0.07 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
05/04/2016 12:00	0.52 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 05/04/2016 12:30	0.61 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450

Chlorine (free)		Criteria	Detection Limit/MDL	Sampling Point Name
05/10/2016 12:40	0.49 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
05/10/2016 13:15	0.43 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
05/11/2016 08:55	0.36 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
05/11/2016 09:00	0.36 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
05/11/2016 10:00	0.27 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 05/11/2016 10:40	0.13 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
05/11/2016 10:55	0.24 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
05/11/2016 11:10	0.26 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
05/11/2016 11:50	0.40 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
05/11/2016 12:15	0.28 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountainview Dr.- P245 - SS#412
05/16/2016 12:00	0.26 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
05/16/2016 12:20	0.31 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
05/16/2016 12:30	0.47 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
05/16/2016 13:10	0.35 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
05/16/2016 13:30	0.25 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 05/17/2016 09:15	0.00 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 05/17/2016 11:10	0.08 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
* 05/18/2016 08:00	0.61 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
05/24/2016 07:41	0.50 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
05/24/2016 07:56	0.29 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountainview Dr.- P245 - SS#412

Chlorine (free)		Criteria	Detection Limit/MDL	Sampling Point Name
05/24/2016 08:19	0.50 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
05/24/2016 08:37	0.28 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
05/24/2016 08:56	0.54 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
05/24/2016 09:56	0.50 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
05/24/2016 10:15	0.49 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
05/24/2016 10:42	0.34 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
05/24/2016 11:04	0.28 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
05/24/2016 11:43	0.37 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
05/30/2016 12:30	0.23 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
05/30/2016 13:30	0.23 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
05/31/2016 07:47	0.53 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
* 05/31/2016 08:54	0.09 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
* 05/31/2016 11:16	0.66 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
05/31/2016 11:33	0.54 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
05/31/2016 11:52	0.54 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
06/01/2016 11:15	0.25 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
06/06/2016 07:28	0.40 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
06/06/2016 07:48	0.25 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountianview Dr.- P245 - SS#412
06/06/2016 08:08	0.23 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
* 06/06/2016 08:33	0.16 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453

Chlorine (free)		Criteria	Detection Limit/MDL	Sampling Point Name
06/06/2016 09:22	0.38 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
* 06/06/2016 09:43	0.62 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
06/06/2016 10:12	0.59 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
06/06/2016 11:16	0.44 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
06/06/2016 11:35	0.57 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
06/06/2016 12:25	0.33 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
* 06/13/2016 10:45	0.08 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
06/13/2016 13:15	0.41 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
06/13/2016 13:45	0.37 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
06/14/2016 08:00	0.22 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
* 06/14/2016 08:30	0.16 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
06/14/2016 09:00	0.45 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 06/14/2016 11:05	0.12 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
06/20/2016 09:37	0.36 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
06/20/2016 09:56	0.57 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
06/20/2016 10:13	0.46 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
06/20/2016 11:42	0.32 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
06/20/2016 12:03	0.44 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
06/20/2016 12:21	0.35 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
06/20/2016 12:43	0.28 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
06/21/2016 08:10	0.36 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459

Chlorine (free)		Criteria	Detection Limit/MDL	Sampling Point Name
06/21/2016 10:10	0.32 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountianview Dr.- P245 - SS#412
06/21/2016 13:00	0.35 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
06/28/2016 08:37	0.32 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
06/28/2016 09:00	0.41 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 06/28/2016 09:16	0.0 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
06/28/2016 09:38	0.21 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
06/28/2016 09:57	0.50 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
06/28/2016 10:30	0.45 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
06/28/2016 11:44	0.25 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
06/29/2016 10:00	0.28 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
07/05/2016 08:15	0.59 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
07/05/2016 08:31	0.31 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountianview Dr.- P245 - SS#412
07/05/2016 09:01	0.42 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
07/05/2016 09:31	0.48 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
07/05/2016 09:48	0.47 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
07/05/2016 10:21	0.48 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
07/05/2016 10:43	0.54 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
07/05/2016 11:05	0.44 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
07/05/2016 11:20	0.59 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
07/05/2016 11:39	0.36 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
07/11/2016 12:45	0.35 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480

Chlorine (free)		Criteria	Detection Limit/MDL	Sampling Point Name
07/11/2016 13:00	0.36 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
* 07/11/2016 13:40	0.01 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
07/12/2016 08:35	0.45 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
07/12/2016 10:15	0.49 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
07/12/2016 10:40	0.48 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
07/12/2016 11:20	0.49 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
07/12/2016 13:40	0.45 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
07/13/2016 09:30	0.23 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
07/25/2016 08:30	0.44 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
07/25/2016 09:00	0.40 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
* 07/25/2016 09:30	0.63 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
07/25/2016 10:00	0.39 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 07/25/2016 11:45	0.15 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
07/25/2016 13:00	0.52 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
07/25/2016 13:30	0.58 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
07/26/2016 08:15	0.58 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
08/02/2016	0.57 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
08/02/2016 07:27	0.50 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
08/02/2016 07:47	0.39 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountianview Dr.- P245 - SS#412
08/02/2016 08:11	0.20 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
08/02/2016 08:27	0.49 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453

Chlorine (free)		Criteria	Detection Limit/MDL	Sampling Point Name
08/02/2016 08:46	0.48 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
08/02/2016 09:45	0.58 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
08/02/2016 10:22	0.37 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
08/02/2016 10:52	0.49 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
08/02/2016 11:09	0.42 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
08/09/2016 09:30	0.32 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
08/09/2016 12:30	0.46 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
08/09/2016 13:10	0.53 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
08/09/2016 13:45	0.58 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
08/10/2016 09:00	0.41 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
08/10/2016 09:30	0.43 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
08/10/2016 11:25	0.24 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
08/10/2016 12:00	0.43 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
08/16/2016 10:10	0.28 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
08/16/2016 10:50	0.46 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
08/16/2016 12:45	0.46 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
08/16/2016 13:10	0.37 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
08/16/2016 13:40	0.51 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
08/17/2016 08:00	0.35 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
08/17/2016 09:50	0.40 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
08/17/2016 10:15	0.42 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430

Chlorine (free)		Criteria	Detection Limit/MDL	Sampling Point Name
08/17/2016 11:45	0.45 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
08/17/2016 12:05	0.31 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountianview Dr.- P245 - SS#412
08/22/2016 10:45	0.44 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
08/23/2016 01:30	0.31 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
08/23/2016 08:00	0.44 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
08/23/2016 08:45	0.46 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
08/23/2016 09:20	0.47 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
08/23/2016 09:50	0.29 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
08/23/2016 10:15	0.49 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
08/23/2016 12:20	0.42 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
08/30/2016 08:40	0.26 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
08/30/2016 11:40	0.36 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
08/30/2016 12:20	0.42 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
08/30/2016 12:45	0.43 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
08/30/2016 13:40	0.36 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
08/31/2016 10:15	0.35 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountianview Dr.- P245 - SS#412
08/31/2016 11:25	0.45 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
08/31/2016 12:50	0.40 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
08/31/2016 13:10	0.33 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
08/31/2016 13:30	0.41 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
09/06/2016 09:15	0.38 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275

Chlorine (free)		Criteria	Detection Limit/MDL	Sampling Point Name
09/06/2016 11:00	0.47 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
09/06/2016 12:00	0.47 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
09/06/2016 12:35	0.42 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
09/06/2016 13:00	0.45 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
09/06/2016 13:40	0.51 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
09/07/2016 10:40	0.33 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
09/07/2016 10:55	0.45 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
09/13/2016 12:10	0.23 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
09/13/2016 12:45	0.39 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
09/14/2016 08:45	0.29 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
09/14/2016 09:20	0.45 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
09/14/2016 09:45	0.32 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
09/14/2016 10:15	0.51 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
09/14/2016 11:15	0.35 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
09/14/2016 12:05	0.34 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
09/14/2016 12:30	0.34 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
09/14/2016 13:40	0.34 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountainview Dr.- P245 - SS#412
09/19/2016 10:10	0.38 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
09/19/2016 11:40	0.39 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
09/19/2016 12:05	0.46 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
09/19/2016 13:20	0.32 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
09/19/2016 13:45	0.43 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450

Chlorine (free)		Criteria	Detection Limit/MDL	Sampling Point Name
09/20/2016 08:15	0.33 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
09/20/2016 08:45	0.35 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
09/20/2016 11:15	0.50 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
09/27/2016 10:30	0.30 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
09/27/2016 10:50	0.45 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
09/27/2016 11:10	0.20 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
09/27/2016 11:50	0.27 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
09/27/2016 12:15	0.29 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
09/27/2016 12:40	0.28 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
09/28/2016 09:45	0.33 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountainview Dr.- P245 - SS#412
09/28/2016 10:55	0.33 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
09/28/2016 13:15	0.25 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
* 10/04/2016 09:30	0.11 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
* 10/04/2016 11:40	0.15 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
10/04/2016 12:30	0.26 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 10/04/2016 13:00	0.03 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
10/04/2016 13:40	0.40 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
10/05/2016 08:00	0.40 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
10/05/2016 09:15	0.39 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 10/05/2016 10:35	0.17 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
* 10/11/2016 01:20	0.12 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453

Chlorine (free)		Criteria	Detection Limit/MDL	Sampling Point Name
10/11/2016 08:20	0.31 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
10/11/2016 09:10	0.21 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 10/11/2016 09:40	0.18 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
10/11/2016 10:05	0.29 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
10/11/2016 10:40	0.22 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
* 10/11/2016 11:05	0.18 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
10/11/2016 11:20	0.45 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountianview Dr.- P245 - SS#412
* 10/11/2016 12:20	0.10 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
10/11/2016 12:40	0.23 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
10/18/2016 08:30	0.27 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 10/18/2016 09:00	0.14 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
10/18/2016 10:30	0.34 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
10/18/2016 11:10	0.40 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
10/18/2016 11:40	0.44 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
10/19/2016 08:25	0.33 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
10/19/2016 09:20	0.28 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
10/19/2016 09:45	0.39 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
10/24/2016 07:35	0.44 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
10/24/2016 08:06	0.30 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountianview Dr.- P245 - SS#412
10/24/2016 08:31	0.21 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
10/24/2016 09:09	0.36 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
10/24/2016 09:39	0.36 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480

Chlorine (free)		Criteria	Detection Limit/MDL	Sampling Point Name
10/24/2016 10:10	0.45 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
10/24/2016 10:10	0.45 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
10/24/2016 10:15	0.20 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
10/24/2016 10:32	0.35 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
10/24/2016 11:32	0.47 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
10/31/2016 12:30	0.39 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
10/31/2016 13:40	0.22 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
11/01/2016 09:45	0.26 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
11/01/2016 10:50	0.30 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 11/01/2016 11:20	0.04 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
11/01/2016 12:15	0.35 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
11/01/2016 12:50	0.29 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
11/02/2016 08:50	0.25 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
11/08/2016 10:30	0.33 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
11/08/2016 12:00	0.24 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
11/08/2016 12:25	0.51 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
11/08/2016 13:30	0.29 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
11/09/2016 08:30	0.27 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
11/09/2016 10:30	0.37 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
11/09/2016 11:00	0.44 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
11/09/2016 11:40	0.42 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430

Chlorine (free)		Criteria	Detection Limit/MDL	Sampling Point Name
11/09/2016 12:00	0.35 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
11/09/2016 12:25	0.29 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountianview Dr.- P245 - SS#412
11/15/2016 10:00	0.21 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
11/15/2016 11:15	0.35 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
11/15/2016 11:45	0.29 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 11/15/2016 12:00	0.04 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
11/15/2016 12:30	0.35 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
11/15/2016 12:50	0.46 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
11/16/2016 09:00	0.29 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
11/16/2016 11:10	0.47 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
11/22/2016 09:45	0.38 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
11/22/2016 12:15	0.24 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
11/22/2016 12:35	0.43 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
11/22/2016 13:00	0.22 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
11/23/2016 09:20	0.24 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
11/23/2016 09:50	0.23 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
11/23/2016 10:10	0.35 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
11/23/2016 10:50	0.25 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
11/23/2016 11:10	0.47 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
11/23/2016 12:40	0.33 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountianview Dr.- P245 - SS#412
11/28/2016 11:10	0.27 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
11/28/2016 11:35	0.38 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421

Chlorine (free)	Criteria	Detection Limit/MDL	Sampling Point Name	
* 11/29/2016 08:55	0.08 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
11/29/2016 10:00	0.42 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
11/29/2016 11:00	0.28 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
11/29/2016 11:15	0.41 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477
11/29/2016 11:40	0.20 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
11/30/2016 08:15	0.47 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
12/05/2016 10:15	0.56 mg/L	>=0.2, <=0.6	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
12/05/2016 11:00	0.49 mg/L	>=0.2, <=0.6	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
12/05/2016 11:30	0.53 mg/L	>=0.2, <=0.6	User-Defined	3333 Carleton Way - S104 - SS#459
12/05/2016 11:45	0.53 mg/L	>=0.2, <=0.6	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
12/06/2016 09:20	0.43 mg/L	>=0.2, <=0.6	User-Defined	8319 Mountianview Dr.- P245 - SS#412
12/06/2016 09:50	0.39 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
12/06/2016 10:10	0.38 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
12/06/2016 10:30	0.38 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482
12/06/2016 11:45	0.43 mg/L	>=0.2, <=0.6	User-Defined	4700 Glacier Dr. - P256 - SS#441
12/06/2016 12:20	0.48 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
12/13/2016 09:25	0.57 mg/L	>=0.2, <=0.6	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
12/13/2016 09:50	0.28 mg/L	>=0.2, <=0.6	User-Defined	8330 Rainbow Dr.- S101 - SS#421
12/13/2016 10:20	0.39 mg/L	>=0.2, <=0.6	User-Defined	8925 Hwy. 99 - S137
12/13/2016 11:15	0.30 mg/L	>=0.2, <=0.6	User-Defined	2149 Lake Placid Rd - S106 - SS#471
12/13/2016 11:40	0.43 mg/L	>=0.2, <=0.6	User-Defined	2773 Cheakamus Way - S121- SS#477

Chlorine (free)		Criteria	Detection Limit/MDL	Sampling Point Name
12/13/2016 12:00	0.29 mg/L	>=0.2, <=0.6	User-Defined	5438 Stonebridge drive - P275
12/14/2016 08:35	0.46 mg/L	>=0.2, <=0.6	User-Defined	3840 Sunridge Drive - P265 - SS#456
12/14/2016 08:55	0.46 mg/L	>=0.2, <=0.6	User-Defined	4335 Main Street - Main St. - SS#450
12/20/2016 11:35	0.30 mg/L	>=0.2, <=0.6	User-Defined	1300 Mount Fee Rd
12/20/2016 12:25	0.36 mg/L	>=0.2, <=0.6	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
12/20/2016 13:10	0.42 mg/L	>=0.2, <=0.6	User-Defined	2400 Taluswood Pl. - P270 - SS#465
12/20/2016 13:35	0.28 mg/L	>=0.2, <=0.6	User-Defined	1300 Block Alta Lake Rd - SS#482

# samples:	428	min:	0.0 mg/L
# detects:	428	max:	0.69 mg/L
# non-detects:	0	avg:	0.353 mg/L (based on 428 numerical results)
# of Exceedences:	51		

Chloroform		Criteria	Detection Limit/MDL	Sampling Point Name
01/15/2016 10:00	2 ug/L	<=90	User-Defined	1300 Mount Fee Rd
01/15/2016 12:30	17 ug/L	<=90	User-Defined	4335 Main Street - Main St. - SS#450
01/15/2016 13:30	36 ug/L	<=90	User-Defined	4700 Glacier Dr. - P256 - SS#441
04/01/2016 08:00	4 ug/L	<=90	User-Defined	1300 Mount Fee Rd
04/01/2016 09:30	< 1 ug/L	<=90	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
04/01/2016 11:25	< 1 ug/L	<=90	User-Defined	2642 Whistler Road - P264 - SS#462
04/01/2016 11:55	13 ug/L	<=90	User-Defined	4335 Main Street - Main St. - SS#450
04/01/2016 12:15	31 ug/L	<=90	User-Defined	4700 Glacier Dr. - P256 - SS#441
06/22/2016 11:45	18 ug/L	<=90	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
06/22/2016 13:30	3 ug/L	<=90	User-Defined	1300 Mount Fee Rd
06/23/2016 08:50	23 ug/L	<=90	User-Defined	2642 Whistler Road - P264 - SS#462
06/28/2016 13:45	18 ug/L	<=90	User-Defined	4335 Main Street - Main St. - SS#450

Chloroform		Criteria	Detection Limit/MDL	Sampling Point Name
06/28/2016 14:00	33 ug/L	<=90	User-Defined	4700 Glacier Dr. - P256 - SS#441
09/15/2016 13:00	1 ug/L	<=90	User-Defined	1300 Mount Fee Rd
10/12/2016 11:35	< 1 ug/L	<=90	User-Defined	2642 Whistler Road - P264 - SS#462
10/12/2016 12:45	36 ug/L	<=90	User-Defined	4335 Main Street - Main St. - SS#450
10/12/2016 13:00	44 ug/L	<=90	User-Defined	4700 Glacier Dr. - P256 - SS#441
10/13/2016 13:50	< 1 ug/L	<=90	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427

# samples:	18	min:	< 1 ug/L
# detects:	14	max:	44 ug/L
# non-detects:	4	avg:	19.929 ug/L (based on 14 numerical results)
# of Exceedences:	0		

Chromium (total)		Criteria	Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	0.0005 mg/L	<=0.05	MAC	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	< 0.0005 mg/L	<=0.05	MAC	8925 Hwy. 99 - S137

# samples:	2	min:	< 0.0005 mg/L
# detects:	1	max:	0.0005 mg/L
# non-detects:	1	avg:	0.0005 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Cobalt (total)		Criteria	Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	< 0.00005 mg/L		0.00005	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	< 0.00005 mg/L		0.00005	8925 Hwy. 99 - S137

# samples:	2	min:	< 0.00005 mg/L
# detects:	0	max:	< 0.00005 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Colour	Criteria	Detection Limit/MDL	Sampling Point Name
01/11/2016 12:35	< 5 TCU	<=15 AO	8319 Mountainview Dr.- P245 - SS#412
01/11/2016 13:10	< 5 TCU	<=15 AO	8330 Rainbow Dr.- S101 - SS#421
01/11/2016 13:35	< 5 TCU	<=15 AO	8925 Hwy. 99 - S137
11/17/2016 13:00	< 5 TCU	<=15 AO	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	< 5 TCU	<=15 AO	8925 Hwy. 99 - S137

# samples:	5	min:	< 5 TCU
# detects:	0	max:	< 5 TCU
# non-detects:	5	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Conductivity	Criteria	Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	245 umho/cm	2	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	124 umho/cm	2	8925 Hwy. 99 - S137

# samples:	2	min:	124 umho/cm
# detects:	2	max:	245 umho/cm
# non-detects:	0	avg:	184.500 umho/cm (based on 2 numerical results)
# of Exceedences:	0		

Copper (total)	Criteria	Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	0.0187 mg/L	<=1.0 AO	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	0.0379 mg/L	<=1.0 AO	8925 Hwy. 99 - S137

# samples:	2	min:	0.0187 mg/L
# detects:	2	max:	0.0379 mg/L
# non-detects:	0	avg:	0.0283 mg/L (based on 2 numerical results)
# of Exceedences:	0		

Cyanide (total)	Criteria	Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	< 0.0020 mg/L	0.0020	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	< 0.0020 mg/L	0.0020	8925 Hwy. 99 - S137

# samples:	2	min:	< 0.0020 mg/L
# detects:	0	max:	< 0.0020 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Dibromoacetic acid	Criteria	Detection Limit/MDL	Sampling Point Name
01/15/2016 10:00	< 0.002 mg/L	0.002	1300 Mount Fee Rd
01/15/2016 12:30	< 0.002 mg/L	0.002	4335 Main Street - Main St. - SS#450
01/15/2016 13:30	< 0.002 mg/L	0.002	4700 Glacier Dr. - P256 - SS#441
04/01/2016 08:00	< 0.002 mg/L	0.002	1300 Mount Fee Rd
04/01/2016 09:30	< 0.002 mg/L	0.002	7314 Blackcomb Way - P267/S126 - SS#427
04/01/2016 11:25	< 0.002 mg/L	0.002	2642 Whistler Road - P264 - SS#462
04/01/2016 11:55	< 0.002 mg/L	0.002	4335 Main Street - Main St. - SS#450
04/01/2016 12:15	< 0.002 mg/L	0.002	4700 Glacier Dr. - P256 - SS#441
06/22/2016 11:45	< 0.002 mg/L	0.002	7314 Blackcomb Way - P267/S126 - SS#427
06/22/2016 13:30	< 0.002 mg/L	0.002	1300 Mount Fee Rd
06/23/2016 08:50	< 0.002 mg/L	0.002	2642 Whistler Road - P264 - SS#462
06/28/2016 13:45	< 0.002 mg/L	0.002	4335 Main Street - Main St. - SS#450
06/28/2016 14:00	< 0.002 mg/L	0.002	4700 Glacier Dr. - P256 - SS#441
09/15/2016 13:00	< 0.002 mg/L	0.002	1300 Mount Fee Rd
10/12/2016 11:35	< 0.002 mg/L	0.002	2642 Whistler Road - P264 - SS#462
10/12/2016 12:45	< 0.002 mg/L	0.002	4335 Main Street - Main St. - SS#450
10/12/2016 13:00	< 0.002 mg/L	0.002	4700 Glacier Dr. - P256 - SS#441
10/13/2016 13:50	< 0.002 mg/L	0.002	7314 Blackcomb Way - P267/S126 - SS#427

# samples:	18	min:	< 0.002 mg/L
# detects:	0	max:	< 0.002 mg/L
# non-detects:	18	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Dibromochloromethane		Criteria		Detection Limit/MDL	Sampling Point Name
01/15/2016 10:00	< 1 ug/L	<=90	User-Defined	1	1300 Mount Fee Rd
01/15/2016 12:30	< 1 ug/L	<=90	User-Defined	1	4335 Main Street - Main St. - SS#450
01/15/2016 13:30	< 1 ug/L	<=90	User-Defined	1	4700 Glacier Dr. - P256 - SS#441
04/01/2016 08:00	< 1 ug/L	<=90	User-Defined	1	1300 Mount Fee Rd
04/01/2016 09:30	< 1 ug/L	<=90	User-Defined	1	7314 Blackcomb Way - P267/S126 - SS#427
04/01/2016 11:25	< 1 ug/L	<=90	User-Defined	1	2642 Whistler Road - P264 - SS#462
04/01/2016 11:55	1 ug/L	<=90	User-Defined	1	4335 Main Street - Main St. - SS#450
04/01/2016 12:15	< 1 ug/L	<=90	User-Defined	1	4700 Glacier Dr. - P256 - SS#441
06/22/2016 11:45	< 1 ug/L	<=90	User-Defined	1	7314 Blackcomb Way - P267/S126 - SS#427
06/22/2016 13:30	< 1 ug/L	<=90	User-Defined	1	1300 Mount Fee Rd
06/23/2016 08:50	< 1 ug/L	<=90	User-Defined	1	2642 Whistler Road - P264 - SS#462
06/28/2016 13:45	< 1 ug/L	<=90	User-Defined	1	4335 Main Street - Main St. - SS#450
06/28/2016 14:00	< 1 ug/L	<=90	User-Defined	1	4700 Glacier Dr. - P256 - SS#441
09/15/2016 13:00	< 1 ug/L	<=90	User-Defined	1	1300 Mount Fee Rd
10/12/2016 11:35	< 1 ug/L	<=90	User-Defined	1	2642 Whistler Road - P264 - SS#462
10/12/2016 12:45	< 1 ug/L	<=90	User-Defined	1	4335 Main Street - Main St. - SS#450
10/12/2016 13:00	< 1 ug/L	<=90	User-Defined	1	4700 Glacier Dr. - P256 - SS#441
10/13/2016 13:50	< 1 ug/L	<=90	User-Defined	1	7314 Blackcomb Way - P267/S126 - SS#427

# samples:	18	min:	< 1 ug/L
# detects:	1	max:	1 ug/L
# non-detects:	17	avg:	1.000 ug/L (based on 1 numerical results)
# of Exceedences:	0		



Dichloroacetic acid		Criteria	Detection Limit/MDL	Sampling Point Name
01/15/2016 10:00	0.002 mg/L		0.002	1300 Mount Fee Rd
01/15/2016 12:30	0.008 mg/L		0.002	4335 Main Street - Main St. - SS#450
01/15/2016 13:30	0.021 mg/L		0.002	4700 Glacier Dr. - P256 - SS#441
04/01/2016 08:00	< 0.002 mg/L		0.002	1300 Mount Fee Rd
04/01/2016 09:30	< 0.002 mg/L		0.002	7314 Blackcomb Way - P267/S126 - SS#427
04/01/2016 11:25	< 0.002 mg/L		0.002	2642 Whistler Road - P264 - SS#462
04/01/2016 11:55	0.009 mg/L		0.002	4335 Main Street - Main St. - SS#450
04/01/2016 12:15	0.022 mg/L		0.002	4700 Glacier Dr. - P256 - SS#441
06/22/2016 11:45	0.012 mg/L		0.002	7314 Blackcomb Way - P267/S126 - SS#427
06/22/2016 13:30	0.002 mg/L		0.002	1300 Mount Fee Rd
06/23/2016 08:50	0.013 mg/L		0.002	2642 Whistler Road - P264 - SS#462
06/28/2016 13:45	0.010 mg/L		0.002	4335 Main Street - Main St. - SS#450
06/28/2016 14:00	0.020 mg/L		0.002	4700 Glacier Dr. - P256 - SS#441
09/15/2016 13:00	< 0.002 mg/L		0.002	1300 Mount Fee Rd
10/12/2016 11:35	< 0.002 mg/L		0.002	2642 Whistler Road - P264 - SS#462
10/12/2016 12:45	0.027 mg/L		0.002	4335 Main Street - Main St. - SS#450
10/12/2016 13:00	0.032 mg/L		0.002	4700 Glacier Dr. - P256 - SS#441
10/13/2016 13:50	< 0.002 mg/L		0.002	7314 Blackcomb Way - P267/S126 - SS#427

# samples:	18	min:	< 0.002 mg/L
# detects:	12	max:	0.032 mg/L
# non-detects:	6	avg:	0.015 mg/L (based on 12 numerical results)
# of Exceedences:	0		

Fluoride		Criteria	Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	< 0.10 mg/L	<=1.5 MAC	0.10	2601 Gondola Way - R228 - SS#474

Fluoride		Criteria		Detection Limit/MDL	Sampling Point Name
12/14/2016 10:50	< 0.10 mg/L	<=1.5	MAC	0.10	8925 Hwy. 99 - S137
# samples:	2	min:	< 0.10 mg/L		
# detects:	0	max:	< 0.10 mg/L		
# non-detects:	2	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Haloacetic acids 5 / HAA5		Criteria		Detection Limit/MDL	Sampling Point Name
01/15/2016 10:00	0.006 mg/L			0.002	1300 Mount Fee Rd
01/15/2016 12:30	0.018 mg/L			0.002	4335 Main Street - Main St. - SS#450
01/15/2016 13:30	0.054 mg/L			0.002	4700 Glacier Dr. - P256 - SS#441
04/01/2016 08:00	< 0.002 mg/L			0.002	1300 Mount Fee Rd
04/01/2016 09:30	< 0.002 mg/L			0.002	7314 Blackcomb Way - P267/S126 - SS#427
04/01/2016 11:25	< 0.002 mg/L			0.002	2642 Whistler Road - P264 - SS#462
04/01/2016 11:55	0.020 mg/L			0.002	4335 Main Street - Main St. - SS#450
04/01/2016 12:15	0.049 mg/L			0.002	4700 Glacier Dr. - P256 - SS#441
06/22/2016 11:45	0.021 mg/L			0.002	7314 Blackcomb Way - P267/S126 - SS#427
06/22/2016 13:30	0.002 mg/L			0.002	1300 Mount Fee Rd
06/23/2016 08:50	0.024 mg/L			0.002	2642 Whistler Road - P264 - SS#462
06/28/2016 13:45	0.018 mg/L			0.002	4335 Main Street - Main St. - SS#450
06/28/2016 14:00	0.046 mg/L			0.002	4700 Glacier Dr. - P256 - SS#441
09/15/2016 13:00	< 0.002 mg/L			0.002	1300 Mount Fee Rd
10/12/2016 11:35	< 0.002 mg/L			0.002	2642 Whistler Road - P264 - SS#462
10/12/2016 12:45	0.049 mg/L			0.002	4335 Main Street - Main St. - SS#450
10/12/2016 13:00	0.068 mg/L			0.002	4700 Glacier Dr. - P256 - SS#441
10/13/2016 13:50	< 0.002 mg/L			0.002	7314 Blackcomb Way - P267/S126 - SS#427

# samples:	18	min:	< 0.002 mg/L
# detects:	12	max:	0.068 mg/L
# non-detects:	6	avg:	0.031 mg/L (based on 12 numerical results)
# of Exceedences:	0		

Hardness (total, as CaCO3)		Criteria	Detection Limit/MDL	Sampling Point Name
01/11/2016 12:35	26.6 mg/L		5.0	8319 Mountianview Dr.- P245 - SS#412
01/11/2016 13:10	51.3 mg/L		5.0	8330 Rainbow Dr.- S101 - SS#421
01/11/2016 13:35	28.2 mg/L		5.0	8925 Hwy. 99 - S137
11/17/2016 13:00	42.0 mg/L		0.50	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	44.0 mg/L		0.50	8925 Hwy. 99 - S137

# samples:	5	min:	26.6 mg/L
# detects:	5	max:	51.3 mg/L
# non-detects:	0	avg:	38.420 mg/L (based on 5 numerical results)
# of Exceedences:	0		

Heterotrophic Plate Count / HPC		Criteria		Detection Limit/MDL	Sampling Point Name
01/21/2016 11:30	< 1 CFU/mL	<=200	User-Defined	1	3333 Carleton Way - S104 - SS#459
01/21/2016 11:50	< 1 CFU/mL	<=200	User-Defined	1	4297 Mountain Square - Mountain Ln - SS#453
01/21/2016 12:00	< 1 CFU/mL	<=200	User-Defined	1	4297 Mountain Square - Mountain Ln - SS#453
01/21/2016 13:50	< 1 CFU/mL	<=200	User-Defined	1	8925 Hwy. 99 - S137
01/21/2016 14:00	< 1 CFU/mL	<=200	User-Defined	1	8319 Mountianview Dr.- P245 - SS#412
01/21/2016 14:15	< 1 CFU/mL	<=200	User-Defined	1	8330 Rainbow Dr.- S101 - SS#421
01/22/2016 09:50	< 1 CFU/mL	<=200	User-Defined	1	2601 Gondola Way - R228 - SS#474
01/25/2016 11:20	< 1 CFU/mL	<=200	User-Defined	1	5438 Stonebridge drive - P275
01/26/2016 10:10	< 1 CFU/mL	<=200	User-Defined	1	2773 Cheakamus Way - S121- SS#477
01/26/2016 13:20	< 1 CFU/mL	<=200	User-Defined	1	4700 Glacier Dr. - P256 - SS#441
01/26/2016 13:55	< 1 CFU/mL	<=200	User-Defined	1	1300 Mount Fee Rd

Heterotrophic Plate Count / HPC		Criteria		Detection Limit/MDL	Sampling Point Name
01/26/2016 14:25	< 1 CFU/mL	<=200	User-Defined	1	1300 Block Alta Lake Rd - SS#482
01/26/2016 14:45	< 1 CFU/mL	<=200	User-Defined	1	6295 Palmer Dr. - Snowflake Park - SS#430
03/31/2016 10:30	< 1 CFU/mL	<=200	User-Defined	1	2400 Taluswood Pl. - P270 - SS#465
04/01/2016 08:00	< 1 CFU/mL	<=200	User-Defined	1	1300 Mount Fee Rd
04/01/2016 09:30	< 1 CFU/mL	<=200	User-Defined	1	7314 Blackcomb Way - P267/S126 - SS#427
04/04/2016 08:30	< 1 CFU/mL	<=200	User-Defined	1	5438 Stonebridge drive - P275
04/04/2016 09:40	< 1 CFU/mL	<=200	User-Defined	1	2773 Cheakamus Way - S121- SS#477
04/04/2016 11:00	< 1 CFU/mL	<=200	User-Defined	1	2149 Lake Placid Rd - S106 - SS#471
04/04/2016 11:30	< 1 CFU/mL	<=200	User-Defined	1	3840 Sunridge Drive - P265 - SS#456
04/04/2016 11:50	< 1 CFU/mL	<=200	User-Defined	1	4335 Main Street - Main St. - SS#450
04/05/2016 10:15	< 1 CFU/mL	<=200	User-Defined	1	8925 Hwy. 99 - S137
04/06/2016 09:15	< 1 CFU/mL	<=200	User-Defined	1	1300 Block Alta Lake Rd - SS#482
04/08/2016 08:30	< 1 CFU/mL	<=200	User-Defined	1	2642 Whistler Road - P264 - SS#462
04/08/2016 08:45	< 1 CFU/mL	<=200	User-Defined	1	2601 Gondola Way - R228 - SS#474
04/08/2016 09:00	< 1 CFU/mL	<=200	User-Defined	1	1559 Spring Creek Rd - P273/S132 - SS#480
04/08/2016 09:40	< 1 CFU/mL	<=200	User-Defined	1	6671 Crabapple Dr. - S103 - SS#433
04/15/2016 07:45	< 1 CFU/mL	<=200	User-Defined	1	8319 Mountainview Dr.- P245 - SS#412
04/20/2016 11:30	< 1 CFU/mL	<=200	User-Defined	1	3333 Carleton Way - S104 - SS#459
04/20/2016 11:45	< 1 CFU/mL	<=200	User-Defined	1	4297 Mountain Square - Mountain Ln - SS#453
04/20/2016 11:55	< 1 CFU/mL	<=200	User-Defined	1	4700 Glacier Dr. - P256 - SS#441
04/20/2016 12:05	< 1 CFU/mL	<=200	User-Defined	1	6295 Palmer Dr. - Snowflake Park - SS#430

Heterotrophic Plate Count / HPC		Criteria		Detection Limit/MDL	Sampling Point Name
04/20/2016 12:30	< 1 CFU/mL	<=200	User-Defined	1	8407 Golden Bear Pl. - P266/S123 - SS#424
06/23/2016 08:30	< 1 CFU/mL	<=200	User-Defined	1	2400 Taluswood Pl. - P270 - SS#465
06/23/2016 08:50	< 1 CFU/mL	<=200	User-Defined	1	2642 Whistler Road - P264 - SS#462
06/28/2016 10:30	< 1 CFU/mL	<=200	User-Defined	1	1300 Mount Fee Rd
06/28/2016 10:55	< 1 CFU/mL	<=200	User-Defined	1	1559 Spring Creek Rd - P273/S132 - SS#480
06/28/2016 11:10	< 1 CFU/mL	<=200	User-Defined	1	1300 Block Alta Lake Rd - SS#482
06/28/2016 11:45	< 1 CFU/mL	<=200	User-Defined	1	2601 Gondola Way - R228 - SS#474
06/28/2016 12:25	< 1 CFU/mL	<=200	User-Defined	1	2773 Cheakamus Way - S121- SS#477
06/28/2016 12:45	< 1 CFU/mL	<=200	User-Defined	1	2149 Lake Placid Rd - S106 - SS#471
06/28/2016 13:20	< 1 CFU/mL	<=200	User-Defined	1	7314 Blackcomb Way - P267/S126 - SS#427
06/28/2016 13:45	< 1 CFU/mL	<=200	User-Defined	1	4335 Main Street - Main St. - SS#450
06/28/2016 14:00	< 1 CFU/mL	<=200	User-Defined	1	4700 Glacier Dr. - P256 - SS#441
07/06/2016 13:50	< 1 CFU/mL	<=200	User-Defined	1	5438 Stonebridge drive - P275
07/06/2016 14:15	< 1 CFU/mL	<=200	User-Defined	1	3333 Carleton Way - S104 - SS#459
07/06/2016 14:30	< 1 CFU/mL	<=200	User-Defined	1	3840 Sunridge Drive - P265 - SS#456
07/06/2016 14:45	< 1 CFU/mL	<=200	User-Defined	1	4297 Mountain Square - Mountain Ln - SS#453
07/07/2016 13:40	< 1 CFU/mL	<=200	User-Defined	1	8925 Hwy. 99 - S137
07/07/2016 14:20	< 1 CFU/mL	<=200	User-Defined	1	8330 Rainbow Dr.- S101 - SS#421
07/11/2016 10:35	< 1 CFU/mL	<=200	User-Defined	1	6671 Crabapple Dr. - S103 - SS#433
07/11/2016 10:50	< 1 CFU/mL	<=200	User-Defined	1	6295 Palmer Dr. - Snowflake Park - SS#430
07/13/2016 13:10	< 1 CFU/mL	<=200	User-Defined	1	8407 Golden Bear Pl. - P266/S123 - SS#424

Heterotrophic Plate Count / HPC		Criteria		Detection Limit/MDL	Sampling Point Name
07/13/2016 13:25	< 1 CFU/mL	<=200	User-Defined	1	8319 Mountianview Dr.- P245 - SS#412
09/15/2016 11:05	< 1 CFU/mL	<=200	User-Defined	1	2400 Taluswood Pl. - P270 - SS#465
09/15/2016 11:25	< 1 CFU/mL	<=200	User-Defined	1	2149 Lake Placid Rd - S106 - SS#471
09/15/2016 13:00	< 1 CFU/mL	<=200	User-Defined	1	1300 Mount Fee Rd
09/29/2016 12:30	< 1 CFU/mL	<=200	User-Defined	1	5438 Stonebridge drive - P275
09/29/2016 13:00	< 1 CFU/mL	<=200	User-Defined	1	1559 Spring Creek Rd - P273/S132 - SS#480
09/29/2016 13:15	< 1 CFU/mL	<=200	User-Defined	1	1300 Block Alta Lake Rd - SS#482
09/29/2016 13:20	< 1 CFU/mL	<=200	User-Defined	1	2773 Cheakamus Way - S121- SS#477
10/12/2016 11:10	6 CFU/mL	<=200	User-Defined	1	2601 Gondola Way - R228 - SS#474
10/12/2016 11:35	< 1 CFU/mL	<=200	User-Defined	1	2642 Whistler Road - P264 - SS#462
10/12/2016 12:00	< 1 CFU/mL	<=200	User-Defined	1	3333 Carleton Way - S104 - SS#459
10/12/2016 12:10	< 1 CFU/mL	<=200	User-Defined	1	3840 Sunridge Drive - P265 - SS#456
10/12/2016 12:35	2 CFU/mL	<=200	User-Defined	1	4297 Mountain Square - Mountain Ln - SS#453
10/12/2016 12:45	< 1 CFU/mL	<=200	User-Defined	1	4335 Main Street - Main St. - SS#450
10/12/2016 13:00	< 1 CFU/mL	<=200	User-Defined	1	4700 Glacier Dr. - P256 - SS#441
10/13/2016 12:10	< 1 CFU/mL	<=200	User-Defined	1	8925 Hwy. 99 - S137
10/13/2016 12:20	< 1 CFU/mL	<=200	User-Defined	1	8319 Mountianview Dr.- P245 - SS#412
10/13/2016 13:35	< 1 CFU/mL	<=200	User-Defined	1	8407 Golden Bear Pl. - P266/S123 - SS#424
10/13/2016 13:50	< 1 CFU/mL	<=200	User-Defined	1	7314 Blackcomb Way - P267/S126 - SS#427
10/13/2016 14:05	< 1 CFU/mL	<=200	User-Defined	1	6295 Palmer Dr. - Snowflake Park - SS#430
10/13/2016 14:15	< 1 CFU/mL	<=200	User-Defined	1	6671 Crabapple Dr. - S103 - SS#433

Heterotrophic Plate Count / HPC		Criteria		Detection Limit/MDL	Sampling Point Name
11/03/2016 12:30	< 1 CFU/mL	<=200	User-Defined	1	8330 Rainbow Dr.- S101 - SS#421
# samples:	75	min:	< 1 CFU/mL		
# detects:	2	max:	6 CFU/mL		
# non-detects:	73	Geometric Mean:	3.464 CFU/mL (based on 2 numerical results)		
# of Exceedences:	0				

Iron (dissolved)		Criteria	Detection Limit/MDL	Sampling Point Name
01/11/2016 12:35	< 0.10 mg/L		0.10	8319 Mountianview Dr.- P245 - SS#412
01/11/2016 13:10	< 0.10 mg/L		0.10	8330 Rainbow Dr.- S101 - SS#421
01/11/2016 13:35	< 0.10 mg/L		0.10	8925 Hwy. 99 - S137
01/28/2016 13:10	< 0.10 mg/L		0.10	8319 Mountianview Dr.- P245 - SS#412
01/28/2016 13:40	< 0.10 mg/L		0.10	8330 Rainbow Dr.- S101 - SS#421
01/28/2016 13:50	< 0.10 mg/L		0.10	Hyd # 8110 - 8550 Buckhorn Place
01/28/2016 14:00	< 0.10 mg/L		0.10	8925 Hwy. 99 - S137
04/29/2016 11:45	< 0.10 mg/L		0.10	8319 Mountianview Dr.- P245 - SS#412
04/29/2016 12:05	< 0.10 mg/L		0.10	Hyd # 8110 - 8550 Buckhorn Place
04/29/2016 13:35	< 0.10 mg/L		0.10	8925 Hwy. 99 - S137
07/14/2016 13:45	< 0.10 mg/L		0.10	8319 Mountianview Dr.- P245 - SS#412
07/14/2016 14:15	< 0.10 mg/L		0.10	Hyd # 8110 - 8550 Buckhorn Place
07/14/2016 14:20	< 0.10 mg/L		0.10	8330 Rainbow Dr.- S101 - SS#421
07/14/2016 14:20	< 0.10 mg/L		0.10	8925 Hwy. 99 - S137
10/14/2016 12:00	< 0.010 mg/L		0.010	Hyd # 8110 - 8550 Buckhorn Place
10/14/2016 13:00	< 0.010 mg/L		0.010	8925 Hwy. 99 - S137
10/14/2016 13:10	0.011 mg/L		0.010	8319 Mountianview Dr.- P245 - SS#412
10/14/2016 15:00	< 0.010 mg/L		0.010	8330 Rainbow Dr.- S101 - SS#421

# samples:	18	min:	< 0.010 mg/L
# detects:	1	max:	< 0.10 mg/L
# non-detects:	17	avg:	0.011 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Iron (total)		Criteria		Detection Limit/MDL	Sampling Point Name
01/11/2016 12:35	< 0.10 mg/L	<=0.3	AO	0.10	8319 Mountianview Dr.- P245 - SS#412
01/11/2016 13:10	< 0.10 mg/L	<=0.3	AO	0.10	8330 Rainbow Dr.- S101 - SS#421
* 01/11/2016 13:35	0.39 mg/L	<=0.3	AO	0.10	8925 Hwy. 99 - S137
* 01/28/2016 13:10	0.46 mg/L	<=0.3	AO	0.10	8319 Mountianview Dr.- P245 - SS#412
01/28/2016 13:40	0.13 mg/L	<=0.3	AO	0.10	8330 Rainbow Dr.- S101 - SS#421
01/28/2016 13:50	0.25 mg/L	<=0.3	AO	0.10	Hyd # 8110 - 8550 Buckhorn Place
01/28/2016 14:00	0.22 mg/L	<=0.3	AO	0.10	8925 Hwy. 99 - S137
04/29/2016 11:45	< 0.10 mg/L	<=0.3	AO	0.10	8319 Mountianview Dr.- P245 - SS#412
04/29/2016 12:05	< 0.10 mg/L	<=0.3	AO	0.10	Hyd # 8110 - 8550 Buckhorn Place
04/29/2016 13:35	0.23 mg/L	<=0.3	AO	0.10	8925 Hwy. 99 - S137
07/14/2016 13:45	< 0.10 mg/L	<=0.3	AO	0.10	8319 Mountianview Dr.- P245 - SS#412
07/14/2016 14:15	< 0.10 mg/L	<=0.3	AO	0.10	Hyd # 8110 - 8550 Buckhorn Place
07/14/2016 14:20	0.21 mg/L	<=0.3	AO	0.10	8925 Hwy. 99 - S137
07/14/2016 14:20	< 0.10 mg/L	<=0.3	AO	0.10	8330 Rainbow Dr.- S101 - SS#421
10/14/2016 12:00	0.01 mg/L	<=0.3	AO	0.01	Hyd # 8110 - 8550 Buckhorn Place
10/14/2016 13:00	0.01 mg/L	<=0.3	AO	0.01	8925 Hwy. 99 - S137
10/14/2016 13:10	< 0.01 mg/L	<=0.3	AO	0.01	8319 Mountianview Dr.- P245 - SS#412
10/14/2016 15:00	< 0.01 mg/L	<=0.3	AO	0.01	8330 Rainbow Dr.- S101 - SS#421
11/17/2016 13:00	0.03 mg/L	<=0.3	AO	0.01	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	0.01 mg/L	<=0.3	AO	0.01	8925 Hwy. 99 - S137



# samples:	20	min:	< 0.01 mg/L
# detects:	11	max:	0.46 mg/L
# non-detects:	9	avg:	0.177 mg/L (based on 11 numerical results)
# of Exceedences:	2		

Lead (total)		Criteria		Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	0.0010 mg/L	<=0.010	MAC	0.0001	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	0.0004 mg/L	<=0.010	MAC	0.0001	8925 Hwy. 99 - S137

# samples:	2	min:	0.0004 mg/L
# detects:	2	max:	0.0010 mg/L
# non-detects:	0	avg:	0.0007 mg/L (based on 2 numerical results)
# of Exceedences:	0		

Magnesium (total)		Criteria		Detection Limit/MDL	Sampling Point Name
01/11/2016 12:35	0.4 mg/L			0.1	8319 Mountianview Dr.- P245 - SS#412
01/11/2016 13:10	0.7 mg/L			0.1	8330 Rainbow Dr.- S101 - SS#421
01/11/2016 13:35	0.4 mg/L			0.1	8925 Hwy. 99 - S137
11/17/2016 13:00	1.87 mg/L			0.01	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	0.60 mg/L			0.01	8925 Hwy. 99 - S137

# samples:	5	min:	0.4 mg/L
# detects:	5	max:	1.87 mg/L
# non-detects:	0	avg:	0.794 mg/L (based on 5 numerical results)
# of Exceedences:	0		

Manganese (dissolved)		Criteria		Detection Limit/MDL	Sampling Point Name
01/11/2016 12:35	< 0.002 mg/L	<=0.05	User-Defined	0.002	8319 Mountianview Dr.- P245 - SS#412
01/11/2016 13:10	< 0.002 mg/L	<=0.05	User-Defined	0.002	8330 Rainbow Dr.- S101 - SS#421
01/11/2016 13:35	0.003 mg/L	<=0.05	User-Defined	0.002	8925 Hwy. 99 - S137

# samples:	3	min:	< 0.002 mg/L
# detects:	1	max:	0.003 mg/L
# non-detects:	2	avg:	0.003 mg/L (based on 1 numerical results)



of Exceedences: 0

Manganese (total)		Criteria		Detection Limit/MDL	Sampling Point Name
01/11/2016 12:35	< 0.002 mg/L	<=0.05	AO	0.002	8319 Mountianview Dr.- P245 - SS#412
01/11/2016 13:10	< 0.002 mg/L	<=0.05	AO	0.002	8330 Rainbow Dr.- S101 - SS#421
01/11/2016 13:35	0.005 mg/L	<=0.05	AO	0.002	8925 Hwy. 99 - S137
11/17/2016 13:00	0.0457 mg/L	<=0.05	AO	0.0002	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	0.0002 mg/L	<=0.05	AO	0.0002	8925 Hwy. 99 - S137

# samples:	5	min:	0.0002 mg/L
# detects:	3	max:	0.0457 mg/L
# non-detects:	2	avg:	0.0170 mg/L (based on 3 numerical results)
# of Exceedences:	0		

Mercury (total)		Criteria		Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	< 0.00002 mg/L			0.00002	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	< 0.00002 mg/L			0.00002	8925 Hwy. 99 - S137

# samples:	2	min:	< 0.00002 mg/L
# detects:	0	max:	< 0.00002 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Molybdenum (total)		Criteria		Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	0.0018 mg/L			0.0001	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	0.0002 mg/L			0.0001	8925 Hwy. 99 - S137

# samples:	2	min:	0.0002 mg/L
# detects:	2	max:	0.0018 mg/L
# non-detects:	0	avg:	0.0010 mg/L (based on 2 numerical results)
# of Exceedences:	0		



Monobromoacetic acid	Criteria	Detection Limit/MDL	Sampling Point Name
01/15/2016 10:00	< 0.002 mg/L	0.002	1300 Mount Fee Rd
01/15/2016 12:30	< 0.002 mg/L	0.002	4335 Main Street - Main St. - SS#450
01/15/2016 13:30	< 0.002 mg/L	0.002	4700 Glacier Dr. - P256 - SS#441
04/01/2016 08:00	< 0.002 mg/L	0.002	1300 Mount Fee Rd
04/01/2016 09:30	< 0.002 mg/L	0.002	7314 Blackcomb Way - P267/S126 - SS#427
04/01/2016 11:25	< 0.002 mg/L	0.002	2642 Whistler Road - P264 - SS#462
04/01/2016 11:55	< 0.002 mg/L	0.002	4335 Main Street - Main St. - SS#450
04/01/2016 12:15	< 0.002 mg/L	0.002	4700 Glacier Dr. - P256 - SS#441
06/22/2016 11:45	< 0.002 mg/L	0.002	7314 Blackcomb Way - P267/S126 - SS#427
06/22/2016 13:30	< 0.002 mg/L	0.002	1300 Mount Fee Rd
06/23/2016 08:50	< 0.002 mg/L	0.002	2642 Whistler Road - P264 - SS#462
06/28/2016 13:45	< 0.002 mg/L	0.002	4335 Main Street - Main St. - SS#450
06/28/2016 14:00	< 0.002 mg/L	0.002	4700 Glacier Dr. - P256 - SS#441
09/15/2016 13:00	< 0.002 mg/L	0.002	1300 Mount Fee Rd
10/12/2016 11:35	< 0.002 mg/L	0.002	2642 Whistler Road - P264 - SS#462
10/12/2016 12:45	< 0.002 mg/L	0.002	4335 Main Street - Main St. - SS#450
10/12/2016 13:00	< 0.002 mg/L	0.002	4700 Glacier Dr. - P256 - SS#441
10/13/2016 13:50	< 0.002 mg/L	0.002	7314 Blackcomb Way - P267/S126 - SS#427

# samples:	18	min:	< 0.002 mg/L
# detects:	0	max:	< 0.002 mg/L
# non-detects:	18	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Monochloroacetic acid	Criteria	Detection Limit/MDL	Sampling Point Name
01/15/2016 10:00	0.004 mg/L	0.002	1300 Mount Fee Rd

Monochloroacetic acid		Criteria	Detection Limit/MDL	Sampling Point Name
01/15/2016 12:30	0.003 mg/L		0.002	4335 Main Street - Main St. - SS#450
01/15/2016 13:30	0.003 mg/L		0.002	4700 Glacier Dr. - P256 - SS#441
04/01/2016 08:00	< 0.002 mg/L		0.002	1300 Mount Fee Rd
04/01/2016 09:30	< 0.002 mg/L		0.002	7314 Blackcomb Way - P267/S126 - SS#427
04/01/2016 11:25	< 0.002 mg/L		0.002	2642 Whistler Road - P264 - SS#462
04/01/2016 11:55	< 0.002 mg/L		0.002	4335 Main Street - Main St. - SS#450
04/01/2016 12:15	< 0.002 mg/L		0.002	4700 Glacier Dr. - P256 - SS#441
06/22/2016 11:45	< 0.002 mg/L		0.002	7314 Blackcomb Way - P267/S126 - SS#427
06/22/2016 13:30	< 0.002 mg/L		0.002	1300 Mount Fee Rd
06/23/2016 08:50	< 0.002 mg/L		0.002	2642 Whistler Road - P264 - SS#462
06/28/2016 13:45	< 0.002 mg/L		0.002	4335 Main Street - Main St. - SS#450
06/28/2016 14:00	< 0.002 mg/L		0.002	4700 Glacier Dr. - P256 - SS#441
09/15/2016 13:00	< 0.002 mg/L		0.002	1300 Mount Fee Rd
10/12/2016 11:35	< 0.002 mg/L		0.002	2642 Whistler Road - P264 - SS#462
10/12/2016 12:45	< 0.002 mg/L		0.002	4335 Main Street - Main St. - SS#450
10/12/2016 13:00	< 0.002 mg/L		0.002	4700 Glacier Dr. - P256 - SS#441
10/13/2016 13:50	< 0.002 mg/L		0.002	7314 Blackcomb Way - P267/S126 - SS#427

# samples:	18	min:	< 0.002 mg/L
# detects:	3	max:	0.004 mg/L
# non-detects:	15	avg:	0.003 mg/L (based on 3 numerical results)
# of Exceedences:	0		

Nickel (total)		Criteria	Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	< 0.0002 mg/L		0.0002	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	< 0.0002 mg/L		0.0002	8925 Hwy. 99 - S137



# samples:	2	min:	< 0.0002 mg/L
# detects:	0	max:	< 0.0002 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nitrate (as N)		Criteria	Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	0.096 mg/L		0.010	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	0.118 mg/L		0.010	8925 Hwy. 99 - S137

# samples:	2	min:	0.096 mg/L
# detects:	2	max:	0.118 mg/L
# non-detects:	0	avg:	0.107 mg/L (based on 2 numerical results)
# of Exceedences:	0		

Nitrite (as N)		Criteria	Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	< 0.010 mg/L		0.010	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	< 0.010 mg/L		0.010	8925 Hwy. 99 - S137

# samples:	2	min:	< 0.010 mg/L
# detects:	0	max:	< 0.010 mg/L
# non-detects:	2	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

pH		Criteria	Detection Limit/MDL	Sampling Point Name
* 01/05/2016 10:30	6.51	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
* 01/05/2016 12:30	6.93	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
01/05/2016 12:55	7.54	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
* 01/05/2016 13:10	6.77	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
* 01/05/2016 13:20	6.96	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441
01/05/2016 13:40	7.06	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
* 01/06/2016 11:30	6.84	>=7, <=10.5	User-Defined	8319 Mountianview Dr.- P245 - SS#412



pH	Criteria	Detection Limit/MDL	Sampling Point Name	
01/06/2016 12:00	7.44	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
01/06/2016 12:25	7.49	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
* 01/11/2016 13:10	6.87	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
01/11/2016 13:35	7.00	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
01/12/2016 10:30	7.25	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
01/12/2016 11:00	7.29	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
01/12/2016 13:00	7.41	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
01/12/2016 13:30	7.31	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
01/13/2016 11:30	7.34	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
01/13/2016 12:20	7.49	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 01/19/2016 10:20	6.49	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
01/19/2016 11:30	7.01	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
01/19/2016 12:05	7.12	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
01/19/2016 12:35	7.12	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
01/19/2016 13:45	7.10	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
* 01/20/2016 09:45	6.60	>=7, <=10.5	User-Defined	8319 Mountainview Dr.- P245 - SS#412
01/20/2016 10:10	7.38	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
01/20/2016 10:35	7.38	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
01/20/2016 11:10	7.30	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
01/20/2016 11:40	7.02	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441

pH		Criteria	Detection Limit/MDL	Sampling Point Name
* 01/25/2016 11:20	6.86	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
01/26/2016 09:40	7.31	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 01/26/2016 10:10	6.47	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
01/26/2016 10:45	7.47	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
01/26/2016 12:00	7.35	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
01/26/2016 12:35	7.36	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
* 01/27/2016 09:10	6.78	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 01/27/2016 09:40	6.98	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
* 02/02/2016 10:15	6.65	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
* 02/02/2016 12:00	6.55	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
02/02/2016 13:00	7.11	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 02/02/2016 13:25	6.48	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
02/02/2016 13:50	7.32	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
02/03/2016 09:50	7.03	>=7, <=10.5	User-Defined	8319 Mountainview Dr.- P245 - SS#412
02/03/2016 10:45	7.33	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
02/03/2016 12:10	7.02	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
02/03/2016 12:50	7.16	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
* 02/03/2016 13:20	6.69	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441
* 02/09/2016 11:00	6.77	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
* 02/09/2016 13:00	6.67	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477

pH		Criteria	Detection Limit/MDL	Sampling Point Name
02/09/2016 13:25	7.33	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
02/09/2016 13:50	7.36	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
* 02/10/2016 08:20	6.60	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
02/10/2016 08:50	7.55	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 02/10/2016 11:40	6.95	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
* 02/16/2016 10:30	6.59	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
* 02/16/2016 11:00	6.38	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 02/16/2016 11:35	6.50	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
* 02/16/2016 13:00	6.71	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
* 02/16/2016 13:45	6.76	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
* 02/17/2016 09:00	6.63	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
02/17/2016 10:40	7.05	>=7, <=10.5	User-Defined	8319 Mountianview Dr.- P245 - SS#412
* 02/17/2016 11:30	6.67	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
* 02/17/2016 12:30	6.62	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
* 02/17/2016 13:00	6.66	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441
* 02/23/2016 08:40	6.42	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
* 02/23/2016 11:00	6.45	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
02/23/2016 12:00	7.22	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
02/23/2016 12:30	7.31	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
02/24/2016 07:30	7.25	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
02/24/2016 10:15	7.00	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137

pH		Criteria	Detection Limit/MDL	Sampling Point Name
* 02/24/2016 10:40	6.82	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
02/24/2016 11:15	7.48	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
* 03/01/2016 08:15	6.81	>=7, <=10.5	User-Defined	8319 Mountainview Dr.- P245 - SS#412
* 03/01/2016 10:30	6.51	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
* 03/01/2016 11:40	6.53	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 03/01/2016 12:15	6.54	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
03/01/2016 12:45	7.28	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
03/02/2016 08:45	7.46	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
03/02/2016 11:25	7.47	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
03/02/2016 11:50	7.30	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
* 03/02/2016 12:30	6.68	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441
03/02/2016 13:00	7.32	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
* 03/08/2016 08:30	6.67	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
* 03/08/2016 11:40	6.76	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
* 03/08/2016 12:00	6.53	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 03/08/2016 12:25	6.75	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
03/08/2016 13:15	7.14	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
03/09/2016 09:45	7.14	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
03/09/2016 10:15	7.23	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
03/09/2016 12:25	7.68	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
* 03/22/2016 08:45	6.68	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427

pH		Criteria	Detection Limit/MDL	Sampling Point Name
* 03/22/2016 09:30	6.95	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
03/22/2016 10:50	7.03	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
03/22/2016 13:30	7.24	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
* 03/23/2016 10:00	6.65	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
* 03/23/2016 10:45	6.46	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 03/23/2016 11:05	6.49	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
* 03/23/2016 11:30	6.75	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
* 03/29/2016 09:40	6.69	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
03/29/2016 10:00	7.06	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
03/29/2016 10:45	7.39	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
03/29/2016 11:00	7.55	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
03/29/2016 11:50	7.66	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
03/29/2016 13:05	7.65	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
03/29/2016 13:35	7.07	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441
03/30/2016 09:00	7.47	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
03/30/2016 10:15	7.23	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
* 03/30/2016 11:15	6.60	>=7, <=10.5	User-Defined	8319 Mountianview Dr.- P245 - SS#412
* 04/04/2016 08:30	6.61	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
* 04/04/2016 09:40	6.41	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
* 04/04/2016 11:00	6.28	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 04/04/2016 11:30	6.62	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456

pH		Criteria	Detection Limit/MDL	Sampling Point Name
* 04/04/2016 11:50	6.42	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
* 04/04/2016 12:15	6.67	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 04/05/2016 09:20	6.63	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 04/05/2016 10:15	6.54	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
* 04/12/2016 09:30	6.51	>=7, <=10.5	User-Defined	8319 Mountianview Dr.- P245 - SS#412
* 04/13/2016 08:10	6.49	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
* 04/13/2016 08:45	6.35	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
* 04/13/2016 10:35	6.43	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
* 04/13/2016 11:00	6.31	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
* 04/13/2016 11:35	6.47	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
* 04/13/2016 11:55	6.25	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 04/13/2016 12:20	6.43	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
* 04/13/2016 13:30	6.52	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441
* 04/13/2016 13:45	6.41	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
* 04/19/2016 13:05	6.60	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 04/19/2016 13:30	6.43	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
* 04/20/2016 09:00	6.80	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
* 04/20/2016 10:45	6.45	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
* 04/20/2016 11:40	6.22	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 04/20/2016 12:00	6.32	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477

pH		Criteria	Detection Limit/MDL	Sampling Point Name
* 04/20/2016 12:25	6.48	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
04/27/2016 08:00	7.18	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
04/27/2016 09:00	7.01	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
* 04/27/2016 09:25	6.41	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
* 04/27/2016 10:20	6.55	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
04/27/2016 11:00	7.18	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 04/27/2016 11:10	6.73	>=7, <=10.5	User-Defined	8319 Mountainview Dr. - P245 - SS#412
04/27/2016 11:26	7.36	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
04/27/2016 11:43	7.35	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
04/27/2016 12:37	7.29	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
* 04/27/2016 12:57	6.67	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441
* 05/04/2016 08:30	6.52	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121 - SS#477
* 05/04/2016 09:00	6.36	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 05/04/2016 09:30	6.99	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
* 05/04/2016 11:40	6.62	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
05/04/2016 12:00	7.25	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 05/04/2016 12:30	6.94	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
* 05/10/2016 12:40	6.62	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
* 05/10/2016 13:15	6.50	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
* 05/11/2016 08:55	6.59	>=7, <=10.5	User-Defined	1300 Mount Fee Rd

pH		Criteria	Detection Limit/MDL	Sampling Point Name
05/11/2016 09:00	7.77	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
* 05/11/2016 10:00	6.80	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 05/11/2016 10:40	6.87	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441
* 05/11/2016 10:55	6.45	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
05/11/2016 11:10	7.71	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
05/11/2016 11:50	7.58	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
* 05/11/2016 12:15	6.74	>=7, <=10.5	User-Defined	8319 Mountianview Dr.- P245 - SS#412
* 05/16/2016 12:00	6.45	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
* 05/16/2016 12:20	6.56	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
* 05/16/2016 12:30	6.89	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 05/16/2016 13:10	6.77	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
05/16/2016 13:30	7.12	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 05/17/2016 09:15	6.67	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 05/17/2016 11:10	6.65	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
* 05/18/2016 08:00	6.82	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
05/24/2016 07:41	7.18	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
* 05/24/2016 07:56	6.78	>=7, <=10.5	User-Defined	8319 Mountianview Dr.- P245 - SS#412
05/24/2016 08:19	7.46	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
05/24/2016 08:37	7.11	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
* 05/24/2016 08:56	6.81	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441

pH		Criteria	Detection Limit/MDL	Sampling Point Name
* 05/24/2016 09:56	6.55	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
* 05/24/2016 10:15	6.71	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
* 05/24/2016 10:42	6.59	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
* 05/24/2016 11:04	6.63	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 05/24/2016 11:43	6.64	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
* 05/30/2016 12:30	6.50	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
* 05/30/2016 13:30	6.63	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
05/31/2016 07:47	7.86	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
* 05/31/2016 08:54	6.84	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
05/31/2016 11:16	7.35	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
05/31/2016 11:33	7.08	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
* 05/31/2016 11:52	6.72	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 06/01/2016 11:15	6.57	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 06/06/2016 07:28	6.70	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
06/06/2016 07:48	7.07	>=7, <=10.5	User-Defined	8319 Mountainview Dr.- P245 - SS#412
* 06/06/2016 08:08	6.76	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
* 06/06/2016 08:33	6.75	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
* 06/06/2016 09:22	6.98	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441
* 06/06/2016 09:43	6.38	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
* 06/06/2016 10:12	6.37	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465

pH		Criteria	Detection Limit/MDL	Sampling Point Name
* 06/06/2016 11:16	6.20	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
* 06/06/2016 11:35	6.05	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 06/06/2016 12:25	6.00	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
* 06/13/2016 10:45	6.85	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
06/13/2016 13:15	7.14	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
06/13/2016 13:45	7.05	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
06/14/2016 08:00	7.33	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
* 06/14/2016 08:30	6.86	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
* 06/14/2016 09:00	6.87	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 06/14/2016 11:05	6.72	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
* 06/20/2016 09:37	6.60	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
* 06/20/2016 09:56	6.36	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 06/20/2016 10:13	6.60	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
06/20/2016 11:42	7.18	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
* 06/20/2016 12:03	6.75	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441
06/20/2016 12:21	7.07	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
* 06/20/2016 12:43	6.98	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
* 06/21/2016 08:10	6.71	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
* 06/21/2016 10:10	6.92	>=7, <=10.5	User-Defined	8319 Mountainview Dr.- P245 - SS#412
06/21/2016 13:00	7.05	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424

pH		Criteria		Detection Limit/MDL	Sampling Point Name
* 06/28/2016 08:37	6.43	>=7, <=10.5	User-Defined		4335 Main Street - Main St. - SS#450
06/28/2016 09:00	7.03	>=7, <=10.5	User-Defined		7314 Blackcomb Way - P267/S126 - SS#427
* 06/28/2016 09:16	6.97	>=7, <=10.5	User-Defined		3840 Sunridge Drive - P265 - SS#456
* 06/28/2016 09:38	6.48	>=7, <=10.5	User-Defined		2149 Lake Placid Rd - S106 - SS#471
* 06/28/2016 09:57	6.50	>=7, <=10.5	User-Defined		2773 Cheakamus Way - S121- SS#477
* 06/28/2016 10:30	6.59	>=7, <=10.5	User-Defined		5438 Stonebridge drive - P275
* 06/28/2016 11:44	6.76	>=7, <=10.5	User-Defined		8925 Hwy. 99 - S137
* 06/29/2016 10:00	6.54	>=7, <=10.5	User-Defined		8330 Rainbow Dr.- S101 - SS#421
* 07/05/2016 08:15	6.36	>=7, <=10.5	User-Defined		8407 Golden Bear Pl. - P266/S123 - SS#424
* 07/05/2016 08:31	6.64	>=7, <=10.5	User-Defined		8319 Mountianview Dr.- P245 - SS#412
* 07/05/2016 09:01	6.41	>=7, <=10.5	User-Defined		4297 Mountain Square - Mountain Ln - SS#453
* 07/05/2016 09:31	6.57	>=7, <=10.5	User-Defined		4700 Glacier Dr. - P256 - SS#441
* 07/05/2016 09:48	6.48	>=7, <=10.5	User-Defined		6295 Palmer Dr. - Snowflake Park - SS#430
* 07/05/2016 10:21	6.44	>=7, <=10.5	User-Defined		2400 Taluswood Pl. - P270 - SS#465
* 07/05/2016 10:43	6.92	>=7, <=10.5	User-Defined		3333 Carleton Way - S104 - SS#459
* 07/05/2016 11:05	6.53	>=7, <=10.5	User-Defined		1300 Block Alta Lake Rd - SS#482
* 07/05/2016 11:20	6.85	>=7, <=10.5	User-Defined		1559 Spring Creek Rd - P273/S132 - SS#480
* 07/05/2016 11:39	6.52	>=7, <=10.5	User-Defined		1300 Mount Fee Rd
* 07/11/2016 12:45	6.24	>=7, <=10.5	User-Defined		1559 Spring Creek Rd - P273/S132 - SS#480
* 07/11/2016 13:00	6.39	>=7, <=10.5	User-Defined		2773 Cheakamus Way - S121- SS#477

pH		Criteria	Detection Limit/MDL	Sampling Point Name
* 07/11/2016 13:40	6.98	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
* 07/12/2016 08:35	6.49	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
* 07/12/2016 10:15	6.98	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
07/12/2016 10:40	7.31	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
07/12/2016 11:20	7.25	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 07/12/2016 13:40	6.76	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 07/13/2016 09:30	6.62	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
* 07/25/2016 08:30	6.28	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 07/25/2016 09:00	6.59	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
07/25/2016 09:30	7.38	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 07/25/2016 10:00	6.65	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 07/25/2016 11:45	6.71	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
07/25/2016 13:00	7.04	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
07/25/2016 13:30	7.43	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
* 07/26/2016 08:15	6.30	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
08/02/2016	7.06	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
* 08/02/2016 07:27	6.51	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
* 08/02/2016 07:47	6.64	>=7, <=10.5	User-Defined	8319 Mountianview Dr.- P245 - SS#412
* 08/02/2016 08:11	6.51	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441
* 08/02/2016 08:27	6.48	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453

pH		Criteria	Detection Limit/MDL	Sampling Point Name
* 08/02/2016 08:46	6.51	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
* 08/02/2016 09:45	6.54	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
* 08/02/2016 10:22	6.10	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
* 08/02/2016 10:52	6.48	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 08/02/2016 11:09	6.58	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
* 08/09/2016 09:30	6.64	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
* 08/09/2016 12:30	6.67	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
08/09/2016 13:10	7.12	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
08/09/2016 13:45	7.27	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
* 08/10/2016 09:00	6.99	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
08/10/2016 09:30	7.12	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
08/10/2016 11:25	7.02	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
* 08/10/2016 12:00	6.98	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 08/16/2016 10:10	6.53	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
* 08/16/2016 10:50	6.62	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 08/16/2016 12:45	6.69	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
08/16/2016 13:10	7.34	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
08/16/2016 13:40	7.29	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
* 08/17/2016 08:00	6.99	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
* 08/17/2016 09:50	6.90	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441

pH		Criteria	Detection Limit/MDL	Sampling Point Name
08/17/2016 10:15	7.43	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
08/17/2016 11:45	7.58	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
* 08/17/2016 12:05	6.80	>=7, <=10.5	User-Defined	8319 Mountianview Dr.- P245 - SS#412
* 08/22/2016 10:45	6.39	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
08/23/2016 01:30	7.04	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
* 08/23/2016 08:00	6.93	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
* 08/23/2016 08:45	6.75	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
08/23/2016 09:20	7.40	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
* 08/23/2016 09:50	6.56	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
08/23/2016 10:15	7.50	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 08/23/2016 12:20	6.85	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 08/30/2016 08:40	6.58	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
* 08/30/2016 11:40	6.22	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
* 08/30/2016 12:20	6.38	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 08/30/2016 12:45	6.41	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
* 08/30/2016 13:40	6.62	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
* 08/31/2016 10:15	6.97	>=7, <=10.5	User-Defined	8319 Mountianview Dr.- P245 - SS#412
08/31/2016 11:25	7.49	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
* 08/31/2016 12:50	6.77	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441
08/31/2016 13:10	7.45	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424

pH		Criteria	Detection Limit/MDL	Sampling Point Name
08/31/2016 13:30	7.19	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
* 09/06/2016 09:15	6.89	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
* 09/06/2016 11:00	6.66	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
* 09/06/2016 12:00	6.60	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
09/06/2016 12:35	7.50	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
* 09/06/2016 13:00	6.52	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
09/06/2016 13:40	7.86	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 09/07/2016 10:40	6.93	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
* 09/07/2016 10:55	6.79	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 09/13/2016 12:10	6.41	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
* 09/13/2016 12:45	6.52	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
09/14/2016 08:45	7.30	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
09/14/2016 09:20	7.66	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
09/14/2016 09:45	7.56	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
09/14/2016 10:15	7.66	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
* 09/14/2016 11:15	6.78	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
* 09/14/2016 12:05	6.81	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441
09/14/2016 12:30	7.51	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
* 09/14/2016 13:40	6.92	>=7, <=10.5	User-Defined	8319 Mountianview Dr.- P245 - SS#412
* 09/19/2016 10:10	6.71	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421

pH		Criteria	Detection Limit/MDL	Sampling Point Name
* 09/19/2016 11:40	6.83	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
* 09/19/2016 12:05	6.60	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 09/19/2016 13:20	6.90	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
* 09/19/2016 13:45	6.60	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
* 09/20/2016 08:15	6.38	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
* 09/20/2016 08:45	6.31	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
09/20/2016 11:15	7.66	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
* 09/27/2016 10:30	6.47	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
* 09/27/2016 10:50	6.29	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 09/27/2016 11:10	6.77	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
09/27/2016 11:50	7.34	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
09/27/2016 12:15	7.39	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
09/27/2016 12:40	7.43	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
09/28/2016 09:45	7.12	>=7, <=10.5	User-Defined	8319 Mountainview Dr.- P245 - SS#412
09/28/2016 10:55	7.56	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
09/28/2016 13:15	7.19	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
* 10/04/2016 09:30	6.87	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
10/04/2016 11:40	7.14	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
* 10/04/2016 12:30	6.76	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
10/04/2016 13:00	7.32	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456

pH		Criteria	Detection Limit/MDL	Sampling Point Name
10/04/2016 13:40	7.53	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
10/05/2016 08:00	7.59	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
* 10/05/2016 09:15	6.81	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 10/05/2016 10:35	6.77	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
10/11/2016 01:20	7.18	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
10/11/2016 08:20	7.12	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
10/11/2016 09:10	7.61	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
10/11/2016 09:40	7.59	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
10/11/2016 10:05	7.51	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
* 10/11/2016 10:40	6.93	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
10/11/2016 11:05	7.42	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
10/11/2016 11:20	7.23	>=7, <=10.5	User-Defined	8319 Mountianview Dr.- P245 - SS#412
10/11/2016 12:20	7.23	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441
* 10/11/2016 12:40	6.94	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
* 10/18/2016 08:30	6.44	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 10/18/2016 09:00	6.62	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
* 10/18/2016 10:30	6.42	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
* 10/18/2016 11:10	6.66	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
* 10/18/2016 11:40	6.36	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
* 10/19/2016 08:25	6.30	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 10/19/2016 09:20	6.84	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137

pH		Criteria	Detection Limit/MDL	Sampling Point Name
* 10/19/2016 09:45	6.57	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 10/24/2016 07:35	6.27	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
* 10/24/2016 08:06	6.59	>=7, <=10.5	User-Defined	8319 Mountainview Dr.- P245 - SS#412
* 10/24/2016 08:31	6.55	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
* 10/24/2016 09:09	6.52	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
* 10/24/2016 09:39	6.32	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 10/24/2016 10:10	6.62	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
* 10/24/2016 10:10	6.62	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
* 10/24/2016 10:15	6.86	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441
* 10/24/2016 10:32	6.67	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
* 10/24/2016 11:32	6.63	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
* 10/31/2016 12:30	6.58	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 10/31/2016 13:40	6.77	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
* 11/01/2016 09:45	6.45	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
* 11/01/2016 10:50	6.35	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
11/01/2016 11:20	7.09	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
* 11/01/2016 12:15	6.73	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
* 11/01/2016 12:50	6.60	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 11/02/2016 08:50	6.18	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
* 11/08/2016 10:30	6.63	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465

pH		Criteria	Detection Limit/MDL	Sampling Point Name
* 11/08/2016 12:00	6.46	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
* 11/08/2016 12:25	6.29	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 11/08/2016 13:30	6.57	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
* 11/09/2016 08:30	6.51	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
* 11/09/2016 10:30	6.45	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
* 11/09/2016 11:00	6.65	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441
* 11/09/2016 11:40	6.57	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
* 11/09/2016 12:00	6.50	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
* 11/09/2016 12:25	6.42	>=7, <=10.5	User-Defined	8319 Mountainview Dr.- P245 - SS#412
* 11/15/2016 10:00	6.51	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
* 11/15/2016 11:15	6.46	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
* 11/15/2016 11:45	6.42	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
11/15/2016 12:00	7.23	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
* 11/15/2016 12:30	6.34	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
* 11/15/2016 12:50	6.61	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 11/16/2016 09:00	6.40	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
* 11/16/2016 11:10	6.76	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 11/22/2016 09:45	6.46	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
* 11/22/2016 12:15	6.48	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
* 11/22/2016 12:35	6.29	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480

pH		Criteria	Detection Limit/MDL	Sampling Point Name
* 11/22/2016 13:00	6.45	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
* 11/23/2016 09:20	6.53	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
* 11/23/2016 09:50	6.53	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
* 11/23/2016 10:10	6.82	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441
* 11/23/2016 10:50	6.56	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
* 11/23/2016 11:10	6.57	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
* 11/23/2016 12:40	6.44	>=7, <=10.5	User-Defined	8319 Mountianview Dr.- P245 - SS#412
* 11/28/2016 11:10	6.45	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
* 11/28/2016 11:35	6.74	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 11/29/2016 08:55	6.62	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
11/29/2016 10:00	7.32	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
11/29/2016 11:00	7.07	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 11/29/2016 11:15	6.48	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
11/29/2016 11:40	7.18	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
11/30/2016 08:15	7.61	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
* 12/05/2016 10:15	6.66	>=7, <=10.5	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
* 12/05/2016 11:00	6.63	>=7, <=10.5	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
* 12/05/2016 11:30	6.61	>=7, <=10.5	User-Defined	3333 Carleton Way - S104 - SS#459
* 12/05/2016 11:45	6.56	>=7, <=10.5	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
12/06/2016 09:20	7.28	>=7, <=10.5	User-Defined	8319 Mountianview Dr.- P245 - SS#412

pH		Criteria	Detection Limit/MDL	Sampling Point Name
* 12/06/2016 09:50	6.30	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 12/06/2016 10:10	6.32	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
* 12/06/2016 10:30	6.43	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482
* 12/06/2016 11:45	6.91	>=7, <=10.5	User-Defined	4700 Glacier Dr. - P256 - SS#441
* 12/06/2016 12:20	6.65	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
* 12/13/2016 09:25	6.69	>=7, <=10.5	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
* 12/13/2016 09:50	6.44	>=7, <=10.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 12/13/2016 10:20	6.80	>=7, <=10.5	User-Defined	8925 Hwy. 99 - S137
* 12/13/2016 11:15	6.05	>=7, <=10.5	User-Defined	2149 Lake Placid Rd - S106 - SS#471
* 12/13/2016 11:40	6.15	>=7, <=10.5	User-Defined	2773 Cheakamus Way - S121- SS#477
* 12/13/2016 12:00	6.32	>=7, <=10.5	User-Defined	5438 Stonebridge drive - P275
* 12/14/2016 08:35	6.76	>=7, <=10.5	User-Defined	3840 Sunridge Drive - P265 - SS#456
* 12/14/2016 08:55	6.74	>=7, <=10.5	User-Defined	4335 Main Street - Main St. - SS#450
* 12/20/2016 11:35	6.54	>=7, <=10.5	User-Defined	1300 Mount Fee Rd
* 12/20/2016 12:25	6.29	>=7, <=10.5	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 12/20/2016 13:10	6.77	>=7, <=10.5	User-Defined	2400 Taluswood Pl. - P270 - SS#465
* 12/20/2016 13:35	6.41	>=7, <=10.5	User-Defined	1300 Block Alta Lake Rd - SS#482

# samples:	428	min:	6.00
# detects:	428	max:	7.86
# non-detects:	0	avg:	6.824 (based on 428 numerical results)
# of Exceedences:	293		

Potassium (total)		Criteria		Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	2.25 mg/L			0.02	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	0.67 mg/L			0.02	8925 Hwy. 99 - S137
# samples:	2	min:	0.67 mg/L		
# detects:	2	max:	2.25 mg/L		
# non-detects:	0	avg:	1.460 mg/L (based on 2 numerical results)		
# of Exceedences:	0				

Selenium (total)		Criteria		Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	< 0.0005 mg/L	<=0.05	MAC	0.0005	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	< 0.0005 mg/L	<=0.05	MAC	0.0005	8925 Hwy. 99 - S137
# samples:	2	min:	< 0.0005 mg/L		
# detects:	0	max:	< 0.0005 mg/L		
# non-detects:	2	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Sodium (total)		Criteria		Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	28.5 mg/L	<=200	AO	0.02	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	5.20 mg/L	<=200	AO	0.02	8925 Hwy. 99 - S137
# samples:	2	min:	5.20 mg/L		
# detects:	2	max:	28.5 mg/L		
# non-detects:	0	avg:	16.850 mg/L (based on 2 numerical results)		
# of Exceedences:	0				

Sulphate		Criteria		Detection Limit/MDL	Sampling Point Name
01/11/2016 12:35	9.6 mg/L			1.0	8319 Mountainview Dr.- P245 - SS#412
01/11/2016 13:10	32.4 mg/L			1.0	8330 Rainbow Dr.- S101 - SS#421
01/11/2016 13:35	10.0 mg/L			1.0	8925 Hwy. 99 - S137
11/17/2016 13:00	12.1 mg/L			1.0	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	21.5 mg/L			1.0	8925 Hwy. 99 - S137

# samples:	5	min:	9.6 mg/L
# detects:	5	max:	32.4 mg/L
# non-detects:	0	avg:	17.120 mg/L (based on 5 numerical results)
# of Exceedences:	0		

Temperature		Criteria		Detection Limit/MDL	Sampling Point Name
01/05/2016 10:30	6.4 degrees C	<=15	AO		1300 Mount Fee Rd
01/05/2016 12:30	5.6 degrees C	<=15	AO		1559 Spring Creek Rd - P273/S132 - SS#480
01/05/2016 12:55	5.2 degrees C	<=15	AO		4297 Mountain Square - Mountain Ln - SS#453
01/05/2016 13:10	5.8 degrees C	<=15	AO		1300 Block Alta Lake Rd - SS#482
01/05/2016 13:20	6.4 degrees C	<=15	AO		4700 Glacier Dr. - P256 - SS#441
01/05/2016 13:40	5.8 degrees C	<=15	AO		2400 Taluswood Pl. - P270 - SS#465
01/06/2016 11:30	7.1 degrees C	<=15	AO		8319 Mountianview Dr.- P245 - SS#412
01/06/2016 12:00	6.6 degrees C	<=15	AO		8407 Golden Bear Pl. - P266/S123 - SS#424
01/06/2016 12:25	6.9 degrees C	<=15	AO		6295 Palmer Dr. - Snowflake Park - SS#430
01/11/2016 13:10	7.6 degrees C	<=15	AO		8330 Rainbow Dr.- S101 - SS#421
01/11/2016 13:35	7.9 degrees C	<=15	AO		8925 Hwy. 99 - S137
01/12/2016 10:30	4.8 degrees C	<=15	AO		2773 Cheakamus Way - S121- SS#477
01/12/2016 11:00	7.2 degrees C	<=15	AO		5438 Stonebridge drive - P275
01/12/2016 13:00	4.8 degrees C	<=15	AO		2149 Lake Placid Rd - S106 - SS#471
01/12/2016 13:30	5.0 degrees C	<=15	AO		3840 Sunridge Drive - P265 - SS#456
01/13/2016 11:30	4.1 degrees C	<=15	AO		4335 Main Street - Main St. - SS#450
01/13/2016 12:20	4.2 degrees C	<=15	AO		7314 Blackcomb Way - P267/S126 - SS#427
01/19/2016 10:20	6.0 degrees C	<=15	AO		1300 Mount Fee Rd
01/19/2016 11:30	5.5 degrees C	<=15	AO		1559 Spring Creek Rd - P273/S132 - SS#480



Temperature		Criteria	Detection Limit/MDL	Sampling Point Name
01/19/2016 12:05	5.8 degrees C	<=15	AO	2400 Taluswood Pl. - P270 - SS#465
01/19/2016 12:35	5.3 degrees C	<=15	AO	1300 Block Alta Lake Rd - SS#482
01/19/2016 13:45	5.8 degrees C	<=15	AO	3333 Carleton Way - S104 - SS#459
01/20/2016 09:45	6.6 degrees C	<=15	AO	8319 Mountainview Dr.- P245 - SS#412
01/20/2016 10:10	7.6 degrees C	<=15	AO	8407 Golden Bear Pl. - P266/S123 - SS#424
01/20/2016 10:35	5.8 degrees C	<=15	AO	6295 Palmer Dr. - Snowflake Park - SS#430
01/20/2016 11:10	5.6 degrees C	<=15	AO	4297 Mountain Square - Mountain Ln - SS#453
01/20/2016 11:40	6.2 degrees C	<=15	AO	4700 Glacier Dr. - P256 - SS#441
01/25/2016 11:20	5.6 degrees C	<=15	AO	5438 Stonebridge drive - P275
01/26/2016 09:40	4.8 degrees C	<=15	AO	2149 Lake Placid Rd - S106 - SS#471
01/26/2016 10:10	6.2 degrees C	<=15	AO	2773 Cheakamus Way - S121- SS#477
01/26/2016 10:45	5.9 degrees C	<=15	AO	3840 Sunridge Drive - P265 - SS#456
01/26/2016 12:00	5.1 degrees C	<=15	AO	7314 Blackcomb Way - P267/S126 - SS#427
01/26/2016 12:35	5.3 degrees C	<=15	AO	4335 Main Street - Main St. - SS#450
01/27/2016 09:10	7.9 degrees C	<=15	AO	8330 Rainbow Dr.- S101 - SS#421
01/27/2016 09:40	7.3 degrees C	<=15	AO	8925 Hwy. 99 - S137
02/02/2016 10:15	10.9 degrees C	<=15	AO	2400 Taluswood Pl. - P270 - SS#465
02/02/2016 12:00	5.4 degrees C	<=15	AO	1300 Mount Fee Rd
02/02/2016 13:00	6.7 degrees C	<=15	AO	1559 Spring Creek Rd - P273/S132 - SS#480
02/02/2016 13:25	6.1 degrees C	<=15	AO	1300 Block Alta Lake Rd - SS#482
02/02/2016 13:50	5.6 degrees C	<=15	AO	3333 Carleton Way - S104 - SS#459

Temperature	Criteria	Detection Limit/MDL	Sampling Point Name
02/03/2016 09:50	6.8 degrees C	<=15 AO	8319 Mountianview Dr.- P245 - SS#412
02/03/2016 10:45	6.3 degrees C	<=15 AO	8407 Golden Bear Pl. - P266/S123 - SS#424
02/03/2016 12:10	4.7 degrees C	<=15 AO	4297 Mountain Square - Mountain Ln - SS#453
02/03/2016 12:50	5.7 degrees C	<=15 AO	6295 Palmer Dr. - Snowflake Park - SS#430
02/03/2016 13:20	6.5 degrees C	<=15 AO	4700 Glacier Dr. - P256 - SS#441
02/09/2016 11:00	5.3 degrees C	<=15 AO	5438 Stonebridge drive - P275
02/09/2016 13:00	5.2 degrees C	<=15 AO	2773 Cheakamus Way - S121- SS#477
02/09/2016 13:25	5.4 degrees C	<=15 AO	2149 Lake Placid Rd - S106 - SS#471
02/09/2016 13:50	5.4 degrees C	<=15 AO	3840 Sunridge Drive - P265 - SS#456
02/10/2016 08:20	6.1 degrees C	<=15 AO	4335 Main Street - Main St. - SS#450
02/10/2016 08:50	5.0 degrees C	<=15 AO	7314 Blackcomb Way - P267/S126 - SS#427
02/10/2016 11:40	6.3 degrees C	<=15 AO	8925 Hwy. 99 - S137
02/16/2016 10:30	6.3 degrees C	<=15 AO	1300 Mount Fee Rd
02/16/2016 11:00	8.7 degrees C	<=15 AO	1559 Spring Creek Rd - P273/S132 - SS#480
02/16/2016 11:35	6.5 degrees C	<=15 AO	1300 Block Alta Lake Rd - SS#482
02/16/2016 13:00	10.5 degrees C	<=15 AO	2400 Taluswood Pl. - P270 - SS#465
02/16/2016 13:45	5.8 degrees C	<=15 AO	3333 Carleton Way - S104 - SS#459
02/17/2016 09:00	6.3 degrees C	<=15 AO	4297 Mountain Square - Mountain Ln - SS#453
02/17/2016 10:40	6.7 degrees C	<=15 AO	8319 Mountianview Dr.- P245 - SS#412
02/17/2016 11:30	7.0 degrees C	<=15 AO	8407 Golden Bear Pl. - P266/S123 - SS#424
02/17/2016 12:30	6.6 degrees C	<=15 AO	6295 Palmer Dr. - Snowflake Park - SS#430

Temperature		Criteria		Detection Limit/MDL	Sampling Point Name
02/17/2016 13:00	7.0 degrees C	<=15	AO		4700 Glacier Dr. - P256 - SS#441
02/23/2016 08:40	5.7 degrees C	<=15	AO		5438 Stonebridge drive - P275
02/23/2016 11:00	7.1 degrees C	<=15	AO		2773 Cheakamus Way - S121- SS#477
02/23/2016 12:00	4.4 degrees C	<=15	AO		2149 Lake Placid Rd - S106 - SS#471
02/23/2016 12:30	5.7 degrees C	<=15	AO		3840 Sunridge Drive - P265 - SS#456
02/24/2016 07:30	9.5 degrees C	<=15	AO		7314 Blackcomb Way - P267/S126 - SS#427
02/24/2016 10:15	6.8 degrees C	<=15	AO		8925 Hwy. 99 - S137
02/24/2016 10:40	6.4 degrees C	<=15	AO		8330 Rainbow Dr.- S101 - SS#421
02/24/2016 11:15	4.1 degrees C	<=15	AO		4335 Main Street - Main St. - SS#450
03/01/2016 08:15	7.0 degrees C	<=15	AO		8319 Mountainview Dr.- P245 - SS#412
03/01/2016 10:30	5.8 degrees C	<=15	AO		1300 Mount Fee Rd
03/01/2016 11:40	6.9 degrees C	<=15	AO		1559 Spring Creek Rd - P273/S132 - SS#480
03/01/2016 12:15	5.7 degrees C	<=15	AO		1300 Block Alta Lake Rd - SS#482
03/01/2016 12:45	5.9 degrees C	<=15	AO		2400 Taluswood Pl. - P270 - SS#465
03/02/2016 08:45	9.8 degrees C	<=15	AO		3333 Carleton Way - S104 - SS#459
03/02/2016 11:25	6.8 degrees C	<=15	AO		8407 Golden Bear Pl. - P266/S123 - SS#424
03/02/2016 11:50	5.3 degrees C	<=15	AO		6295 Palmer Dr. - Snowflake Park - SS#430
03/02/2016 12:30	6.2 degrees C	<=15	AO		4700 Glacier Dr. - P256 - SS#441
03/02/2016 13:00	4.9 degrees C	<=15	AO		4297 Mountain Square - Mountain Ln - SS#453
03/08/2016 08:30	5.9 degrees C	<=15	AO		5438 Stonebridge drive - P275
03/08/2016 11:40	6.7 degrees C	<=15	AO		2773 Cheakamus Way - S121- SS#477

Temperature		Criteria	Detection Limit/MDL	Sampling Point Name
03/08/2016 12:00	6.1 degrees C	<=15	AO	2149 Lake Placid Rd - S106 - SS#471
03/08/2016 12:25	6.7 degrees C	<=15	AO	3840 Sunridge Drive - P265 - SS#456
03/08/2016 13:15	6.0 degrees C	<=15	AO	7314 Blackcomb Way - P267/S126 - SS#427
03/09/2016 09:45	6.7 degrees C	<=15	AO	8925 Hwy. 99 - S137
03/09/2016 10:15	7.3 degrees C	<=15	AO	8330 Rainbow Dr.- S101 - SS#421
03/09/2016 12:25	5.0 degrees C	<=15	AO	4335 Main Street - Main St. - SS#450
03/22/2016 08:45	6.7 degrees C	<=15	AO	7314 Blackcomb Way - P267/S126 - SS#427
03/22/2016 09:30	6.3 degrees C	<=15	AO	8330 Rainbow Dr.- S101 - SS#421
03/22/2016 10:50	5.3 degrees C	<=15	AO	5438 Stonebridge drive - P275
03/22/2016 13:30	5.7 degrees C	<=15	AO	8925 Hwy. 99 - S137
03/23/2016 10:00	6.7 degrees C	<=15	AO	4335 Main Street - Main St. - SS#450
03/23/2016 10:45	6.3 degrees C	<=15	AO	2149 Lake Placid Rd - S106 - SS#471
03/23/2016 11:05	6.2 degrees C	<=15	AO	2773 Cheakamus Way - S121- SS#477
03/23/2016 11:30	5.9 degrees C	<=15	AO	3840 Sunridge Drive - P265 - SS#456
03/29/2016 09:40	5.9 degrees C	<=15	AO	1300 Mount Fee Rd
03/29/2016 10:00	4.9 degrees C	<=15	AO	1559 Spring Creek Rd - P273/S132 - SS#480
03/29/2016 10:45	6.4 degrees C	<=15	AO	6295 Palmer Dr. - Snowflake Park - SS#430
03/29/2016 11:00	6.0 degrees C	<=15	AO	8407 Golden Bear Pl. - P266/S123 - SS#424
03/29/2016 11:50	6.9 degrees C	<=15	AO	3333 Carleton Way - S104 - SS#459
03/29/2016 13:05	6.2 degrees C	<=15	AO	4297 Mountain Square - Mountain Ln - SS#453
03/29/2016 13:35	6.6 degrees C	<=15	AO	4700 Glacier Dr. - P256 - SS#441
03/30/2016 09:00	7.0 degrees C	<=15	AO	2400 Taluswood Pl. - P270 - SS#465

Temperature	Criteria	Detection Limit/MDL	Sampling Point Name
03/30/2016 10:15	6.4 degrees C	<=15 AO	1300 Block Alta Lake Rd - SS#482
03/30/2016 11:15	7.5 degrees C	<=15 AO	8319 Mountainview Dr.- P245 - SS#412
04/04/2016 08:30	5.8 degrees C	<=15 AO	5438 Stonebridge drive - P275
04/04/2016 09:40	8.2 degrees C	<=15 AO	2773 Cheakamus Way - S121- SS#477
04/04/2016 11:00	7.1 degrees C	<=15 AO	2149 Lake Placid Rd - S106 - SS#471
04/04/2016 11:30	7.5 degrees C	<=15 AO	3840 Sunridge Drive - P265 - SS#456
04/04/2016 11:50	8.3 degrees C	<=15 AO	4335 Main Street - Main St. - SS#450
04/04/2016 12:15	7.4 degrees C	<=15 AO	7314 Blackcomb Way - P267/S126 - SS#427
04/05/2016 09:20	7.6 degrees C	<=15 AO	8330 Rainbow Dr.- S101 - SS#421
04/05/2016 10:15	7.1 degrees C	<=15 AO	8925 Hwy. 99 - S137
04/12/2016 09:30	8.7 degrees C	<=15 AO	8319 Mountainview Dr.- P245 - SS#412
04/13/2016 08:10	7.3 degrees C	<=15 AO	2400 Taluswood Pl. - P270 - SS#465
04/13/2016 08:45	7.8 degrees C	<=15 AO	8407 Golden Bear Pl. - P266/S123 - SS#424
04/13/2016 10:35	7.8 degrees C	<=15 AO	6295 Palmer Dr. - Snowflake Park - SS#430
04/13/2016 11:00	8.5 degrees C	<=15 AO	1300 Block Alta Lake Rd - SS#482
04/13/2016 11:35	8.6 degrees C	<=15 AO	1300 Mount Fee Rd
04/13/2016 11:55	9.0 degrees C	<=15 AO	1559 Spring Creek Rd - P273/S132 - SS#480
04/13/2016 12:20	9.0 degrees C	<=15 AO	3333 Carleton Way - S104 - SS#459
04/13/2016 13:30	8.0 degrees C	<=15 AO	4700 Glacier Dr. - P256 - SS#441
04/13/2016 13:45	8.4 degrees C	<=15 AO	4297 Mountain Square - Mountain Ln - SS#453
04/19/2016 13:05	7.5 degrees C	<=15 AO	7314 Blackcomb Way - P267/S126 - SS#427

Temperature		Criteria		Detection Limit/MDL	Sampling Point Name
04/19/2016 13:30	9.5 degrees C	<=15	AO		4335 Main Street - Main St. - SS#450
04/20/2016 09:00	7.3 degrees C	<=15	AO		5438 Stonebridge drive - P275
04/20/2016 10:45	8.6 degrees C	<=15	AO		3840 Sunridge Drive - P265 - SS#456
04/20/2016 11:40	8.2 degrees C	<=15	AO		2149 Lake Placid Rd - S106 - SS#471
04/20/2016 12:00	9.4 degrees C	<=15	AO		2773 Cheakamus Way - S121- SS#477
04/20/2016 12:25	8.6 degrees C	<=15	AO		8925 Hwy. 99 - S137
04/27/2016 08:00	9.3 degrees C	<=15	AO		3333 Carleton Way - S104 - SS#459
04/27/2016 09:00	12.3 degrees C	<=15	AO		2400 Taluswood Pl. - P270 - SS#465
04/27/2016 09:25	9.3 degrees C	<=15	AO		1300 Block Alta Lake Rd - SS#482
04/27/2016 10:20	9.3 degrees C	<=15	AO		1300 Mount Fee Rd
04/27/2016 11:00	7.9 degrees C	<=15	AO		1559 Spring Creek Rd - P273/S132 - SS#480
04/27/2016 11:10	9.5 degrees C	<=15	AO		8319 Mountainview Dr.- P245 - SS#412
04/27/2016 11:26	7.4 degrees C	<=15	AO		8407 Golden Bear Pl. - P266/S123 - SS#424
04/27/2016 11:43	8.1 degrees C	<=15	AO		6295 Palmer Dr. - Snowflake Park - SS#430
04/27/2016 12:37	9.7 degrees C	<=15	AO		4297 Mountain Square - Mountain Ln - SS#453
04/27/2016 12:57	8.2 degrees C	<=15	AO		4700 Glacier Dr. - P256 - SS#441
05/04/2016 08:30	8.5 degrees C	<=15	AO		2773 Cheakamus Way - S121- SS#477
05/04/2016 09:00	7.9 degrees C	<=15	AO		2149 Lake Placid Rd - S106 - SS#471
05/04/2016 09:30	8.1 degrees C	<=15	AO		3840 Sunridge Drive - P265 - SS#456
05/04/2016 11:40	7.7 degrees C	<=15	AO		8925 Hwy. 99 - S137
05/04/2016 12:00	6.1 degrees C	<=15	AO		7314 Blackcomb Way - P267/S126 - SS#427
05/04/2016 12:30	8.1 degrees C	<=15	AO		4335 Main Street - Main St. - SS#450

Temperature		Criteria		Detection Limit/MDL	Sampling Point Name
05/10/2016 12:40	9.9 degrees C	<=15	AO		2400 Taluswood Pl. - P270 - SS#465
05/10/2016 13:15	11.3 degrees C	<=15	AO		3333 Carleton Way - S104 - SS#459
05/11/2016 08:55	9.9 degrees C	<=15	AO		1300 Mount Fee Rd
05/11/2016 09:00	7.1 degrees C	<=15	AO		4297 Mountain Square - Mountain Ln - SS#453
05/11/2016 10:00	7.9 degrees C	<=15	AO		1559 Spring Creek Rd - P273/S132 - SS#480
05/11/2016 10:40	9.3 degrees C	<=15	AO		4700 Glacier Dr. - P256 - SS#441
05/11/2016 10:55	10.6 degrees C	<=15	AO		1300 Block Alta Lake Rd - SS#482
05/11/2016 11:10	9.5 degrees C	<=15	AO		6295 Palmer Dr. - Snowflake Park - SS#430
05/11/2016 11:50	7.5 degrees C	<=15	AO		8407 Golden Bear Pl. - P266/S123 - SS#424
05/11/2016 12:15	10.8 degrees C	<=15	AO		8319 Mountianview Dr.- P245 - SS#412
05/16/2016 12:00	10.1 degrees C	<=15	AO		2773 Cheakamus Way - S121- SS#477
05/16/2016 12:20	10.3 degrees C	<=15	AO		5438 Stonebridge drive - P275
05/16/2016 12:30	7.5 degrees C	<=15	AO		2149 Lake Placid Rd - S106 - SS#471
05/16/2016 13:10	8.8 degrees C	<=15	AO		3840 Sunridge Drive - P265 - SS#456
05/16/2016 13:30	7.5 degrees C	<=15	AO		7314 Blackcomb Way - P267/S126 - SS#427
05/17/2016 09:15	12.3 degrees C	<=15	AO		8330 Rainbow Dr.- S101 - SS#421
05/17/2016 11:10	8.1 degrees C	<=15	AO		8925 Hwy. 99 - S137
05/18/2016 08:00	6.2 degrees C	<=15	AO		4335 Main Street - Main St. - SS#450
05/24/2016 07:41	6.4 degrees C	<=15	AO		8407 Golden Bear Pl. - P266/S123 - SS#424
05/24/2016 07:56	7.4 degrees C	<=15	AO		8319 Mountianview Dr.- P245 - SS#412
05/24/2016 08:19	8.9 degrees C	<=15	AO		6295 Palmer Dr. - Snowflake Park - SS#430

Temperature		Criteria	Detection Limit/MDL	Sampling Point Name
05/24/2016 08:37	10.4 degrees C	<=15	AO	4297 Mountain Square - Mountain Ln - SS#453
05/24/2016 08:56	9.2 degrees C	<=15	AO	4700 Glacier Dr. - P256 - SS#441
05/24/2016 09:56	9.9 degrees C	<=15	AO	3333 Carleton Way - S104 - SS#459
05/24/2016 10:15	9.9 degrees C	<=15	AO	2400 Taluswood Pl. - P270 - SS#465
05/24/2016 10:42	10.3 degrees C	<=15	AO	1300 Block Alta Lake Rd - SS#482
05/24/2016 11:04	8.6 degrees C	<=15	AO	1559 Spring Creek Rd - P273/S132 - SS#480
05/24/2016 11:43	11.0 degrees C	<=15	AO	1300 Mount Fee Rd
05/30/2016 12:30	12.7 degrees C	<=15	AO	5438 Stonebridge drive - P275
05/30/2016 13:30	10.3 degrees C	<=15	AO	2773 Cheakamus Way - S121- SS#477
05/31/2016 07:47	6.2 degrees C	<=15	AO	4335 Main Street - Main St. - SS#450
05/31/2016 08:54	8.4 degrees C	<=15	AO	8925 Hwy. 99 - S137
05/31/2016 11:16	7.9 degrees C	<=15	AO	7314 Blackcomb Way - P267/S126 - SS#427
05/31/2016 11:33	8.0 degrees C	<=15	AO	3840 Sunridge Drive - P265 - SS#456
05/31/2016 11:52	8.5 degrees C	<=15	AO	2149 Lake Placid Rd - S106 - SS#471
06/01/2016 11:15	9.3 degrees C	<=15	AO	8330 Rainbow Dr.- S101 - SS#421
06/06/2016 07:28	9.9 degrees C	<=15	AO	8407 Golden Bear Pl. - P266/S123 - SS#424
06/06/2016 07:48	9.8 degrees C	<=15	AO	8319 Mountainview Dr.- P245 - SS#412
06/06/2016 08:08	9.9 degrees C	<=15	AO	6295 Palmer Dr. - Snowflake Park - SS#430
06/06/2016 08:33	10.5 degrees C	<=15	AO	4297 Mountain Square - Mountain Ln - SS#453
06/06/2016 09:22	10.5 degrees C	<=15	AO	4700 Glacier Dr. - P256 - SS#441
06/06/2016 09:43	11.7 degrees C	<=15	AO	3333 Carleton Way - S104 - SS#459

Temperature	Criteria	Detection Limit/MDL	Sampling Point Name
06/06/2016 10:12	9.5 degrees C	<=15 AO	2400 Taluswood Pl. - P270 - SS#465
06/06/2016 11:16	11.1 degrees C	<=15 AO	1300 Mount Fee Rd
06/06/2016 11:35	9.3 degrees C	<=15 AO	1559 Spring Creek Rd - P273/S132 - SS#480
06/06/2016 12:25	10.2 degrees C	<=15 AO	1300 Block Alta Lake Rd - SS#482
06/13/2016 10:45	11.3 degrees C	<=15 AO	5438 Stonebridge drive - P275
06/13/2016 13:15	7.4 degrees C	<=15 AO	7314 Blackcomb Way - P267/S126 - SS#427
06/13/2016 13:45	7.8 degrees C	<=15 AO	4335 Main Street - Main St. - SS#450
06/14/2016 08:00	9.4 degrees C	<=15 AO	3840 Sunridge Drive - P265 - SS#456
06/14/2016 08:30	9.7 degrees C	<=15 AO	2773 Cheakamus Way - S121- SS#477
06/14/2016 09:00	8.1 degrees C	<=15 AO	2149 Lake Placid Rd - S106 - SS#471
06/14/2016 11:05	8.8 degrees C	<=15 AO	8925 Hwy. 99 - S137
06/20/2016 09:37	12.8 degrees C	<=15 AO	1300 Mount Fee Rd
06/20/2016 09:56	10.2 degrees C	<=15 AO	1559 Spring Creek Rd - P273/S132 - SS#480
06/20/2016 10:13	10.9 degrees C	<=15 AO	1300 Block Alta Lake Rd - SS#482
06/20/2016 11:42	11.3 degrees C	<=15 AO	4297 Mountain Square - Mountain Ln - SS#453
06/20/2016 12:03	10.4 degrees C	<=15 AO	4700 Glacier Dr. - P256 - SS#441
06/20/2016 12:21	9.7 degrees C	<=15 AO	6295 Palmer Dr. - Snowflake Park - SS#430
06/20/2016 12:43	12.9 degrees C	<=15 AO	2400 Taluswood Pl. - P270 - SS#465
06/21/2016 08:10	11.5 degrees C	<=15 AO	3333 Carleton Way - S104 - SS#459
06/21/2016 10:10	8.4 degrees C	<=15 AO	8319 Mountianview Dr.- P245 - SS#412
06/21/2016 13:00	9.7 degrees C	<=15 AO	8407 Golden Bear Pl. - P266/S123 - SS#424
06/28/2016 08:37	9.4 degrees C	<=15 AO	4335 Main Street - Main St. - SS#450

Temperature		Criteria	Detection Limit/MDL	Sampling Point Name
06/28/2016 09:00	9.4 degrees C	<=15	AO	7314 Blackcomb Way - P267/S126 - SS#427
06/28/2016 09:16	10.4 degrees C	<=15	AO	3840 Sunridge Drive - P265 - SS#456
06/28/2016 09:38	9.7 degrees C	<=15	AO	2149 Lake Placid Rd - S106 - SS#471
06/28/2016 09:57	11.3 degrees C	<=15	AO	2773 Cheakamus Way - S121- SS#477
06/28/2016 10:30	12.4 degrees C	<=15	AO	5438 Stonebridge drive - P275
06/28/2016 11:44	9.0 degrees C	<=15	AO	8925 Hwy. 99 - S137
06/29/2016 10:00	9.7 degrees C	<=15	AO	8330 Rainbow Dr.- S101 - SS#421
07/05/2016 08:15	9.8 degrees C	<=15	AO	8407 Golden Bear Pl. - P266/S123 - SS#424
07/05/2016 08:31	11.4 degrees C	<=15	AO	8319 Mountainview Dr.- P245 - SS#412
07/05/2016 09:01	11.0 degrees C	<=15	AO	4297 Mountain Square - Mountain Ln - SS#453
07/05/2016 09:31	10.6 degrees C	<=15	AO	4700 Glacier Dr. - P256 - SS#441
07/05/2016 09:48	10.6 degrees C	<=15	AO	6295 Palmer Dr. - Snowflake Park - SS#430
07/05/2016 10:21	10.1 degrees C	<=15	AO	2400 Taluswood Pl. - P270 - SS#465
07/05/2016 10:43	12.2 degrees C	<=15	AO	3333 Carleton Way - S104 - SS#459
07/05/2016 11:05	11.1 degrees C	<=15	AO	1300 Block Alta Lake Rd - SS#482
07/05/2016 11:20	9.4 degrees C	<=15	AO	1559 Spring Creek Rd - P273/S132 - SS#480
07/05/2016 11:39	12.7 degrees C	<=15	AO	1300 Mount Fee Rd
07/11/2016 12:45	10.1 degrees C	<=15	AO	1559 Spring Creek Rd - P273/S132 - SS#480
07/11/2016 13:00	11.4 degrees C	<=15	AO	2773 Cheakamus Way - S121- SS#477
07/11/2016 13:40	12.0 degrees C	<=15	AO	3840 Sunridge Drive - P265 - SS#456
07/12/2016 08:35	11.1 degrees C	<=15	AO	5438 Stonebridge drive - P275

Temperature	Criteria	Detection Limit/MDL	Sampling Point Name	
07/12/2016 10:15	10.3 degrees C	<=15	AO	2149 Lake Placid Rd - S106 - SS#471
07/12/2016 10:40	10.9 degrees C	<=15	AO	4335 Main Street - Main St. - SS#450
07/12/2016 11:20	10.4 degrees C	<=15	AO	7314 Blackcomb Way - P267/S126 - SS#427
07/12/2016 13:40	11.2 degrees C	<=15	AO	8330 Rainbow Dr.- S101 - SS#421
07/13/2016 09:30	9.8 degrees C	<=15	AO	8925 Hwy. 99 - S137
07/25/2016 08:30	9.1 degrees C	<=15	AO	2149 Lake Placid Rd - S106 - SS#471
07/25/2016 09:00	11.6 degrees C	<=15	AO	2773 Cheakamus Way - S121- SS#477
07/25/2016 09:30	13.8 degrees C	<=15	AO	7314 Blackcomb Way - P267/S126 - SS#427
07/25/2016 10:00	10.7 degrees C	<=15	AO	8330 Rainbow Dr.- S101 - SS#421
07/25/2016 11:45	11.1 degrees C	<=15	AO	8925 Hwy. 99 - S137
07/25/2016 13:00	13.7 degrees C	<=15	AO	3840 Sunridge Drive - P265 - SS#456
07/25/2016 13:30	13.9 degrees C	<=15	AO	4335 Main Street - Main St. - SS#450
07/26/2016 08:15	12.3 degrees C	<=15	AO	5438 Stonebridge drive - P275
08/02/2016	14.3 degrees C	<=15	AO	3333 Carleton Way - S104 - SS#459
08/02/2016 07:27	13.8 degrees C	<=15	AO	8407 Golden Bear Pl. - P266/S123 - SS#424
08/02/2016 07:47	11.6 degrees C	<=15	AO	8319 Mountainview Dr.- P245 - SS#412
08/02/2016 08:11	12 degrees C	<=15	AO	4700 Glacier Dr. - P256 - SS#441
08/02/2016 08:27	13.2 degrees C	<=15	AO	4297 Mountain Square - Mountain Ln - SS#453
08/02/2016 08:46	12.6 degrees C	<=15	AO	6295 Palmer Dr. - Snowflake Park - SS#430
08/02/2016 09:45	11.6 degrees C	<=15	AO	2400 Taluswood Pl. - P270 - SS#465
08/02/2016 10:22	14 degrees C	<=15	AO	1300 Mount Fee Rd
08/02/2016 10:52	10.4 degrees C	<=15	AO	1559 Spring Creek Rd - P273/S132 - SS#480

Temperature		Criteria		Detection Limit/MDL	Sampling Point Name
08/02/2016 11:09	12.1 degrees C	<=15	AO		1300 Block Alta Lake Rd - SS#482
08/09/2016 09:30	13.2 degrees C	<=15	AO		5438 Stonebridge drive - P275
08/09/2016 12:30	11.9 degrees C	<=15	AO		2773 Cheakamus Way - S121- SS#477
08/09/2016 13:10	12.6 degrees C	<=15	AO		7314 Blackcomb Way - P267/S126 - SS#427
08/09/2016 13:45	14.1 degrees C	<=15	AO		4335 Main Street - Main St. - SS#450
08/10/2016 09:00	12.0 degrees C	<=15	AO		2149 Lake Placid Rd - S106 - SS#471
08/10/2016 09:30	12.7 degrees C	<=15	AO		3840 Sunridge Drive - P265 - SS#456
08/10/2016 11:25	12.1 degrees C	<=15	AO		8925 Hwy. 99 - S137
08/10/2016 12:00	10.6 degrees C	<=15	AO		8330 Rainbow Dr.- S101 - SS#421
08/16/2016 10:10	14.6 degrees C	<=15	AO		1300 Mount Fee Rd
08/16/2016 10:50	10.4 degrees C	<=15	AO		1559 Spring Creek Rd - P273/S132 - SS#480
08/16/2016 12:45	12.8 degrees C	<=15	AO		2400 Taluswood Pl. - P270 - SS#465
* 08/16/2016 13:10	18.7 degrees C	<=15	AO		3333 Carleton Way - S104 - SS#459
* 08/16/2016 13:40	16.2 degrees C	<=15	AO		4297 Mountain Square - Mountain Ln - SS#453
08/17/2016 08:00	13.4 degrees C	<=15	AO		1300 Block Alta Lake Rd - SS#482
08/17/2016 09:50	14.5 degrees C	<=15	AO		4700 Glacier Dr. - P256 - SS#441
* 08/17/2016 10:15	16.0 degrees C	<=15	AO		6295 Palmer Dr. - Snowflake Park - SS#430
* 08/17/2016 11:45	16.7 degrees C	<=15	AO		8407 Golden Bear Pl. - P266/S123 - SS#424
08/17/2016 12:05	14.7 degrees C	<=15	AO		8319 Mountianview Dr.- P245 - SS#412
08/22/2016 10:45	12.8 degrees C	<=15	AO		5438 Stonebridge drive - P275
08/23/2016 01:30	11.4 degrees C	<=15	AO		8925 Hwy. 99 - S137
08/23/2016 08:00	11.0 degrees C	<=15	AO		2773 Cheakamus Way - S121- SS#477

Temperature		Criteria		Detection Limit/MDL	Sampling Point Name
08/23/2016 08:45	10.3 degrees C	<=15	AO		2149 Lake Placid Rd - S106 - SS#471
08/23/2016 09:20	13.6 degrees C	<=15	AO		3840 Sunridge Drive - P265 - SS#456
08/23/2016 09:50	12.5 degrees C	<=15	AO		4335 Main Street - Main St. - SS#450
08/23/2016 10:15	12.6 degrees C	<=15	AO		7314 Blackcomb Way - P267/S126 - SS#427
08/23/2016 12:20	9.9 degrees C	<=15	AO		8330 Rainbow Dr.- S101 - SS#421
08/30/2016 08:40	9.9 degrees C	<=15	AO		2400 Taluswood Pl. - P270 - SS#465
* 08/30/2016 11:40	15.5 degrees C	<=15	AO		1300 Mount Fee Rd
08/30/2016 12:20	11.2 degrees C	<=15	AO		1559 Spring Creek Rd - P273/S132 - SS#480
08/30/2016 12:45	13.0 degrees C	<=15	AO		1300 Block Alta Lake Rd - SS#482
08/30/2016 13:40	14.6 degrees C	<=15	AO		4297 Mountain Square - Mountain Ln - SS#453
08/31/2016 10:15	11.1 degrees C	<=15	AO		8319 Mountainview Dr.- P245 - SS#412
* 08/31/2016 11:25	16.4 degrees C	<=15	AO		3333 Carleton Way - S104 - SS#459
08/31/2016 12:50	13.0 degrees C	<=15	AO		4700 Glacier Dr. - P256 - SS#441
08/31/2016 13:10	14.2 degrees C	<=15	AO		8407 Golden Bear Pl. - P266/S123 - SS#424
08/31/2016 13:30	14.0 degrees C	<=15	AO		6295 Palmer Dr. - Snowflake Park - SS#430
09/06/2016 09:15	13.9 degrees C	<=15	AO		5438 Stonebridge drive - P275
09/06/2016 11:00	12 degrees C	<=15	AO		2773 Cheakamus Way - S121- SS#477
09/06/2016 12:00	12.1 degrees C	<=15	AO		2149 Lake Placid Rd - S106 - SS#471
09/06/2016 12:35	13.3 degrees C	<=15	AO		3840 Sunridge Drive - P265 - SS#456
09/06/2016 13:00	12.3 degrees C	<=15	AO		4335 Main Street - Main St. - SS#450

Temperature		Criteria		Detection Limit/MDL	Sampling Point Name
09/06/2016 13:40	12.1 degrees C	<=15	AO		7314 Blackcomb Way - P267/S126 - SS#427
09/07/2016 10:40	12.9 degrees C	<=15	AO		8925 Hwy. 99 - S137
09/07/2016 10:55	13.6 degrees C	<=15	AO		8330 Rainbow Dr.- S101 - SS#421
* 09/13/2016 12:10	15.6 degrees C	<=15	AO		1300 Mount Fee Rd
09/13/2016 12:45	11.6 degrees C	<=15	AO		1559 Spring Creek Rd - P273/S132 - SS#480
09/14/2016 08:45	13.5 degrees C	<=15	AO		2400 Taluswood Pl. - P270 - SS#465
09/14/2016 09:20	14.4 degrees C	<=15	AO		3333 Carleton Way - S104 - SS#459
09/14/2016 09:45	13.3 degrees C	<=15	AO		4297 Mountain Square - Mountain Ln - SS#453
09/14/2016 10:15	12.2 degrees C	<=15	AO		8407 Golden Bear Pl. - P266/S123 - SS#424
09/14/2016 11:15	12.6 degrees C	<=15	AO		1300 Block Alta Lake Rd - SS#482
09/14/2016 12:05	13.3 degrees C	<=15	AO		4700 Glacier Dr. - P256 - SS#441
09/14/2016 12:30	13.0 degrees C	<=15	AO		6295 Palmer Dr. - Snowflake Park - SS#430
09/14/2016 13:40	13.0 degrees C	<=15	AO		8319 Mountianview Dr.- P245 - SS#412
09/19/2016 10:10	12.0 degrees C	<=15	AO		8330 Rainbow Dr.- S101 - SS#421
09/19/2016 11:40	13.4 degrees C	<=15	AO		5438 Stonebridge drive - P275
09/19/2016 12:05	9.8 degrees C	<=15	AO		7314 Blackcomb Way - P267/S126 - SS#427
09/19/2016 13:20	14.2 degrees C	<=15	AO		8925 Hwy. 99 - S137
09/19/2016 13:45	9.9 degrees C	<=15	AO		4335 Main Street - Main St. - SS#450
09/20/2016 08:15	11.4 degrees C	<=15	AO		2773 Cheakamus Way - S121- SS#477
09/20/2016 08:45	11.0 degrees C	<=15	AO		2149 Lake Placid Rd - S106 - SS#471
09/20/2016 11:15	13.0 degrees C	<=15	AO		3840 Sunridge Drive - P265 - SS#456
09/27/2016 10:30	14.2 degrees C	<=15	AO		1300 Mount Fee Rd

Temperature		Criteria	Detection Limit/MDL	Sampling Point Name
09/27/2016 10:50	10.1 degrees C	<=15	AO	1559 Spring Creek Rd - P273/S132 - SS#480
09/27/2016 11:10	11.6 degrees C	<=15	AO	1300 Block Alta Lake Rd - SS#482
09/27/2016 11:50	14.3 degrees C	<=15	AO	2400 Taluswood Pl. - P270 - SS#465
09/27/2016 12:15	13.8 degrees C	<=15	AO	3333 Carleton Way - S104 - SS#459
09/27/2016 12:40	13.1 degrees C	<=15	AO	4297 Mountain Square - Mountain Ln - SS#453
09/28/2016 09:45	11.1 degrees C	<=15	AO	8319 Mountainview Dr.- P245 - SS#412
09/28/2016 10:55	11.9 degrees C	<=15	AO	8407 Golden Bear Pl. - P266/S123 - SS#424
09/28/2016 13:15	12.1 degrees C	<=15	AO	6295 Palmer Dr. - Snowflake Park - SS#430
10/04/2016 09:30	13.0 degrees C	<=15	AO	5438 Stonebridge drive - P275
10/04/2016 11:40	10.8 degrees C	<=15	AO	2773 Cheakamus Way - S121- SS#477
10/04/2016 12:30	11.0 degrees C	<=15	AO	2149 Lake Placid Rd - S106 - SS#471
10/04/2016 13:00	11.9 degrees C	<=15	AO	3840 Sunridge Drive - P265 - SS#456
10/04/2016 13:40	9.8 degrees C	<=15	AO	7314 Blackcomb Way - P267/S126 - SS#427
10/05/2016 08:00	9.1 degrees C	<=15	AO	4335 Main Street - Main St. - SS#450
10/05/2016 09:15	9.3 degrees C	<=15	AO	8330 Rainbow Dr.- S101 - SS#421
10/05/2016 10:35	13.0 degrees C	<=15	AO	8925 Hwy. 99 - S137
10/11/2016 01:20	11.1 degrees C	<=15	AO	4297 Mountain Square - Mountain Ln - SS#453
10/11/2016 08:20	12.5 degrees C	<=15	AO	1300 Mount Fee Rd
10/11/2016 09:10	8.7 degrees C	<=15	AO	1559 Spring Creek Rd - P273/S132 - SS#480
10/11/2016 09:40	11.6 degrees C	<=15	AO	2400 Taluswood Pl. - P270 - SS#465
10/11/2016 10:05	10.9 degrees C	<=15	AO	3333 Carleton Way - S104 - SS#459

Temperature		Criteria		Detection Limit/MDL	Sampling Point Name
10/11/2016 10:40	9.7 degrees C	<=15	AO		6295 Palmer Dr. - Snowflake Park - SS#430
10/11/2016 11:05	10.3 degrees C	<=15	AO		8407 Golden Bear Pl. - P266/S123 - SS#424
10/11/2016 11:20	10.9 degrees C	<=15	AO		8319 Mountianview Dr.- P245 - SS#412
10/11/2016 12:20	12.8 degrees C	<=15	AO		4700 Glacier Dr. - P256 - SS#441
10/11/2016 12:40	10.7 degrees C	<=15	AO		1300 Block Alta Lake Rd - SS#482
10/18/2016 08:30	10.9 degrees C	<=15	AO		2149 Lake Placid Rd - S106 - SS#471
10/18/2016 09:00	11.9 degrees C	<=15	AO		5438 Stonebridge drive - P275
10/18/2016 10:30	9.8 degrees C	<=15	AO		2773 Cheakamus Way - S121- SS#477
10/18/2016 11:10	10.2 degrees C	<=15	AO		3840 Sunridge Drive - P265 - SS#456
10/18/2016 11:40	9.5 degrees C	<=15	AO		4335 Main Street - Main St. - SS#450
10/19/2016 08:25	10.7 degrees C	<=15	AO		8330 Rainbow Dr.- S101 - SS#421
10/19/2016 09:20	11.6 degrees C	<=15	AO		8925 Hwy. 99 - S137
10/19/2016 09:45	7.9 degrees C	<=15	AO		7314 Blackcomb Way - P267/S126 - SS#427
10/24/2016 07:35	10.4 degrees C	<=15	AO		8407 Golden Bear Pl. - P266/S123 - SS#424
10/24/2016 08:06	11.3 degrees C	<=15	AO		8319 Mountianview Dr.- P245 - SS#412
10/24/2016 08:31	10.2 degrees C	<=15	AO		1300 Block Alta Lake Rd - SS#482
10/24/2016 09:09	11.3 degrees C	<=15	AO		1300 Mount Fee Rd
10/24/2016 09:39	8.9 degrees C	<=15	AO		1559 Spring Creek Rd - P273/S132 - SS#480
10/24/2016 10:10	10.5 degrees C	<=15	AO		6295 Palmer Dr. - Snowflake Park - SS#430
10/24/2016 10:10	13.1 degrees C	<=15	AO		2400 Taluswood Pl. - P270 - SS#465
10/24/2016 10:15	10.9 degrees C	<=15	AO		4700 Glacier Dr. - P256 - SS#441

Temperature		Criteria	Detection Limit/MDL	Sampling Point Name
10/24/2016 10:32	10.3 degrees C	<=15	AO	4297 Mountain Square - Mountain Ln - SS#453
10/24/2016 11:32	11.9 degrees C	<=15	AO	3333 Carleton Way - S104 - SS#459
10/31/2016 12:30	8.4 degrees C	<=15	AO	7314 Blackcomb Way - P267/S126 - SS#427
10/31/2016 13:40	10.7 degrees C	<=15	AO	5438 Stonebridge drive - P275
11/01/2016 09:45	9.3 degrees C	<=15	AO	2773 Cheakamus Way - S121- SS#477
11/01/2016 10:50	10.5 degrees C	<=15	AO	2149 Lake Placid Rd - S106 - SS#471
11/01/2016 11:20	9.2 degrees C	<=15	AO	3840 Sunridge Drive - P265 - SS#456
11/01/2016 12:15	8.8 degrees C	<=15	AO	4335 Main Street - Main St. - SS#450
11/01/2016 12:50	9.8 degrees C	<=15	AO	8330 Rainbow Dr.- S101 - SS#421
11/02/2016 08:50	9.1 degrees C	<=15	AO	8925 Hwy. 99 - S137
11/08/2016 10:30	11.9 degrees C	<=15	AO	2400 Taluswood Pl. - P270 - SS#465
11/08/2016 12:00	10.1 degrees C	<=15	AO	1300 Mount Fee Rd
11/08/2016 12:25	9.4 degrees C	<=15	AO	1559 Spring Creek Rd - P273/S132 - SS#480
11/08/2016 13:30	10.3 degrees C	<=15	AO	4297 Mountain Square - Mountain Ln - SS#453
11/09/2016 08:30	10.0 degrees C	<=15	AO	1300 Block Alta Lake Rd - SS#482
11/09/2016 10:30	9.8 degrees C	<=15	AO	3333 Carleton Way - S104 - SS#459
11/09/2016 11:00	9.1 degrees C	<=15	AO	4700 Glacier Dr. - P256 - SS#441
11/09/2016 11:40	10.0 degrees C	<=15	AO	6295 Palmer Dr. - Snowflake Park - SS#430
11/09/2016 12:00	10.4 degrees C	<=15	AO	8407 Golden Bear Pl. - P266/S123 - SS#424
11/09/2016 12:25	10.1 degrees C	<=15	AO	8319 Mountianview Dr.- P245 - SS#412
11/15/2016 10:00	10.5 degrees C	<=15	AO	5438 Stonebridge drive - P275

Temperature		Criteria	Detection Limit/MDL	Sampling Point Name
11/15/2016 11:15	9.0 degrees C	<=15	AO	2773 Cheakamus Way - S121- SS#477
11/15/2016 11:45	10.1 degrees C	<=15	AO	2149 Lake Placid Rd - S106 - SS#471
11/15/2016 12:00	9.2 degrees C	<=15	AO	3840 Sunridge Drive - P265 - SS#456
11/15/2016 12:30	8.0 degrees C	<=15	AO	4335 Main Street - Main St. - SS#450
11/15/2016 12:50	7.7 degrees C	<=15	AO	7314 Blackcomb Way - P267/S126 - SS#427
11/16/2016 09:00	9.9 degrees C	<=15	AO	8925 Hwy. 99 - S137
11/16/2016 11:10	10.1 degrees C	<=15	AO	8330 Rainbow Dr.- S101 - SS#421
11/22/2016 09:45	10.4 degrees C	<=15	AO	2400 Taluswood Pl. - P270 - SS#465
11/22/2016 12:15	9.3 degrees C	<=15	AO	1300 Mount Fee Rd
11/22/2016 12:35	9.2 degrees C	<=15	AO	1559 Spring Creek Rd - P273/S132 - SS#480
11/22/2016 13:00	8.4 degrees C	<=15	AO	1300 Block Alta Lake Rd - SS#482
11/23/2016 09:20	8.8 degrees C	<=15	AO	3333 Carleton Way - S104 - SS#459
11/23/2016 09:50	8.9 degrees C	<=15	AO	4297 Mountain Square - Mountain Ln - SS#453
11/23/2016 10:10	8.7 degrees C	<=15	AO	4700 Glacier Dr. - P256 - SS#441
11/23/2016 10:50	9.0 degrees C	<=15	AO	6295 Palmer Dr. - Snowflake Park - SS#430
11/23/2016 11:10	10.2 degrees C	<=15	AO	8407 Golden Bear Pl. - P266/S123 - SS#424
11/23/2016 12:40	9.8 degrees C	<=15	AO	8319 Mountainview Dr.- P245 - SS#412
11/28/2016 11:10	8.8 degrees C	<=15	AO	8925 Hwy. 99 - S137
11/28/2016 11:35	9.6 degrees C	<=15	AO	8330 Rainbow Dr.- S101 - SS#421
11/29/2016 08:55	8.4 degrees C	<=15	AO	5438 Stonebridge drive - P275
11/29/2016 10:00	6.1 degrees C	<=15	AO	7314 Blackcomb Way - P267/S126 - SS#427
11/29/2016 11:00	7.7 degrees C	<=15	AO	2149 Lake Placid Rd - S106 - SS#471

Temperature		Criteria		Detection Limit/MDL	Sampling Point Name
11/29/2016 11:15	7.8 degrees C	<=15	AO		2773 Cheakamus Way - S121- SS#477
11/29/2016 11:40	10.4 degrees C	<=15	AO		3840 Sunridge Drive - P265 - SS#456
11/30/2016 08:15	4.8 degrees C	<=15	AO		4335 Main Street - Main St. - SS#450
12/05/2016 10:15	9.5 degrees C	<=15	AO		8407 Golden Bear Pl. - P266/S123 - SS#424
12/05/2016 11:00	8.3 degrees C	<=15	AO		6295 Palmer Dr. - Snowflake Park - SS#430
12/05/2016 11:30	7.8 degrees C	<=15	AO		3333 Carleton Way - S104 - SS#459
12/05/2016 11:45	8.8 degrees C	<=15	AO		4297 Mountain Square - Mountain Ln - SS#453
12/06/2016 09:20	7.4 degrees C	<=15	AO		8319 Mountainview Dr.- P245 - SS#412
12/06/2016 09:50	8.8 degrees C	<=15	AO		1559 Spring Creek Rd - P273/S132 - SS#480
12/06/2016 10:10	8.2 degrees C	<=15	AO		1300 Mount Fee Rd
12/06/2016 10:30	7.7 degrees C	<=15	AO		1300 Block Alta Lake Rd - SS#482
12/06/2016 11:45	8.4 degrees C	<=15	AO		4700 Glacier Dr. - P256 - SS#441
12/06/2016 12:20	10.7 degrees C	<=15	AO		2400 Taluswood Pl. - P270 - SS#465
12/13/2016 09:25	7.9 degrees C	<=15	AO		7314 Blackcomb Way - P267/S126 - SS#427
12/13/2016 09:50	7.2 degrees C	<=15	AO		8330 Rainbow Dr.- S101 - SS#421
12/13/2016 10:20	8.4 degrees C	<=15	AO		8925 Hwy. 99 - S137
12/13/2016 11:15	9.1 degrees C	<=15	AO		2149 Lake Placid Rd - S106 - SS#471
12/13/2016 11:40	7.9 degrees C	<=15	AO		2773 Cheakamus Way - S121- SS#477
12/13/2016 12:00	8.3 degrees C	<=15	AO		5438 Stonebridge drive - P275
12/14/2016 08:35	6.0 degrees C	<=15	AO		3840 Sunridge Drive - P265 - SS#456
12/20/2016 11:35	6.0 degrees C	<=15	AO		1300 Mount Fee Rd
12/20/2016 12:25	8.7 degrees C	<=15	AO		1559 Spring Creek Rd - P273/S132 - SS#480

Temperature		Criteria	Detection Limit/MDL	Sampling Point Name
12/20/2016 13:10	6.7 degrees C	<=15	AO	2400 Taluswood Pl. - P270 - SS#465
12/20/2016 13:35	6.3 degrees C	<=15	AO	1300 Block Alta Lake Rd - SS#482
# samples:	427	min:	4.1 degrees C	
# detects:	427	max:	18.7 degrees C	
# non-detects:	0	avg:	9.345 degrees C (based on 427 numerical results)	
# of Exceedences:	7			

Total Dissolved Solids / TDS		Criteria	Detection Limit/MDL	Sampling Point Name
01/11/2016 12:35	53 mg/L	<=200	User-Defined	8319 Mountianview Dr.- P245 - SS#412
01/11/2016 13:10	96 mg/L	<=200	User-Defined	8330 Rainbow Dr.- S101 - SS#421
01/11/2016 13:35	47 mg/L	<=200	User-Defined	8925 Hwy. 99 - S137
# samples:	3	min:	47 mg/L	
# detects:	3	max:	96 mg/L	
# non-detects:	0	avg:	65.333 mg/L (based on 3 numerical results)	
# of Exceedences:	0			

Total Dissolved Solids / TDS (computed)		Criteria	Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	120 mg/L		1.00	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	67.6 mg/L		1.00	8925 Hwy. 99 - S137
# samples:	2	min:	67.6 mg/L	
# detects:	2	max:	120 mg/L	
# non-detects:	0	avg:	93.800 mg/L (based on 2 numerical results)	
# of Exceedences:	0			

Total Organic Carbon / TOC		Criteria	Detection Limit/MDL	Sampling Point Name
01/11/2016 12:35	< 0.5 mg/L	<=2.5	User-Defined	8319 Mountianview Dr.- P245 - SS#412
01/11/2016 13:10	< 0.5 mg/L	<=2.5	User-Defined	8330 Rainbow Dr.- S101 - SS#421
01/11/2016 13:35	< 0.5 mg/L	<=2.5	User-Defined	8925 Hwy. 99 - S137

# samples:	3	min:	< 0.5 mg/L
# detects:	0	max:	< 0.5 mg/L
# non-detects:	3	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Total Trihalomethanes / TTHM		Criteria		Detection Limit/MDL	Sampling Point Name
01/15/2016 10:00	4 ug/L	<=100	User-Defined	4	1300 Mount Fee Rd
01/15/2016 12:30	17 ug/L	<=100	User-Defined	4	4335 Main Street - Main St. - SS#450
01/15/2016 13:30	37 ug/L	<=100	User-Defined	4	4700 Glacier Dr. - P256 - SS#441
04/01/2016 08:00	5 ug/L	<=100	User-Defined	4	1300 Mount Fee Rd
04/01/2016 09:30	< 4 ug/L	<=100	User-Defined	4	7314 Blackcomb Way - P267/S126 - SS#427
04/01/2016 11:25	< 4 ug/L	<=100	User-Defined	4	2642 Whistler Road - P264 - SS#462
04/01/2016 11:55	16 ug/L	<=100	User-Defined	4	4335 Main Street - Main St. - SS#450
04/01/2016 12:15	33 ug/L	<=100	User-Defined	4	4700 Glacier Dr. - P256 - SS#441
06/22/2016 11:45	18 ug/L	<=100	User-Defined	4	7314 Blackcomb Way - P267/S126 - SS#427
06/22/2016 13:30	4 ug/L	<=100	User-Defined	4	1300 Mount Fee Rd
06/23/2016 08:50	23 ug/L	<=100	User-Defined	4	2642 Whistler Road - P264 - SS#462
06/28/2016 13:45	18 ug/L	<=100	User-Defined	4	4335 Main Street - Main St. - SS#450
06/28/2016 14:00	36 ug/L	<=100	User-Defined	4	4700 Glacier Dr. - P256 - SS#441
09/15/2016 13:00	< 4 ug/L	<=100	User-Defined	4	1300 Mount Fee Rd
10/12/2016 11:35	< 4 ug/L	<=100	User-Defined	4	2642 Whistler Road - P264 - SS#462
10/12/2016 12:45	36 ug/L	<=100	User-Defined	4	4335 Main Street - Main St. - SS#450
10/12/2016 13:00	44 ug/L	<=100	User-Defined	4	4700 Glacier Dr. - P256 - SS#441
10/13/2016 13:50	< 4 ug/L	<=100	User-Defined	4	7314 Blackcomb Way - P267/S126 - SS#427

# samples:	18	min:	< 4 ug/L
# detects:	13	max:	44 ug/L
# non-detects:	5	avg:	22.385 ug/L (based on 13 numerical results)

of Exceedences: 0

Trichloroacetic acid		Criteria	Detection Limit/MDL	Sampling Point Name
01/15/2016 10:00	< 0.002 mg/L		0.002	1300 Mount Fee Rd
01/15/2016 12:30	0.007 mg/L		0.002	4335 Main Street - Main St. - SS#450
01/15/2016 13:30	0.029 mg/L		0.002	4700 Glacier Dr. - P256 - SS#441
04/01/2016 08:00	< 0.002 mg/L		0.002	1300 Mount Fee Rd
04/01/2016 09:30	< 0.002 mg/L		0.002	7314 Blackcomb Way - P267/S126 - SS#427
04/01/2016 11:25	< 0.002 mg/L		0.002	2642 Whistler Road - P264 - SS#462
04/01/2016 11:55	0.010 mg/L		0.002	4335 Main Street - Main St. - SS#450
04/01/2016 12:15	0.027 mg/L		0.002	4700 Glacier Dr. - P256 - SS#441
06/22/2016 11:45	0.009 mg/L		0.002	7314 Blackcomb Way - P267/S126 - SS#427
06/22/2016 13:30	< 0.002 mg/L		0.002	1300 Mount Fee Rd
06/23/2016 08:50	0.011 mg/L		0.002	2642 Whistler Road - P264 - SS#462
06/28/2016 13:45	0.007 mg/L		0.002	4335 Main Street - Main St. - SS#450
06/28/2016 14:00	0.027 mg/L		0.002	4700 Glacier Dr. - P256 - SS#441
09/15/2016 13:00	< 0.002 mg/L		0.002	1300 Mount Fee Rd
10/12/2016 11:35	< 0.002 mg/L		0.002	2642 Whistler Road - P264 - SS#462
10/12/2016 12:45	0.022 mg/L		0.002	4335 Main Street - Main St. - SS#450
10/12/2016 13:00	0.036 mg/L		0.002	4700 Glacier Dr. - P256 - SS#441
10/13/2016 13:50	< 0.002 mg/L		0.002	7314 Blackcomb Way - P267/S126 - SS#427

# samples:	18	min:	< 0.002 mg/L
# detects:	10	max:	0.036 mg/L
# non-detects:	8	avg:	0.019 mg/L (based on 10 numerical results)
# of Exceedences:	0		



Turbidity		Criteria		Detection Limit/MDL	Sampling Point Name
01/05/2016 10:30	0.14 NTU	<=1	User-Defined		1300 Mount Fee Rd
01/05/2016 12:30	0.16 NTU	<=1	User-Defined		1559 Spring Creek Rd - P273/S132 - SS#480
01/05/2016 12:55	0.11 NTU	<=1	User-Defined		4297 Mountain Square - Mountain Ln - SS#453
01/05/2016 13:10	0.13 NTU	<=1	User-Defined		1300 Block Alta Lake Rd - SS#482
01/05/2016 13:20	0.13 NTU	<=1	User-Defined		4700 Glacier Dr. - P256 - SS#441
01/05/2016 13:40	0.12 NTU	<=1	User-Defined		2400 Taluswood Pl. - P270 - SS#465
01/06/2016 11:30	0.56 NTU	<=1	User-Defined		8319 Mountianview Dr.- P245 - SS#412
01/06/2016 12:00	0.10 NTU	<=1	User-Defined		8407 Golden Bear Pl. - P266/S123 - SS#424
01/06/2016 12:25	0.11 NTU	<=1	User-Defined		6295 Palmer Dr. - Snowflake Park - SS#430
01/11/2016 13:10	0.28 NTU	<=1	User-Defined		8330 Rainbow Dr.- S101 - SS#421
01/11/2016 13:35	0.78 NTU	<=1	User-Defined		8925 Hwy. 99 - S137
01/12/2016 10:30	0.12 NTU	<=1	User-Defined		2773 Cheakamus Way - S121- SS#477
01/12/2016 11:00	0.46 NTU	<=1	User-Defined		5438 Stonebridge drive - P275
01/12/2016 13:00	0.42 NTU	<=1	User-Defined		2149 Lake Placid Rd - S106 - SS#471
01/12/2016 13:30	0.13 NTU	<=1	User-Defined		3840 Sunridge Drive - P265 - SS#456
01/13/2016 11:30	0.17 NTU	<=1	User-Defined		4335 Main Street - Main St. - SS#450
01/13/2016 12:20	0.32 NTU	<=1	User-Defined		7314 Blackcomb Way - P267/S126 - SS#427
01/19/2016 10:20	0.07 NTU	<=1	User-Defined		1300 Mount Fee Rd
01/19/2016 11:30	0.11 NTU	<=1	User-Defined		1559 Spring Creek Rd - P273/S132 - SS#480
01/19/2016 12:05	0.22 NTU	<=1	User-Defined		2400 Taluswood Pl. - P270 - SS#465
01/19/2016 12:35	0.17 NTU	<=1	User-Defined		1300 Block Alta Lake Rd - SS#482
01/19/2016 13:45	0.10 NTU	<=1	User-Defined		3333 Carleton Way - S104 - SS#459

Turbidity		Criteria	Detection Limit/MDL	Sampling Point Name
01/20/2016 09:45	0.43 NTU	<=1	User-Defined	8319 Mountianview Dr.- P245 - SS#412
01/20/2016 10:10	0.10 NTU	<=1	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
01/20/2016 10:35	0.25 NTU	<=1	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
01/20/2016 11:10	0.21 NTU	<=1	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
01/20/2016 11:40	0.18 NTU	<=1	User-Defined	4700 Glacier Dr. - P256 - SS#441
01/25/2016 11:20	0.30 NTU	<=1	User-Defined	5438 Stonebridge drive - P275
01/26/2016 09:40	0.28 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
01/26/2016 10:10	0.12 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
01/26/2016 10:45	0.35 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456
01/26/2016 12:00	0.41 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
01/26/2016 12:35	0.38 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
01/27/2016 09:10	0.10 NTU	<=1	User-Defined	8330 Rainbow Dr.- S101 - SS#421
01/27/2016 09:40	0.45 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
02/02/2016 10:15	0.10 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465
02/02/2016 12:00	0.09 NTU	<=1	User-Defined	1300 Mount Fee Rd
02/02/2016 13:00	0.30 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
02/02/2016 13:25	0.10 NTU	<=1	User-Defined	1300 Block Alta Lake Rd - SS#482
02/02/2016 13:50	0.25 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459
02/03/2016 09:50	0.34 NTU	<=1	User-Defined	8319 Mountianview Dr.- P245 - SS#412
02/03/2016 10:45	0.41 NTU	<=1	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
02/03/2016 12:10	0.29 NTU	<=1	User-Defined	4297 Mountain Square - Mountain Ln - SS#453

Turbidity		Criteria	Detection Limit/MDL	Sampling Point Name
02/03/2016 12:50	0.34 NTU	<=1	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
02/03/2016 13:20	0.18 NTU	<=1	User-Defined	4700 Glacier Dr. - P256 - SS#441
02/09/2016 11:00	0.19 NTU	<=1	User-Defined	5438 Stonebridge drive - P275
02/09/2016 13:00	0.23 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
02/09/2016 13:25	0.31 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
02/09/2016 13:50	0.35 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456
02/10/2016 08:20	0.51 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
02/10/2016 08:50	0.48 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
02/10/2016 11:40	0.41 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
02/16/2016 10:30	0.07 NTU	<=1	User-Defined	1300 Mount Fee Rd
02/16/2016 11:00	0.08 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
02/16/2016 11:35	0.12 NTU	<=1	User-Defined	1300 Block Alta Lake Rd - SS#482
02/16/2016 13:00	0.11 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465
02/16/2016 13:45	0.07 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459
02/17/2016 09:00	0.15 NTU	<=1	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
02/17/2016 10:40	0.17 NTU	<=1	User-Defined	8319 Mountainview Dr.- P245 - SS#412
02/17/2016 11:30	0.07 NTU	<=1	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
02/17/2016 12:30	0.11 NTU	<=1	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
02/17/2016 13:00	0.14 NTU	<=1	User-Defined	4700 Glacier Dr. - P256 - SS#441
02/23/2016 08:40	0.14 NTU	<=1	User-Defined	5438 Stonebridge drive - P275
02/23/2016 11:00	0.12 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477

Turbidity		Criteria	Detection Limit/MDL	Sampling Point Name
02/23/2016 12:00	0.24 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
02/23/2016 12:30	0.24 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456
02/24/2016 07:30	0.35 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
02/24/2016 10:15	0.35 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
02/24/2016 10:40	0.36 NTU	<=1	User-Defined	8330 Rainbow Dr.- S101 - SS#421
02/24/2016 11:15	0.39 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
03/01/2016 08:15	0.15 NTU	<=1	User-Defined	8319 Mountainview Dr.- P245 - SS#412
03/01/2016 10:30	0.07 NTU	<=1	User-Defined	1300 Mount Fee Rd
03/01/2016 11:40	0.07 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
03/01/2016 12:15	0.17 NTU	<=1	User-Defined	1300 Block Alta Lake Rd - SS#482
03/01/2016 12:45	0.30 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465
03/02/2016 08:45	0.33 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459
03/02/2016 11:25	0.21 NTU	<=1	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
03/02/2016 11:50	0.24 NTU	<=1	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
03/02/2016 12:30	0.24 NTU	<=1	User-Defined	4700 Glacier Dr. - P256 - SS#441
03/02/2016 13:00	0.45 NTU	<=1	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
03/08/2016 08:30	0.11 NTU	<=1	User-Defined	5438 Stonebridge drive - P275
03/08/2016 11:40	0.17 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
03/08/2016 12:00	0.24 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
03/08/2016 12:25	0.13 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456
03/08/2016 13:15	0.84 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
03/09/2016 09:45	0.65 NTU	<=1	User-Defined	8925 Hwy. 99 - S137

Turbidity		Criteria	Detection Limit/MDL	Sampling Point Name
03/09/2016 10:15	0.27 NTU	<=1	User-Defined	8330 Rainbow Dr.- S101 - SS#421
03/09/2016 12:25	0.29 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
03/22/2016 08:45	0.11 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
03/22/2016 09:30	0.24 NTU	<=1	User-Defined	8330 Rainbow Dr.- S101 - SS#421
03/22/2016 10:50	0.38 NTU	<=1	User-Defined	5438 Stonebridge drive - P275
03/22/2016 13:30	0.25 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
03/23/2016 10:00	0.21 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
03/23/2016 10:45	0.15 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
03/23/2016 11:05	0.11 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
03/23/2016 11:30	0.12 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456
03/29/2016 09:40	0.12 NTU	<=1	User-Defined	1300 Mount Fee Rd
03/29/2016 10:00	0.26 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
03/29/2016 10:45	0.23 NTU	<=1	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
03/29/2016 11:00	0.31 NTU	<=1	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
03/29/2016 11:50	0.21 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459
03/29/2016 13:05	0.17 NTU	<=1	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
03/29/2016 13:35	0.27 NTU	<=1	User-Defined	4700 Glacier Dr. - P256 - SS#441
03/30/2016 09:00	0.14 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465
03/30/2016 10:15	0.17 NTU	<=1	User-Defined	1300 Block Alta Lake Rd - SS#482
03/30/2016 11:15	0.40 NTU	<=1	User-Defined	8319 Mountianview Dr.- P245 - SS#412
04/04/2016 08:30	0.19 NTU	<=1	User-Defined	5438 Stonebridge drive - P275

Turbidity	Criteria	Detection Limit/MDL	Sampling Point Name	
04/04/2016 09:40	0.13 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
04/04/2016 11:00	0.10 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
04/04/2016 11:30	0.06 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456
04/04/2016 11:50	0.19 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
04/04/2016 12:15	0.05 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
04/05/2016 09:20	0.05 NTU	<=1	User-Defined	8330 Rainbow Dr.- S101 - SS#421
* 04/05/2016 10:15	1.78 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
04/12/2016 09:30	0.47 NTU	<=1	User-Defined	8319 Mountainview Dr.- P245 - SS#412
04/13/2016 08:10	0.08 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465
04/13/2016 08:45	0.07 NTU	<=1	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
04/13/2016 10:35	0.13 NTU	<=1	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
04/13/2016 11:00	0.11 NTU	<=1	User-Defined	1300 Block Alta Lake Rd - SS#482
04/13/2016 11:35	0.07 NTU	<=1	User-Defined	1300 Mount Fee Rd
04/13/2016 11:55	0.20 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
04/13/2016 12:20	0.06 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459
04/13/2016 13:30	0.23 NTU	<=1	User-Defined	4700 Glacier Dr. - P256 - SS#441
04/13/2016 13:45	0.13 NTU	<=1	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
04/19/2016 13:05	0.69 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
04/19/2016 13:30	0.13 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
04/20/2016 09:00	0.22 NTU	<=1	User-Defined	5438 Stonebridge drive - P275
04/20/2016 10:45	0.35 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456

Turbidity	Criteria	Detection Limit/MDL	Sampling Point Name	
04/20/2016 11:40	0.40 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
04/20/2016 12:00	0.23 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
04/20/2016 12:25	0.62 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
04/27/2016 08:00	0.26 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459
04/27/2016 09:00	0.33 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465
04/27/2016 09:25	0.11 NTU	<=1	User-Defined	1300 Block Alta Lake Rd - SS#482
04/27/2016 10:20	0.09 NTU	<=1	User-Defined	1300 Mount Fee Rd
04/27/2016 11:00	0.24 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
04/27/2016 11:10	0.64 NTU	<=1	User-Defined	8319 Mountianview Dr.- P245 - SS#412
04/27/2016 11:26	0.56 NTU	<=1	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
04/27/2016 11:43	0.40 NTU	<=1	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
04/27/2016 12:37	0.29 NTU	<=1	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
04/27/2016 12:57	0.27 NTU	<=1	User-Defined	4700 Glacier Dr. - P256 - SS#441
05/04/2016 08:30	0.37 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
05/04/2016 09:00	0.20 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
05/04/2016 09:30	0.17 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456
05/04/2016 11:40	0.70 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
05/04/2016 12:00	0.64 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
05/04/2016 12:30	0.70 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
05/10/2016 12:40	0.40 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465
05/10/2016 13:15	0.21 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459
05/11/2016 08:55	0.08 NTU	<=1	User-Defined	1300 Mount Fee Rd

Turbidity		Criteria		Detection Limit/MDL	Sampling Point Name
05/11/2016 09:00	0.48 NTU	<=1	User-Defined		4297 Mountain Square - Mountain Ln - SS#453
05/11/2016 10:00	0.23 NTU	<=1	User-Defined		1559 Spring Creek Rd - P273/S132 - SS#480
05/11/2016 10:40	0.23 NTU	<=1	User-Defined		4700 Glacier Dr. - P256 - SS#441
05/11/2016 10:55	0.12 NTU	<=1	User-Defined		1300 Block Alta Lake Rd - SS#482
05/11/2016 11:10	0.36 NTU	<=1	User-Defined		6295 Palmer Dr. - Snowflake Park - SS#430
05/11/2016 11:50	0.40 NTU	<=1	User-Defined		8407 Golden Bear Pl. - P266/S123 - SS#424
05/11/2016 12:15	0.32 NTU	<=1	User-Defined		8319 Mountianview Dr.- P245 - SS#412
05/16/2016 12:00	0.24 NTU	<=1	User-Defined		2773 Cheakamus Way - S121- SS#477
05/16/2016 12:20	0.11 NTU	<=1	User-Defined		5438 Stonebridge drive - P275
05/16/2016 12:30	0.31 NTU	<=1	User-Defined		2149 Lake Placid Rd - S106 - SS#471
05/16/2016 13:10	0.37 NTU	<=1	User-Defined		3840 Sunridge Drive - P265 - SS#456
05/16/2016 13:30	0.34 NTU	<=1	User-Defined		7314 Blackcomb Way - P267/S126 - SS#427
05/17/2016 09:15	0.87 NTU	<=1	User-Defined		8330 Rainbow Dr.- S101 - SS#421
05/17/2016 11:10	0.58 NTU	<=1	User-Defined		8925 Hwy. 99 - S137
05/18/2016 08:00	0.56 NTU	<=1	User-Defined		4335 Main Street - Main St. - SS#450
05/24/2016 07:41	0.39 NTU	<=1	User-Defined		8407 Golden Bear Pl. - P266/S123 - SS#424
05/24/2016 07:56	0.30 NTU	<=1	User-Defined		8319 Mountianview Dr.- P245 - SS#412
05/24/2016 08:19	0.26 NTU	<=1	User-Defined		6295 Palmer Dr. - Snowflake Park - SS#430
05/24/2016 08:37	0.43 NTU	<=1	User-Defined		4297 Mountain Square - Mountain Ln - SS#453
05/24/2016 08:56	0.32 NTU	<=1	User-Defined		4700 Glacier Dr. - P256 - SS#441

Turbidity		Criteria	Detection Limit/MDL	Sampling Point Name
05/24/2016 09:56	0.17 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459
05/24/2016 10:15	0.15 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465
05/24/2016 10:42	0.20 NTU	<=1	User-Defined	1300 Block Alta Lake Rd - SS#482
05/24/2016 11:04	0.21 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
05/24/2016 11:43	0.14 NTU	<=1	User-Defined	1300 Mount Fee Rd
05/30/2016 12:30	0.32 NTU	<=1	User-Defined	5438 Stonebridge drive - P275
05/30/2016 13:30	0.21 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
05/31/2016 07:47	0.46 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
05/31/2016 08:54	0.72 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
05/31/2016 11:16	0.32 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
05/31/2016 11:33	0.35 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456
05/31/2016 11:52	0.22 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
06/01/2016 11:15	0.32 NTU	<=1	User-Defined	8330 Rainbow Dr.- S101 - SS#421
06/06/2016 07:28	0.20 NTU	<=1	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
06/06/2016 07:48	0.32 NTU	<=1	User-Defined	8319 Mountianview Dr.- P245 - SS#412
06/06/2016 08:08	0.36 NTU	<=1	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
06/06/2016 08:33	0.23 NTU	<=1	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
06/06/2016 09:22	0.33 NTU	<=1	User-Defined	4700 Glacier Dr. - P256 - SS#441
06/06/2016 09:43	0.25 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459
06/06/2016 10:12	0.26 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465
06/06/2016 11:16	0.14 NTU	<=1	User-Defined	1300 Mount Fee Rd
06/06/2016 11:35	0.33 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480

Turbidity		Criteria		Detection Limit/MDL	Sampling Point Name
06/06/2016 12:25	0.36 NTU	<=1	User-Defined		1300 Block Alta Lake Rd - SS#482
06/13/2016 10:45	0.30 NTU	<=1	User-Defined		5438 Stonebridge drive - P275
06/13/2016 13:15	0.20 NTU	<=1	User-Defined		7314 Blackcomb Way - P267/S126 - SS#427
06/13/2016 13:45	0.36 NTU	<=1	User-Defined		4335 Main Street - Main St. - SS#450
06/14/2016 08:00	0.25 NTU	<=1	User-Defined		3840 Sunridge Drive - P265 - SS#456
06/14/2016 08:30	0.49 NTU	<=1	User-Defined		2773 Cheakamus Way - S121- SS#477
06/14/2016 09:00	0.20 NTU	<=1	User-Defined		2149 Lake Placid Rd - S106 - SS#471
06/14/2016 11:05	0.42 NTU	<=1	User-Defined		8925 Hwy. 99 - S137
06/20/2016 09:37	0.17 NTU	<=1	User-Defined		1300 Mount Fee Rd
06/20/2016 09:56	0.15 NTU	<=1	User-Defined		1559 Spring Creek Rd - P273/S132 - SS#480
06/20/2016 10:13	0.37 NTU	<=1	User-Defined		1300 Block Alta Lake Rd - SS#482
06/20/2016 11:42	0.34 NTU	<=1	User-Defined		4297 Mountain Square - Mountain Ln - SS#453
06/20/2016 12:03	0.26 NTU	<=1	User-Defined		4700 Glacier Dr. - P256 - SS#441
06/20/2016 12:21	0.22 NTU	<=1	User-Defined		6295 Palmer Dr. - Snowflake Park - SS#430
06/20/2016 12:43	0.30 NTU	<=1	User-Defined		2400 Taluswood Pl. - P270 - SS#465
06/21/2016 08:10	0.33 NTU	<=1	User-Defined		3333 Carleton Way - S104 - SS#459
06/21/2016 10:10	0.09 NTU	<=1	User-Defined		8319 Mountainview Dr.- P245 - SS#412
06/21/2016 13:00	0.24 NTU	<=1	User-Defined		8407 Golden Bear Pl. - P266/S123 - SS#424
06/28/2016 08:37	0.85 NTU	<=1	User-Defined		4335 Main Street - Main St. - SS#450
06/28/2016 09:00	0.69 NTU	<=1	User-Defined		7314 Blackcomb Way - P267/S126 - SS#427
06/28/2016 09:16	0.28 NTU	<=1	User-Defined		3840 Sunridge Drive - P265 - SS#456

Turbidity		Criteria	Detection Limit/MDL	Sampling Point Name
06/28/2016 09:38	0.78 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
06/28/2016 09:57	0.16 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
06/28/2016 10:30	0.37 NTU	<=1	User-Defined	5438 Stonebridge drive - P275
06/28/2016 11:44	0.48 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
06/29/2016 10:00	0.07 NTU	<=1	User-Defined	8330 Rainbow Dr.- S101 - SS#421
07/05/2016 08:15	0.43 NTU	<=1	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
07/05/2016 08:31	0.31 NTU	<=1	User-Defined	8319 Mountianview Dr.- P245 - SS#412
07/05/2016 09:01	0.39 NTU	<=1	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
07/05/2016 09:31	0.31 NTU	<=1	User-Defined	4700 Glacier Dr. - P256 - SS#441
07/05/2016 09:48	0.21 NTU	<=1	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
07/05/2016 10:21	0.42 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465
07/05/2016 10:43	0.38 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459
07/05/2016 11:05	0.15 NTU	<=1	User-Defined	1300 Block Alta Lake Rd - SS#482
07/05/2016 11:20	0.33 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
07/05/2016 11:39	0.14 NTU	<=1	User-Defined	1300 Mount Fee Rd
07/11/2016 12:45	0.19 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
07/11/2016 13:00	0.08 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
07/11/2016 13:40	0.39 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456
07/12/2016 08:35	0.09 NTU	<=1	User-Defined	5438 Stonebridge drive - P275
07/12/2016 10:15	0.38 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
07/12/2016 10:40	0.37 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450

Turbidity		Criteria		Detection Limit/MDL	Sampling Point Name
07/12/2016 11:20	0.19 NTU	<=1	User-Defined		7314 Blackcomb Way - P267/S126 - SS#427
07/12/2016 13:40	0.18 NTU	<=1	User-Defined		8330 Rainbow Dr.- S101 - SS#421
07/13/2016 09:30	0.37 NTU	<=1	User-Defined		8925 Hwy. 99 - S137
07/25/2016 08:30	0.10 NTU	<=1	User-Defined		2149 Lake Placid Rd - S106 - SS#471
07/25/2016 09:00	0.08 NTU	<=1	User-Defined		2773 Cheakamus Way - S121- SS#477
07/25/2016 09:30	0.44 NTU	<=1	User-Defined		7314 Blackcomb Way - P267/S126 - SS#427
07/25/2016 10:00	0.31 NTU	<=1	User-Defined		8330 Rainbow Dr.- S101 - SS#421
07/25/2016 11:45	0.44 NTU	<=1	User-Defined		8925 Hwy. 99 - S137
07/25/2016 13:00	0.31 NTU	<=1	User-Defined		3840 Sunridge Drive - P265 - SS#456
07/25/2016 13:30	0.23 NTU	<=1	User-Defined		4335 Main Street - Main St. - SS#450
07/26/2016 08:15	0.14 NTU	<=1	User-Defined		5438 Stonebridge drive - P275
08/02/2016	0.25 NTU	<=1	User-Defined		3333 Carleton Way - S104 - SS#459
08/02/2016 07:27	0.28 NTU	<=1	User-Defined		8407 Golden Bear Pl. - P266/S123 - SS#424
08/02/2016 07:47	0.10 NTU	<=1	User-Defined		8319 Mountianview Dr.- P245 - SS#412
08/02/2016 08:11	0.38 NTU	<=1	User-Defined		4700 Glacier Dr. - P256 - SS#441
08/02/2016 08:27	0.17 NTU	<=1	User-Defined		4297 Mountain Square - Mountain Ln - SS#453
08/02/2016 08:46	0.21 NTU	<=1	User-Defined		6295 Palmer Dr. - Snowflake Park - SS#430
08/02/2016 09:45	0.13 NTU	<=1	User-Defined		2400 Taluswood Pl. - P270 - SS#465
08/02/2016 10:22	0.11 NTU	<=1	User-Defined		1300 Mount Fee Rd
08/02/2016 10:52	0.14 NTU	<=1	User-Defined		1559 Spring Creek Rd - P273/S132 - SS#480
08/02/2016 11:09	0.09 NTU	<=1	User-Defined		1300 Block Alta Lake Rd - SS#482
08/09/2016 09:30	0.17 NTU	<=1	User-Defined		5438 Stonebridge drive - P275

Turbidity		Criteria	Detection Limit/MDL	Sampling Point Name
08/09/2016 12:30	0.15 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
08/09/2016 13:10	0.36 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
08/09/2016 13:45	0.42 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
08/10/2016 09:00	0.19 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
08/10/2016 09:30	0.20 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456
08/10/2016 11:25	0.23 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
08/10/2016 12:00	0.11 NTU	<=1	User-Defined	8330 Rainbow Dr.- S101 - SS#421
08/16/2016 10:10	0.16 NTU	<=1	User-Defined	1300 Mount Fee Rd
08/16/2016 10:50	0.11 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
08/16/2016 12:45	0.17 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465
08/16/2016 13:10	0.18 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459
08/16/2016 13:40	0.25 NTU	<=1	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
08/17/2016 08:00	0.08 NTU	<=1	User-Defined	1300 Block Alta Lake Rd - SS#482
08/17/2016 09:50	0.15 NTU	<=1	User-Defined	4700 Glacier Dr. - P256 - SS#441
08/17/2016 10:15	0.18 NTU	<=1	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
08/17/2016 11:45	0.35 NTU	<=1	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
08/17/2016 12:05	0.35 NTU	<=1	User-Defined	8319 Mountainview Dr.- P245 - SS#412
08/22/2016 10:45	0.13 NTU	<=1	User-Defined	5438 Stonebridge drive - P275
08/23/2016 01:30	0.05 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
08/23/2016 08:00	0.23 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
08/23/2016 08:45	0.11 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
08/23/2016 09:20	0.28 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456

Turbidity		Criteria	Detection Limit/MDL	Sampling Point Name
08/23/2016 09:50	0.16 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
08/23/2016 10:15	0.18 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
08/23/2016 12:20	0.57 NTU	<=1	User-Defined	8330 Rainbow Dr.- S101 - SS#421
08/30/2016 08:40	0.15 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465
08/30/2016 11:40	0.15 NTU	<=1	User-Defined	1300 Mount Fee Rd
08/30/2016 12:20	0.31 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
08/30/2016 12:45	0.11 NTU	<=1	User-Defined	1300 Block Alta Lake Rd - SS#482
08/30/2016 13:40	0.40 NTU	<=1	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
08/31/2016 10:15	0.10 NTU	<=1	User-Defined	8319 Mountainview Dr.- P245 - SS#412
08/31/2016 11:25	0.20 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459
08/31/2016 12:50	0.22 NTU	<=1	User-Defined	4700 Glacier Dr. - P256 - SS#441
08/31/2016 13:10	0.24 NTU	<=1	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
08/31/2016 13:30	0.26 NTU	<=1	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
09/06/2016 09:15	0.24 NTU	<=1	User-Defined	5438 Stonebridge drive - P275
09/06/2016 11:00	0.12 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
09/06/2016 12:00	0.13 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
09/06/2016 12:35	0.13 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456
09/06/2016 13:00	0.23 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
09/06/2016 13:40	0.29 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
09/07/2016 10:40	0.25 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
09/07/2016 10:55	0.41 NTU	<=1	User-Defined	8330 Rainbow Dr.- S101 - SS#421
09/13/2016 12:10	0.11 NTU	<=1	User-Defined	1300 Mount Fee Rd

Turbidity		Criteria	Detection Limit/MDL	Sampling Point Name
09/13/2016 12:45	0.10 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
09/14/2016 08:45	0.27 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465
09/14/2016 09:20	0.26 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459
09/14/2016 09:45	0.12 NTU	<=1	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
09/14/2016 10:15	0.22 NTU	<=1	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
09/14/2016 11:15	0.33 NTU	<=1	User-Defined	1300 Block Alta Lake Rd - SS#482
09/14/2016 12:05	0.35 NTU	<=1	User-Defined	4700 Glacier Dr. - P256 - SS#441
09/14/2016 12:30	0.23 NTU	<=1	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
09/14/2016 13:40	0.20 NTU	<=1	User-Defined	8319 Mountainview Dr.- P245 - SS#412
09/19/2016 10:10	0.19 NTU	<=1	User-Defined	8330 Rainbow Dr.- S101 - SS#421
09/19/2016 11:40	0.38 NTU	<=1	User-Defined	5438 Stonebridge drive - P275
09/19/2016 12:05	0.37 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
09/19/2016 13:20	0.33 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
09/19/2016 13:45	0.29 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
09/20/2016 08:15	0.27 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
09/20/2016 08:45	0.23 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
09/20/2016 11:15	0.24 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456
09/27/2016 10:30	0.24 NTU	<=1	User-Defined	1300 Mount Fee Rd
09/27/2016 10:50	0.14 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
09/27/2016 11:10	0.11 NTU	<=1	User-Defined	1300 Block Alta Lake Rd - SS#482
09/27/2016 11:50	0.24 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465

Turbidity	Criteria	Detection Limit/MDL	Sampling Point Name	
09/27/2016 12:15	0.28 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459
09/27/2016 12:40	0.17 NTU	<=1	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
09/28/2016 09:45	0.22 NTU	<=1	User-Defined	8319 Mountainview Dr.- P245 - SS#412
09/28/2016 10:55	0.17 NTU	<=1	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
09/28/2016 13:15	0.23 NTU	<=1	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
10/04/2016 09:30	0.20 NTU	<=1	User-Defined	5438 Stonebridge drive - P275
10/04/2016 11:40	0.19 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
10/04/2016 12:30	0.33 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
10/04/2016 13:00	0.15 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456
10/04/2016 13:40	0.25 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
10/05/2016 08:00	0.15 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
10/05/2016 09:15	0.27 NTU	<=1	User-Defined	8330 Rainbow Dr.- S101 - SS#421
10/05/2016 10:35	0.16 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
10/11/2016 01:20	0.27 NTU	<=1	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
* 10/11/2016 08:20	1.07 NTU	<=1	User-Defined	1300 Mount Fee Rd
10/11/2016 09:10	0.33 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
* 10/11/2016 09:40	2.40 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465
10/11/2016 10:05	0.19 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459
10/11/2016 10:40	0.36 NTU	<=1	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
10/11/2016 11:05	0.33 NTU	<=1	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424

Turbidity		Criteria	Detection Limit/MDL	Sampling Point Name
10/11/2016 11:20	0.21 NTU	<=1	User-Defined	8319 Mountianview Dr.- P245 - SS#412
10/11/2016 12:20	0.79 NTU	<=1	User-Defined	4700 Glacier Dr. - P256 - SS#441
10/11/2016 12:40	0.21 NTU	<=1	User-Defined	1300 Block Alta Lake Rd - SS#482
10/18/2016 08:30	0.24 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
10/18/2016 09:00	0.22 NTU	<=1	User-Defined	5438 Stonebridge drive - P275
10/18/2016 10:30	0.13 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
10/18/2016 11:10	0.12 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456
10/18/2016 11:40	0.11 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
10/19/2016 08:25	0.09 NTU	<=1	User-Defined	8330 Rainbow Dr.- S101 - SS#421
10/19/2016 09:20	0.13 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
10/19/2016 09:45	0.11 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
10/24/2016 07:35	0.17 NTU	<=1	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
10/24/2016 08:06	0.13 NTU	<=1	User-Defined	8319 Mountianview Dr.- P245 - SS#412
10/24/2016 08:31	0.29 NTU	<=1	User-Defined	1300 Block Alta Lake Rd - SS#482
10/24/2016 09:09	0.11 NTU	<=1	User-Defined	1300 Mount Fee Rd
10/24/2016 09:39	0.31 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
10/24/2016 10:10	0.16 NTU	<=1	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
10/24/2016 10:10	0.24 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465
10/24/2016 10:15	0.29 NTU	<=1	User-Defined	4700 Glacier Dr. - P256 - SS#441
10/24/2016 10:32	0.21 NTU	<=1	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
10/24/2016 11:32	0.14 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459

Turbidity		Criteria	Detection Limit/MDL	Sampling Point Name
10/31/2016 12:30	0.12 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
10/31/2016 13:40	0.36 NTU	<=1	User-Defined	5438 Stonebridge drive - P275
11/01/2016 09:45	0.18 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
11/01/2016 10:50	0.21 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
11/01/2016 11:20	0.22 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456
11/01/2016 12:15	0.10 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
11/01/2016 12:50	0.15 NTU	<=1	User-Defined	8330 Rainbow Dr.- S101 - SS#421
11/02/2016 08:50	0.10 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
11/08/2016 10:30	0.18 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465
11/08/2016 12:00	0.08 NTU	<=1	User-Defined	1300 Mount Fee Rd
11/08/2016 12:25	0.13 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
11/08/2016 13:30	0.18 NTU	<=1	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
11/09/2016 08:30	0.23 NTU	<=1	User-Defined	1300 Block Alta Lake Rd - SS#482
11/09/2016 10:30	0.16 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459
11/09/2016 11:00	0.15 NTU	<=1	User-Defined	4700 Glacier Dr. - P256 - SS#441
11/09/2016 11:40	0.21 NTU	<=1	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
11/09/2016 12:00	0.10 NTU	<=1	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
11/09/2016 12:25	0.22 NTU	<=1	User-Defined	8319 Mountainview Dr.- P245 - SS#412
11/15/2016 10:00	0.35 NTU	<=1	User-Defined	5438 Stonebridge drive - P275
11/15/2016 11:15	0.37 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
11/15/2016 11:45	0.36 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471

Turbidity		Criteria	Detection Limit/MDL	Sampling Point Name
11/15/2016 12:00	0.17 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456
11/15/2016 12:30	0.09 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
11/15/2016 12:50	0.15 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
11/16/2016 09:00	0.17 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
11/16/2016 11:10	0.13 NTU	<=1	User-Defined	8330 Rainbow Dr.- S101 - SS#421
11/17/2016 13:00	< 0.10 NTU	<=1	User-Defined	2601 Gondola Way - R228 - SS#474
11/22/2016 09:45	0.11 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465
11/22/2016 12:15	0.10 NTU	<=1	User-Defined	1300 Mount Fee Rd
11/22/2016 12:35	0.09 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
11/22/2016 13:00	0.13 NTU	<=1	User-Defined	1300 Block Alta Lake Rd - SS#482
11/23/2016 09:20	0.16 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459
11/23/2016 09:50	0.15 NTU	<=1	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
11/23/2016 10:10	0.25 NTU	<=1	User-Defined	4700 Glacier Dr. - P256 - SS#441
11/23/2016 10:50	0.34 NTU	<=1	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
11/23/2016 11:10	0.09 NTU	<=1	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
11/23/2016 12:40	0.08 NTU	<=1	User-Defined	8319 Mountainview Dr.- P245 - SS#412
11/28/2016 11:10	0.15 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
11/28/2016 11:35	0.11 NTU	<=1	User-Defined	8330 Rainbow Dr.- S101 - SS#421
11/29/2016 08:55	0.96 NTU	<=1	User-Defined	5438 Stonebridge drive - P275
11/29/2016 10:00	0.34 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
11/29/2016 11:00	0.42 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
11/29/2016 11:15	0.16 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477

Turbidity		Criteria	Detection Limit/MDL	Sampling Point Name
11/29/2016 11:40	0.22 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456
11/30/2016 08:15	0.31 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
12/05/2016 10:15	0.16 NTU	<=1	User-Defined	8407 Golden Bear Pl. - P266/S123 - SS#424
12/05/2016 11:00	0.24 NTU	<=1	User-Defined	6295 Palmer Dr. - Snowflake Park - SS#430
12/05/2016 11:30	0.17 NTU	<=1	User-Defined	3333 Carleton Way - S104 - SS#459
12/05/2016 11:45	0.20 NTU	<=1	User-Defined	4297 Mountain Square - Mountain Ln - SS#453
12/06/2016 09:20	0.18 NTU	<=1	User-Defined	8319 Mountainview Dr.- P245 - SS#412
12/06/2016 09:50	0.12 NTU	<=1	User-Defined	1559 Spring Creek Rd - P273/S132 - SS#480
12/06/2016 10:10	0.16 NTU	<=1	User-Defined	1300 Mount Fee Rd
12/06/2016 10:30	0.17 NTU	<=1	User-Defined	1300 Block Alta Lake Rd - SS#482
12/06/2016 11:45	0.26 NTU	<=1	User-Defined	4700 Glacier Dr. - P256 - SS#441
12/06/2016 12:20	0.20 NTU	<=1	User-Defined	2400 Taluswood Pl. - P270 - SS#465
12/13/2016 09:25	0.14 NTU	<=1	User-Defined	7314 Blackcomb Way - P267/S126 - SS#427
12/13/2016 09:50	0.23 NTU	<=1	User-Defined	8330 Rainbow Dr.- S101 - SS#421
12/13/2016 10:20	0.41 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
12/13/2016 11:15	0.23 NTU	<=1	User-Defined	2149 Lake Placid Rd - S106 - SS#471
12/13/2016 11:40	0.13 NTU	<=1	User-Defined	2773 Cheakamus Way - S121- SS#477
12/13/2016 12:00	0.21 NTU	<=1	User-Defined	5438 Stonebridge drive - P275
12/14/2016 08:35	0.23 NTU	<=1	User-Defined	3840 Sunridge Drive - P265 - SS#456
12/14/2016 08:55	0.19 NTU	<=1	User-Defined	4335 Main Street - Main St. - SS#450
12/14/2016 10:50	0.23 NTU	<=1	User-Defined	8925 Hwy. 99 - S137
12/20/2016 11:35	0.09 NTU	<=1	User-Defined	1300 Mount Fee Rd



Turbidity		Criteria		Detection Limit/MDL	Sampling Point Name
12/20/2016 12:25	0.09 NTU	<=1	User-Defined		1559 Spring Creek Rd - P273/S132 - SS#480
12/20/2016 13:10	0.09 NTU	<=1	User-Defined		2400 Taluswood Pl. - P270 - SS#465
12/20/2016 13:35	0.22 NTU	<=1	User-Defined		1300 Block Alta Lake Rd - SS#482
# samples:	430	min:	0.05 NTU		
# detects:	429	max:	2.40 NTU		
# non-detects:	1	avg:	0.257 NTU (based on 429 numerical results)		
# of Exceedences:	3	95th percentile:	0.565 NTU		

Uranium (total)		Criteria		Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	< 0.00002 mg/L	<=0.02	MAC	0.00002	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	< 0.00002 mg/L	<=0.02	MAC	0.00002	8925 Hwy. 99 - S137
# samples:	2	min:	< 0.00002 mg/L		
# detects:	0	max:	< 0.00002 mg/L		
# non-detects:	2	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Zinc (total)		Criteria		Detection Limit/MDL	Sampling Point Name
11/17/2016 13:00	< 0.004 mg/L	<=5	AO	0.004	2601 Gondola Way - R228 - SS#474
12/14/2016 10:50	0.009 mg/L	<=5	AO	0.004	8925 Hwy. 99 - S137
# samples:	2	min:	< 0.004 mg/L		
# detects:	1	max:	0.009 mg/L		
# non-detects:	1	avg:	0.009 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, U=non-detect, OR=over-range, OG=overgrown, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment
 < means less than lower detection limit shown
 > means greater than upper detection limit shown
 « means detected & less than number shown
 » means detected & greater than number shown



* Indicates Criteria is exceeded

Turbidity		Criteria		Sampling Point Name	Detection Limit/MDL
01/05/2016 11:00	0.05 NTU	<=1	User-Defined	W217	
* 01/05/2016 11:30	3.43 NTU	<=1	User-Defined	W-212 SS#483	
01/12/2016 11:30	0.11 NTU	<=1	User-Defined	W218	
01/13/2016 08:50	0.07 NTU	<=1	User-Defined	W-202	
01/13/2016 10:50	0.08 NTU	<=1	User-Defined	W-210	
01/13/2016 11:10	0.16 NTU	<=1	User-Defined	W-213 SS#420	
01/13/2016 12:50	0.18 NTU	<=1	User-Defined	W205-1 SS#444	
01/19/2016 10:45	0.05 NTU	<=1	User-Defined	W217	
01/19/2016 13:15	0.79 NTU	<=1	User-Defined	W-212 SS#483	
01/20/2016 10:15	0.156 NTU	<=1	User-Defined	R-231/SS#436	
01/25/2016 12:00	0.06 NTU	<=1	User-Defined	W218	
01/27/2016 08:10	0.09 NTU	<=1	User-Defined	W-213 SS#420	
01/27/2016 08:40	0.07 NTU	<=1	User-Defined	W-210	
01/27/2016 13:00	0.06 NTU	<=1	User-Defined	W205-3 SS#446	
01/27/2016 13:20	0.06 NTU	<=1	User-Defined	W211 SS#447	
01/27/2016 13:40	0.05 NTU	<=1	User-Defined	W205-1 SS#444	
02/02/2016 08:24	0.89 NTU	<=1	User-Defined	R-232/ SS#439	
02/02/2016 10:16	0.260 NTU	<=1	User-Defined	R-231/SS#436	
02/02/2016 11:15	0.06 NTU	<=1	User-Defined	W217	
02/02/2016 12:40	0.07 NTU	<=1	User-Defined	W-212 SS#483	
02/09/2016 11:45	0.05 NTU	<=1	User-Defined	W218	
02/10/2016 09:30	0.19 NTU	<=1	User-Defined	W-210	
02/10/2016 12:55	0.09 NTU	<=1	User-Defined	W205-1 SS#444	
02/10/2016 13:10	0.12 NTU	<=1	User-Defined	W205-2 SS#445	
02/10/2016 13:30	0.06 NTU	<=1	User-Defined	W205-3 SS#446	
02/10/2016 13:50	0.05 NTU	<=1	User-Defined	W211 SS#447	
02/16/2016 09:15	0.08 NTU	<=1	User-Defined	W-212 SS#483	
02/16/2016 10:00	0.06 NTU	<=1	User-Defined	W217	
02/17/2016 10:10	0.560 NTU	<=1	User-Defined	R-231/SS#436	
02/17/2016 11:20	0.49 NTU	<=1	User-Defined	R-232/ SS#439	
02/23/2016 09:20	0.05 NTU	<=1	User-Defined	W218	
02/24/2016 10:55	0.19 NTU	<=1	User-Defined	W-210	
02/24/2016 11:05	0.5 NTU	<=1	User-Defined	W-213 SS#420	
02/24/2016 11:30	0.05 NTU	<=1	User-Defined	W205-1 SS#444	
02/24/2016 11:40	0.08 NTU	<=1	User-Defined	W205-3 SS#446	
02/24/2016 11:50	0.07 NTU	<=1	User-Defined	W211 SS#447	
03/01/2016 08:55	0.32 NTU	<=1	User-Defined	R-231/SS#436	

Turbidity		Criteria		Sampling Point Name	Detection Limit/MDL
03/01/2016 09:30	0.05 NTU	<=1	User-Defined	W217	
03/01/2016 10:40	0.96 NTU	<=1	User-Defined	R-232/ SS#439	
03/01/2016 11:15	0.06 NTU	<=1	User-Defined	W-212 SS#483	
03/08/2016 09:40	0.04 NTU	<=1	User-Defined	W218	
03/09/2016 10:30	0.57 NTU	<=1	User-Defined	W-210	
03/09/2016 12:00	0.09 NTU	<=1	User-Defined	W-213 SS#420	
03/09/2016 12:55	0.08 NTU	<=1	User-Defined	W205-1 SS#444	
03/09/2016 13:10	0.11 NTU	<=1	User-Defined	W205-3 SS#446	
03/09/2016 13:35	0.05 NTU	<=1	User-Defined	W211 SS#447	
03/22/2016 10:05	0.08 NTU	<=1	User-Defined	W218	
03/22/2016 11:30	0.10 NTU	<=1	User-Defined	W-210	
03/22/2016 11:50	0.08 NTU	<=1	User-Defined	W-213 SS#420	
03/23/2016 08:30	0.10 NTU	<=1	User-Defined	W205-1 SS#444	
03/23/2016 08:40	0.08 NTU	<=1	User-Defined	W205-2 SS#445	
03/23/2016 09:00	0.11 NTU	<=1	User-Defined	W205-3 SS#446	
03/29/2016 09:20	0.09 NTU	<=1	User-Defined	W217	
03/30/2016 08:25	0.233 NTU	<=1	User-Defined	R-231/SS#436	
03/30/2016 13:45	0.09 NTU	<=1	User-Defined	W-212 SS#483	
04/05/2016 08:50	0.05 NTU	<=1	User-Defined	W218	
04/05/2016 09:45	0.08 NTU	<=1	User-Defined	W-202	
04/05/2016 11:00	0.05 NTU	<=1	User-Defined	W-213 SS#420	
04/05/2016 12:35	0.07 NTU	<=1	User-Defined	W205-1 SS#444	
04/05/2016 12:55	0.06 NTU	<=1	User-Defined	W205-2 SS#445	
04/05/2016 13:10	0.16 NTU	<=1	User-Defined	W205-3 SS#446	
04/12/2016 12:30	0.06 NTU	<=1	User-Defined	W-212 SS#483	
04/12/2016 13:15	0.18 NTU	<=1	User-Defined	W217	
04/13/2016 12:45	0.57 NTU	<=1	User-Defined	R-232/ SS#439	
04/20/2016 10:00	0.15 NTU	<=1	User-Defined	W-202	
04/20/2016 10:20	0.10 NTU	<=1	User-Defined	W-213 SS#420	
04/20/2016 10:30	0.08 NTU	<=1	User-Defined	W218	
04/20/2016 13:05	0.08 NTU	<=1	User-Defined	W205-1 SS#444	
04/20/2016 13:15	0.22 NTU	<=1	User-Defined	W205-2 SS#445	
04/20/2016 13:25	0.27 NTU	<=1	User-Defined	W205-3 SS#446	
04/20/2016 13:30	0.64 NTU	<=1	User-Defined	W211 SS#447	
04/26/2016 09:00	0.29 NTU	<=1	User-Defined	R-231/SS#436	
04/26/2016 11:45	0.1 NTU	<=1	User-Defined	W-212 SS#483	
04/27/2016 10:00	0.08 NTU	<=1	User-Defined	W217	
05/10/2016 10:35	0.06 NTU	<=1	User-Defined	W-212 SS#483	
05/10/2016 11:35	0.763 NTU	<=1	User-Defined	R-231/SS#436	

Turbidity		Criteria		Sampling Point Name	Detection Limit/MDL
05/11/2016 08:30	0.05 NTU	<=1	User-Defined	W217	
* 05/11/2016	1.52 NTU	<=1	User-Defined	R-232/ SS#439	
09:30					
05/16/2016 13:00	0.18 NTU	<=1	User-Defined	W218	
05/17/2016 10:00	0.05 NTU	<=1	User-Defined	W-213 SS#420	
05/17/2016 10:20	0.05 NTU	<=1	User-Defined	W-202	
05/18/2016 09:30	0.11 NTU	<=1	User-Defined	W211 SS#447	
05/18/2016 09:40	0.16 NTU	<=1	User-Defined	W205-3 SS#446	
05/18/2016 09:50	0.12 NTU	<=1	User-Defined	W205-2 SS#445	
05/18/2016 10:05	0.10 NTU	<=1	User-Defined	W205-1 SS#444	
05/24/2016 11:25	0.10 NTU	<=1	User-Defined	W217	
* 05/25/2016	2.09 NTU	<=1	User-Defined	R-232/ SS#439	
10:50					
05/25/2016 12:00	0.09 NTU	<=1	User-Defined	W-212 SS#483	
05/25/2016 12:30	0.425 NTU	<=1	User-Defined	R-231/SS#436	
05/31/2016 09:58	0.16 NTU	<=1	User-Defined	W-213 SS#420	
05/31/2016 10:12	0.11 NTU	<=1	User-Defined	W-202	
05/31/2016 10:52	0.12 NTU	<=1	User-Defined	W218	
06/01/2016 12:10	0.16 NTU	<=1	User-Defined	W205-1 SS#444	
06/01/2016 12:20	0.09 NTU	<=1	User-Defined	W205-2 SS#445	
06/01/2016 12:35	0.14 NTU	<=1	User-Defined	W205-3 SS#446	
06/01/2016 12:40	0.13 NTU	<=1	User-Defined	W211 SS#447	
06/06/2016 10:30	0.68 NTU	<=1	User-Defined	R-231/SS#436	
06/06/2016 10:43	0.21 NTU	<=1	User-Defined	W-212 SS#483	
06/06/2016 10:59	0.12 NTU	<=1	User-Defined	W217	
06/13/2016 12:00	0.07 NTU	<=1	User-Defined	W218	
06/14/2016 12:20	0.16 NTU	<=1	User-Defined	W-202	
06/14/2016 13:20	0.17 NTU	<=1	User-Defined	W-213 SS#420	
06/15/2016 08:45	0.08 NTU	<=1	User-Defined	W205-1 SS#444	
06/15/2016 08:55	0.11 NTU	<=1	User-Defined	W205-2 SS#445	
06/15/2016 09:10	0.06 NTU	<=1	User-Defined	W205-3 SS#446	
06/15/2016 09:30	0.08 NTU	<=1	User-Defined	W211 SS#447	
06/20/2016 09:02	0.26 NTU	<=1	User-Defined	W-212 SS#483	
06/20/2016 09:18	0.09 NTU	<=1	User-Defined	W217	
06/20/2016 10:39	0.21 NTU	<=1	User-Defined	R-231/SS#436	
* 06/20/2016	4.69 NTU	<=1	User-Defined	R-232/ SS#439	
11:16					
06/28/2016 12:02	0.19 NTU	<=1	User-Defined	W-202	
06/29/2016 09:00	0.16 NTU	<=1	User-Defined	W218	

Turbidity		Criteria		Sampling Point Name	Detection Limit/MDL
06/29/2016 10:45	0.20 NTU	<=1	User-Defined	W-210	
06/29/2016 11:20	0.05 NTU	<=1	User-Defined	W-213 SS#420	
06/29/2016 11:50	0.04 NTU	<=1	User-Defined	W205-1 SS#444	
06/29/2016 12:00	0.07 NTU	<=1	User-Defined	W205-2 SS#445	
06/29/2016 12:10	0.10 NTU	<=1	User-Defined	W205-3 SS#446	
06/29/2016 12:20	0.09 NTU	<=1	User-Defined	W211 SS#447	
* 07/05/2016	3.56 NTU	<=1	User-Defined	R-232/ SS#439	
09:00					
07/05/2016 10:00	0.42 NTU	<=1	User-Defined	R-231/SS#436	
07/05/2016 11:30	0.10 NTU	<=1	User-Defined	W-212 SS#483	
07/05/2016 11:53	0.21 NTU	<=1	User-Defined	W217	
07/12/2016 09:15	0.10 NTU	<=1	User-Defined	W218	
07/12/2016 12:15	0.13 NTU	<=1	User-Defined	W-210	
07/13/2016 09:00	0.17 NTU	<=1	User-Defined	W-213 SS#420	
07/13/2016 10:20	0.06 NTU	<=1	User-Defined	W-202	
07/13/2016 11:15	0.13 NTU	<=1	User-Defined	W205-1 SS#444	
07/13/2016 11:30	0.05 NTU	<=1	User-Defined	W205-2 SS#445	
07/13/2016 12:00	0.19 NTU	<=1	User-Defined	W205-3 SS#446	
07/13/2016 12:15	0.09 NTU	<=1	User-Defined	W211 SS#447	
07/25/2016 10:30	0.13 NTU	<=1	User-Defined	W205-1 SS#444	
07/25/2016 10:45	0.07 NTU	<=1	User-Defined	W205-2 SS#445	
07/25/2016 11:00	0.12 NTU	<=1	User-Defined	W205-3 SS#446	
07/25/2016 11:15	0.88 NTU	<=1	User-Defined	W211 SS#447	
07/26/2016 08:45	0.11 NTU	<=1	User-Defined	W218	
07/26/2016 09:05	0.09 NTU	<=1	User-Defined	W-202	
07/26/2016 10:30	0.10 NTU	<=1	User-Defined	W-210	
07/26/2016 11:00	0.21 NTU	<=1	User-Defined	W-213 SS#420	
08/02/2016 07:32	0.15 NTU	<=1	User-Defined	W-212 SS#483	
08/02/2016 10:38	0.07 NTU	<=1	User-Defined	W217	
08/02/2016 11:45	0.15 NTU	<=1	User-Defined	R-231/SS#436	
* 08/02/2016	3.31 NTU	<=1	User-Defined	R-232/ SS#439	
12:13					
08/09/2016 11:30	0.05 NTU	<=1	User-Defined	W218	
08/10/2016 12:15	0.16 NTU	<=1	User-Defined	W-210	
08/10/2016 12:30	0.13 NTU	<=1	User-Defined	W-202	
08/10/2016 12:55	0.17 NTU	<=1	User-Defined	W-213 SS#420	
08/10/2016 13:20	0.11 NTU	<=1	User-Defined	W205-1 SS#444	
08/10/2016 13:35	0.26 NTU	<=1	User-Defined	W205-2 SS#445	
08/10/2016 13:45	0.14 NTU	<=1	User-Defined	W205-3 SS#446	

Turbidity		Criteria		Sampling Point Name	Detection Limit/MDL
08/10/2016 13:55	0.99 NTU	<=1	User-Defined	W211 SS#447	
08/16/2016 09:10	0.06 NTU	<=1	User-Defined	W217	
08/16/2016 11:30	0.156 NTU	<=1	User-Defined	R-231/SS#436	
* 08/17/2016	4.51 NTU	<=1	User-Defined	R-232/ SS#439	
09:00					
08/17/2016 11:05	0.19 NTU	<=1	User-Defined	W-212 SS#483	
08/22/2016	0.07 NTU	<=1	User-Defined	W218	
08/23/2016 11:10	0.05 NTU	<=1	User-Defined	W-210	
08/23/2016 12:45	0.16 NTU	<=1	User-Defined	W-202	
08/23/2016 13:20	0.11 NTU	<=1	User-Defined	W-213 SS#420	
08/24/2016 08:15	0.04 NTU	<=1	User-Defined	W205-1 SS#444	
08/24/2016 08:30	0.05 NTU	<=1	User-Defined	W205-2 SS#445	
08/24/2016 08:45	0.05 NTU	<=1	User-Defined	W205-3 SS#446	
08/24/2016 08:45	0.05 NTU	<=1	User-Defined	W211 SS#447	
08/30/2016 09:30	0.07 NTU	<=1	User-Defined	W217	
08/30/2016 11:00	0.21 NTU	<=1	User-Defined	W-212 SS#483	
08/31/2016 08:00	0.190 NTU	<=1	User-Defined	R-231/SS#436	
08/31/2016 12:30	0.414 NTU	<=1	User-Defined	R-232/ SS#439	
09/06/2016 09:45	0.11 NTU	<=1	User-Defined	W218	
09/07/2016 08:45	0.19 NTU	<=1	User-Defined	W211 SS#447	
09/07/2016 08:55	0.15 NTU	<=1	User-Defined	W205-3 SS#446	
09/07/2016 09:07	0.13 NTU	<=1	User-Defined	W205-2 SS#445	
09/07/2016 09:15	0.13 NTU	<=1	User-Defined	W205-1 SS#444	
09/07/2016 09:40	0.38 NTU	<=1	User-Defined	W-202	
09/07/2016 09:50	0.30 NTU	<=1	User-Defined	W-210	
09/07/2016 11:10	0.17 NTU	<=1	User-Defined	W-213 SS#420	
09/13/2016 10:45	0.07 NTU	<=1	User-Defined	W217	
09/13/2016 13:35	0.15 NTU	<=1	User-Defined	W-212 SS#483	
09/14/2016 10:45	0.16 NTU	<=1	User-Defined	R-231/SS#436	
* 09/14/2016	1.65 NTU	<=1	User-Defined	R-232/ SS#439	
11:50					
09/19/2016 09:00	0.07 NTU	<=1	User-Defined	W218	
09/19/2016 09:45	0.09 NTU	<=1	User-Defined	W-202	
09/19/2016 10:30	0.29 NTU	<=1	User-Defined	W-210	
09/20/2016 11:45	0.18 NTU	<=1	User-Defined	W205-2 SS#445	
09/20/2016 12:00	0.19 NTU	<=1	User-Defined	W205-3 SS#446	
09/20/2016 12:15	0.20 NTU	<=1	User-Defined	W205-1 SS#444	
09/20/2016 12:30	0.18 NTU	<=1	User-Defined	W211 SS#447	
09/21/2016 11:45	0.31 NTU	<=1	User-Defined	W-213 SS#420	

Turbidity		Criteria		Sampling Point Name	Detection Limit/MDL
09/27/2016 08:25	0.17 NTU	<=1	User-Defined	W-212 SS#483	
09/27/2016 09:30	0.05 NTU	<=1	User-Defined	W217	
* 09/27/2016	4.65 NTU	<=1	User-Defined	R-232/ SS#439	
13:30					
09/28/2016 10:30	0.150 NTU	<=1	User-Defined	R-231/SS#436	
10/05/2016 08:45	0.19 NTU	<=1	User-Defined	W-210	
10/05/2016 09:00	0.21 NTU	<=1	User-Defined	W218	
10/05/2016 11:00	0.07 NTU	<=1	User-Defined	W-202	
* 10/05/2016	1.84 NTU	<=1	User-Defined	W-213 SS#420	
11:50					
10/05/2016 12:30	0.18 NTU	<=1	User-Defined	W205-1 SS#444	
10/05/2016 12:40	0.12 NTU	<=1	User-Defined	W205-2 SS#445	
10/05/2016 13:00	0.08 NTU	<=1	User-Defined	W211 SS#447	
10/11/2016 08:45	0.64 NTU	<=1	User-Defined	W217	
10/11/2016 11:45	0.84 NTU	<=1	User-Defined	R-232/ SS#439	
10/11/2016 12:50	0.20 NTU	<=1	User-Defined	W-212 SS#483	
10/12/2016 11:20	0.23 NTU	<=1	User-Defined	R-231/SS#436	
10/18/2016 09:45	0.08 NTU	<=1	User-Defined	W218	
10/19/2016 10:30	0.13 NTU	<=1	User-Defined	W205-1 SS#444	
10/19/2016 10:45	0.07 NTU	<=1	User-Defined	W205-2 SS#445	
10/19/2016 11:00	0.09 NTU	<=1	User-Defined	W205-3 SS#446	
10/19/2016 11:15	0.06 NTU	<=1	User-Defined	W211 SS#447	
10/19/2016 11:50	0.13 NTU	<=1	User-Defined	W-210	
10/19/2016 12:00	0.26 NTU	<=1	User-Defined	W-202	
10/19/2016 13:00	0.73 NTU	<=1	User-Defined	W-213 SS#420	
10/24/2016 08:52	0.32 NTU	<=1	User-Defined	W-212 SS#483	
10/24/2016 09:23	0.08 NTU	<=1	User-Defined	W217	
10/25/2016 08:32	0.99 NTU	<=1	User-Defined	R-232/ SS#439	
10/25/2016 09:45	0.79 NTU	<=1	User-Defined	R-231/SS#436	
11/01/2016 08:30	0.06 NTU	<=1	User-Defined	W218	
11/02/2016 08:30	0.22 NTU	<=1	User-Defined	W-202	
11/02/2016 10:30	0.25 NTU	<=1	User-Defined	W-210	
11/02/2016 11:20	0.10 NTU	<=1	User-Defined	W-213 SS#420	
11/02/2016 12:25	0.09 NTU	<=1	User-Defined	W205-1 SS#444	
11/02/2016 12:30	0.09 NTU	<=1	User-Defined	W205-2 SS#445	
11/02/2016 12:40	0.13 NTU	<=1	User-Defined	W205-3 SS#446	
11/02/2016 12:45	0.11 NTU	<=1	User-Defined	W211 SS#447	
* 11/08/2016	1.64 NTU	<=1	User-Defined	W-212 SS#483	0.10
11:00					

Turbidity		Criteria		Sampling Point Name	Detection Limit/MDL
11/08/2016 11:00	0.10 NTU	<=1	User-Defined	W-212 SS#483	
11/08/2016 11:30	< 0.10 NTU	<=1	User-Defined	W217	0.10
* 11/09/2016	9.99 NTU	<=1	User-Defined	R-231/SS#436	
09:30					
11/09/2016 11:30	0.08 NTU	<=1	User-Defined	W217	
11/15/2016 10:30	0.05 NTU	<=1	User-Defined	W218	
11/15/2016 13:15	0.07 NTU	<=1	User-Defined	W205-1 SS#444	
11/15/2016 13:20	0.10 NTU	<=1	User-Defined	W205-2 SS#445	
11/15/2016 13:30	0.07 NTU	<=1	User-Defined	W205-3 SS#446	
11/15/2016 13:40	0.06 NTU	<=1	User-Defined	W211 SS#447	
11/16/2016 08:30	0.15 NTU	<=1	User-Defined	W-202	
11/16/2016 11:30	0.78 NTU	<=1	User-Defined	W-210	
11/16/2016 12:15	0.16 NTU	<=1	User-Defined	W-213 SS#420	
11/18/2016 09:20	0.34 NTU	<=1	User-Defined	W218	0.10
11/22/2016 10:30	0.08 NTU	<=1	User-Defined	W-212 SS#483	
11/22/2016 11:15	0.05 NTU	<=1	User-Defined	W217	
11/22/2016 13:45	0.40 NTU	<=1	User-Defined	R-232/ SS#439	0.10
11/22/2016 13:45	0.72 NTU	<=1	User-Defined	R-232/ SS#439	
11/23/2016 12:00	0.27 NTU	<=1	User-Defined	R-231/SS#436	
11/23/2016 12:00	0.20 NTU	<=1	User-Defined	R-231/SS#436	0.10
11/28/2016 13:20	0.67 NTU	<=1	User-Defined	W-210	
11/29/2016 08:30	0.05 NTU	<=1	User-Defined	W218	
11/29/2016 13:15	0.16 NTU	<=1	User-Defined	W-213 SS#420	
11/29/2016 13:35	0.17 NTU	<=1	User-Defined	W-202	
11/30/2016 08:55	0.12 NTU	<=1	User-Defined	W205-1 SS#444	
11/30/2016 09:05	0.11 NTU	<=1	User-Defined	W205-2 SS#445	
11/30/2016 09:10	0.12 NTU	<=1	User-Defined	W205-3 SS#446	
11/30/2016 09:25	0.12 NTU	<=1	User-Defined	W211 SS#447	
12/05/2016 08:45	0.19 NTU	<=1	User-Defined	W-212 SS#483	
12/05/2016 09:10	0.16 NTU	<=1	User-Defined	W217	
12/06/2016 09:25	0.31 NTU	<=1	User-Defined	R-231/SS#436	
12/07/2016 12:45	0.21 NTU	<=1	User-Defined	W212-2	0.10
12/08/2016 09:45	< 0.10 NTU	<=1	User-Defined	W-202	0.10
12/08/2016 10:20	0.83 NTU	<=1	User-Defined	W-213 SS#420	0.10
12/08/2016 10:50	0.22 NTU	<=1	User-Defined	W-210	0.10
12/08/2016 13:45	< 0.10 NTU	<=1	User-Defined	W205-2 SS#445	0.10
12/13/2016 10:05	0.19 NTU	<=1	User-Defined	W-213 SS#420	
12/13/2016 10:45	0.14 NTU	<=1	User-Defined	W218	
12/13/2016 12:30	0.23 NTU	<=1	User-Defined	W-202	

Turbidity		Criteria		Sampling Point Name	Detection Limit/MDL
12/13/2016 13:00	0.86 NTU	<=1	User-Defined	W-210	
12/14/2016 11:55	< 0.10 NTU	<=1	User-Defined	W205-3 SS#446	0.10
12/14/2016 12:00	0.11 NTU	<=1	User-Defined	W205-3 SS#446	
12/14/2016 12:15	< 0.10 NTU	<=1	User-Defined	W205-2 SS#445	0.10
12/14/2016 12:25	0.09 NTU	<=1	User-Defined	W205-2 SS#445	
12/14/2016 12:30	< 0.10 NTU	<=1	User-Defined	W211 SS#447	0.10
12/14/2016 12:40	0.10 NTU	<=1	User-Defined	W211 SS#447	
12/20/2016 10:15	0.08 NTU	<=1	User-Defined	W-212 SS#483	
12/20/2016 11:00	0.07 NTU	<=1	User-Defined	W217	

# samples:	269	min:	0.04 NTU
# detects:	263	max:	9.99 NTU
# non-detects:	6	avg:	0.341 NTU (based on 263 numerical results)
# of Exceedences:	12	95th percentile:	0.990 NTU

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, U=non-detect, OR=over-range, OG=overgrown, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

* Indicates Criteria is exceeded



Escherichia coli / E. coli (counts)		Criteria		Detection Limit/MDL	Sampling Point Name
01/13/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
01/13/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
01/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
01/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
02/10/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
02/10/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
02/24/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
02/24/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
03/09/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
03/09/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
03/22/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
03/22/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
04/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
04/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
05/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
05/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
05/17/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
05/17/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
05/31/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
05/31/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403

Escherichia coli / E. coli (counts)		Criteria		Detection Limit/MDL	Sampling Point Name
06/14/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
06/14/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
06/28/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
06/28/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
07/12/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
07/12/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
07/26/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
07/26/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
08/10/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
08/10/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
08/22/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
08/22/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
09/07/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
09/07/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
09/20/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
09/20/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
10/05/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
10/05/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
10/18/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
10/18/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
11/01/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406

Escherichia coli / E. coli (counts)		Criteria		Detection Limit/MDL	Sampling Point Name
11/01/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
11/16/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
11/16/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
11/29/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
11/29/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
12/14/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
12/14/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
# samples:	48	min:	< 1 counts/100mL		
# detects:	0	max:	< 1 counts/100mL		
# non-detects:	48	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Total Coliforms (counts)		Criteria		Detection Limit/MDL	Sampling Point Name
01/13/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
01/13/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
01/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
01/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
02/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
02/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
02/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
02/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
03/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
03/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406

Total Coliforms (counts)		Criteria		Detection Limit/MDL	Sampling Point Name
03/22/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
03/22/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
04/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
04/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
05/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
05/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
05/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
05/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
05/31/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
05/31/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
06/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
06/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
06/28/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
06/28/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
07/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
07/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
07/26/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
07/26/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
08/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
08/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
08/22/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406

Total Coliforms (counts)		Criteria		Detection Limit/MDL	Sampling Point Name
08/22/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
09/07/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
09/07/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
09/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
09/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
10/05/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
10/05/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
10/18/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
10/18/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
11/01/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
11/01/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
11/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
11/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
11/29/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406
11/29/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
12/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9225 Lakeshore Drive - S131 - SS#403
12/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	1	9525 Emerald Drive - R238 - SS#406

# samples:	48	min:	< 1 counts/100mL
# detects:	0	max:	< 1 counts/100mL
# non-detects:	48	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, U=non-detect, OR=over-range, OG=overgrown,



TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

< means less than lower detection limit shown

> means greater than upper detection limit shown

« means detected & less than number shown

» means detected & greater than number shown

* **Indicates Criteria is exceeded**

Alkalinity (bicarbonate, as CaCO3)		Criteria	Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	50 mg/L		9225 Lakeshore Drive - S131 - SS#403	1
# samples:	1	min:	50 mg/L	
# detects:	1	max:	50 mg/L	
# non-detects:	0	avg:	50.000 mg/L (based on 1 numerical results)	
# of Exceedences:	0			

Alkalinity (carbonate, as CaCO3)		Criteria	Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	< 1 mg/L		9225 Lakeshore Drive - S131 - SS#403	1
# samples:	1	min:	< 1 mg/L	
# detects:	0	max:	< 1 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Alkalinity (hydroxide, as CaCO3)		Criteria	Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	< 1 mg/L		9225 Lakeshore Drive - S131 - SS#403	1
# samples:	1	min:	< 1 mg/L	
# detects:	0	max:	< 1 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Alkalinity (phenolphthalein, as CaCO3)		Criteria	Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	< 1 mg/L		9225 Lakeshore Drive - S131 - SS#403	1
# samples:	1	min:	< 1 mg/L	
# detects:	0	max:	< 1 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			



Alkalinity (total, as CaCO3)		Criteria	Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	50 mg/L		9225 Lakeshore Drive - S131 - SS#403	1
# samples:	1	min:	50 mg/L	
# detects:	1	max:	50 mg/L	
# non-detects:	0	avg:	50.000 mg/L (based on 1 numerical results)	
# of Exceedences:	0			

Aluminum (total)		Criteria	Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	< 0.005 mg/L	<=0.2	Operational - Other 9225 Lakeshore Drive - S131 - SS#403	0.005
# samples:	1	min:	< 0.005 mg/L	
# detects:	0	max:	< 0.005 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Antimony (total)		Criteria	Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	< 0.0001 mg/L	<=0.006	MAC 9225 Lakeshore Drive - S131 - SS#403	0.0001
# samples:	1	min:	< 0.0001 mg/L	
# detects:	0	max:	< 0.0001 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Arsenic (total)		Criteria	Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	< 0.0005 mg/L	<=0.010	MAC 9225 Lakeshore Drive - S131 - SS#403	0.0005
# samples:	1	min:	< 0.0005 mg/L	
# detects:	0	max:	< 0.0005 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Barium (total)		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	0.007 mg/L	<=1.0	MAC	9225 Lakeshore Drive - S131 - SS#403	0.005
# samples:	1	min:	0.007 mg/L		
# detects:	1	max:	0.007 mg/L		
# non-detects:	0	avg:	0.007 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Boron (total)		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	0.006 mg/L	<=5	MAC	9225 Lakeshore Drive - S131 - SS#403	0.004
# samples:	1	min:	0.006 mg/L		
# detects:	1	max:	0.006 mg/L		
# non-detects:	0	avg:	0.006 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Bromodichloromethane		Criteria		Sampling Point Name	Detection Limit/MDL
01/15/2016 14:00	1 ug/L	<=90	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
04/01/2016 14:00	2 ug/L	<=90	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
06/22/2016 14:20	1 ug/L	<=90	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
10/13/2016 11:35	2 ug/L	<=90	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
# samples:	4	min:	1 ug/L		
# detects:	4	max:	2 ug/L		
# non-detects:	0	avg:	1.500 ug/L (based on 4 numerical results)		
# of Exceedences:	0				

Bromoform		Criteria		Sampling Point Name	Detection Limit/MDL
01/15/2016 14:00	< 1 ug/L	<=90	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
04/01/2016 14:00	< 1 ug/L	<=90	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1

Bromoform		Criteria		Sampling Point Name	Detection Limit/MDL
06/22/2016 14:20	< 1 ug/L	<=90	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
10/13/2016 11:35	< 1 ug/L	<=90	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
# samples:	4	min:	< 1 ug/L		
# detects:	0	max:	< 1 ug/L		
# non-detects:	4	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Cadmium (total)		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	0.00001 mg/L	<=0.005	MAC	9225 Lakeshore Drive - S131 - SS#403	0.00001
# samples:	1	min:	0.00001 mg/L		
# detects:	1	max:	0.00001 mg/L		
# non-detects:	0	avg:	0.00001 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Calcium (total)		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	19.1 mg/L			9225 Lakeshore Drive - S131 - SS#403	0.2
# samples:	1	min:	19.1 mg/L		
# detects:	1	max:	19.1 mg/L		
# non-detects:	0	avg:	19.100 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Chloride		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	10.9 mg/L	<=250	AO	9225 Lakeshore Drive - S131 - SS#403	0.10
# samples:	1	min:	10.9 mg/L		
# detects:	1	max:	10.9 mg/L		
# non-detects:	0	avg:	10.900 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Chlorine (free)		Criteria		Sampling Point Name	Detection Limit/MDL
01/13/2016 09:30	0.46 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
01/13/2016 10:20	0.52 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
01/27/2016 10:05	0.48 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
01/27/2016 11:25	0.57 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
02/10/2016 10:30	0.30 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
02/10/2016 11:15	0.55 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
02/24/2016 08:20	0.40 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
02/24/2016 09:35	0.53 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
03/09/2016 08:30	0.40 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
03/09/2016 09:20	0.50 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
03/22/2016 12:55	0.56 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
03/22/2016 13:10	0.50 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
04/04/2016 12:45	0.54 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
04/04/2016 13:10	0.40 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
04/20/2016 08:55	0.55 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
04/20/2016 09:20	0.47 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
05/04/2016 10:45	0.45 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 05/04/2016 11:25	0.62 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
05/17/2016 08:15	0.48 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
05/17/2016 11:30	0.54 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
05/31/2016 08:13	0.44 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	

Chlorine (free)		Criteria		Sampling Point Name	Detection Limit/MDL
05/31/2016 08:34	0.49 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
06/14/2016 10:15	0.42 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
06/14/2016 10:45	0.47 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
06/28/2016 11:14	0.55 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
06/28/2016 11:28	0.47 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
07/12/2016 12:50	0.42 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
07/12/2016 13:15	0.49 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
07/26/2016 09:45	0.44 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
07/26/2016 10:10	0.48 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
08/10/2016 10:45	0.36 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
08/10/2016 11:00	0.51 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
08/22/2016 13:00	0.44 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
08/22/2016 13:30	0.49 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
09/07/2016 10:09	0.43 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
09/07/2016 10:25	0.51 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
09/20/2016 09:45	0.52 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
09/20/2016 10:15	0.46 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
10/05/2016 09:40	0.44 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
10/05/2016 10:15	0.39 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
11/01/2016 13:20	0.33 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
11/01/2016 13:45	0.48 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	

Chlorine (free)		Criteria		Sampling Point Name	Detection Limit/MDL
11/16/2016 10:15	0.54 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
11/16/2016 10:40	0.40 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
11/29/2016 10:15	0.56 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
11/29/2016 10:30	0.49 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
12/13/2016 13:30	0.55 mg/L	>=0.2, <=0.6	User-Defined	9525 Emerald Drive - R238 - SS#406	
12/14/2016 11:10	0.48 mg/L	>=0.2, <=0.6	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
# samples:	48	min:	0.30 mg/L		
# detects:	48	max:	0.62 mg/L		
# non-detects:	0	avg:	0.476 mg/L (based on 48 numerical results)		
# of Exceedences:	1				

Chloroform		Criteria		Sampling Point Name	Detection Limit/MDL
01/15/2016 14:00	7 ug/L	<=90	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
04/01/2016 14:00	9 ug/L	<=90	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
06/22/2016 14:20	6 ug/L	<=90	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
10/13/2016 11:35	3 ug/L	<=90	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
# samples:	4	min:	3 ug/L		
# detects:	4	max:	9 ug/L		
# non-detects:	0	avg:	6.250 ug/L (based on 4 numerical results)		
# of Exceedences:	0				

Chromium (total)		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	< 0.0005 mg/L	<=0.05	MAC	9225 Lakeshore Drive - S131 - SS#403	0.0005
# samples:	1	min:	< 0.0005 mg/L		
# detects:	0	max:	< 0.0005 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		

of Exceedences: 0

Cobalt (total)		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	< 0.00005 mg/L			9225 Lakeshore Drive - S131 - SS#403	0.00005
# samples:	1	min:	< 0.00005 mg/L		
# detects:	0	max:	< 0.00005 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Colour		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	< 5 TCU	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	5
# samples:	1	min:	< 5 TCU		
# detects:	0	max:	< 5 TCU		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Conductivity		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	164 umho/cm			9225 Lakeshore Drive - S131 - SS#403	2
# samples:	1	min:	164 umho/cm		
# detects:	1	max:	164 umho/cm		
# non-detects:	0	avg:	164.000 umho/cm (based on 1 numerical results)		
# of Exceedences:	0				

Copper (total)		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	0.0661 mg/L	<=1.0	AO	9225 Lakeshore Drive - S131 - SS#403	0.0002
# samples:	1	min:	0.0661 mg/L		
# detects:	1	max:	0.0661 mg/L		
# non-detects:	0	avg:	0.0661 mg/L (based on 1 numerical results)		
# of Exceedences:	0				



Cyanide (total)		Criteria	Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	< 0.0020 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.0020
# samples:	1	min:	< 0.0020 mg/L	
# detects:	0	max:	< 0.0020 mg/L	
# non-detects:	1	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dibromoacetic acid		Criteria	Sampling Point Name	Detection Limit/MDL
01/15/2016 14:00	< 0.002 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002
04/01/2016 14:00	< 0.002 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002
06/22/2016 14:20	< 0.002 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002
10/13/2016 11:35	< 0.002 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002
# samples:	4	min:	< 0.002 mg/L	
# detects:	0	max:	< 0.002 mg/L	
# non-detects:	4	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			

Dibromochloromethane		Criteria	Sampling Point Name	Detection Limit/MDL
01/15/2016 14:00	< 1 ug/L	<=90	User-Defined 9225 Lakeshore Drive - S131 - SS#403	1
04/01/2016 14:00	< 1 ug/L	<=90	User-Defined 9225 Lakeshore Drive - S131 - SS#403	1
06/22/2016 14:20	< 1 ug/L	<=90	User-Defined 9225 Lakeshore Drive - S131 - SS#403	1
10/13/2016 11:35	< 1 ug/L	<=90	User-Defined 9225 Lakeshore Drive - S131 - SS#403	1
# samples:	4	min:	< 1 ug/L	
# detects:	0	max:	< 1 ug/L	
# non-detects:	4	avg:	n/a (based on 0 numerical results)	
# of Exceedences:	0			



Dichloroacetic acid		Criteria	Sampling Point Name	Detection Limit/MDL
01/15/2016 14:00	0.004 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002
04/01/2016 14:00	0.004 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002
06/22/2016 14:20	0.003 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002
10/13/2016 11:35	< 0.002 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002

# samples:	4	min:	< 0.002 mg/L
# detects:	3	max:	0.004 mg/L
# non-detects:	1	avg:	0.004 mg/L (based on 3 numerical results)
# of Exceedences:	0		

Escherichia coli / E. coli (counts)		Criteria		Sampling Point Name	Detection Limit/MDL
01/13/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
01/13/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
01/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
01/27/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
02/10/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
02/10/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
02/24/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
02/24/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
03/09/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
03/09/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
03/22/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
03/22/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
04/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1

Escherichia coli / E. coli (counts)		Criteria		Sampling Point Name	Detection Limit/MDL
04/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
05/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
05/04/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
05/17/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
05/17/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
05/31/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
05/31/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
06/14/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
06/14/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
06/28/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
06/28/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
07/12/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
07/12/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
07/26/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
07/26/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
08/10/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
08/10/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
08/22/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
08/22/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
09/07/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
09/07/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1

Escherichia coli / E. coli (counts)		Criteria		Sampling Point Name	Detection Limit/MDL
09/20/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
09/20/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
10/05/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
10/05/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
10/18/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
10/18/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
11/01/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
11/01/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
11/16/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
11/16/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
11/29/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
11/29/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
12/14/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
12/14/2016 00:00	< 1 counts/100mL	<=0, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1

# samples:	48	min:	< 1 counts/100mL
# detects:	0	max:	< 1 counts/100mL
# non-detects:	48	Geometric Mean:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Fluoride		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	< 0.10 mg/L	<=1.5	MAC	9225 Lakeshore Drive - S131 - SS#403	0.10

# samples:	1	min:	< 0.10 mg/L
# detects:	0	max:	< 0.10 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)

of Exceedences: 0

Haloacetic acids 5 / HAA5		Criteria	Sampling Point Name	Detection Limit/MDL
01/15/2016 14:00	0.011 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002
04/01/2016 14:00	0.009 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002
06/22/2016 14:20	0.006 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002
10/13/2016 11:35	0.002 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002

# samples:	4	min:	0.002 mg/L
# detects:	4	max:	0.011 mg/L
# non-detects:	0	avg:	0.007 mg/L (based on 4 numerical results)
# of Exceedences:	0		

Hardness (total, as CaCO3)		Criteria	Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	50.8 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.50

# samples:	1	min:	50.8 mg/L
# detects:	1	max:	50.8 mg/L
# non-detects:	0	avg:	50.800 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Heterotrophic Plate Count / HPC		Criteria		Sampling Point Name	Detection Limit/MDL
01/21/2016 13:20	< 1 CFU/mL	<=200	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
01/21/2016 13:35	< 1 CFU/mL	<=200	User-Defined	9525 Emerald Drive - R238 - SS#406	1
04/04/2016 12:45	< 1 CFU/mL	<=200	User-Defined	9525 Emerald Drive - R238 - SS#406	1
04/04/2016 13:10	< 1 CFU/mL	<=200	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
07/07/2016 11:20	< 1 CFU/mL	<=200	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
07/07/2016 11:50	< 1 CFU/mL	<=200	User-Defined	9525 Emerald Drive - R238 - SS#406	1



Heterotrophic Plate Count / HPC		Criteria		Sampling Point Name	Detection Limit/MDL
10/13/2016 11:35	< 1 CFU/mL	<=200	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
10/13/2016 12:00	< 1 CFU/mL	<=200	User-Defined	9525 Emerald Drive - R238 - SS#406	1
# samples:	8	min:	< 1 CFU/mL		
# detects:	0	max:	< 1 CFU/mL		
# non-detects:	8	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Iron (total)		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	0.03 mg/L	<=0.3	AO	9225 Lakeshore Drive - S131 - SS#403	0.01
# samples:	1	min:	0.03 mg/L		
# detects:	1	max:	0.03 mg/L		
# non-detects:	0	avg:	0.030 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Lead (total)		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	0.0004 mg/L	<=0.010	MAC	9225 Lakeshore Drive - S131 - SS#403	0.0001
# samples:	1	min:	0.0004 mg/L		
# detects:	1	max:	0.0004 mg/L		
# non-detects:	0	avg:	0.0004 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Magnesium (total)		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	0.77 mg/L			9225 Lakeshore Drive - S131 - SS#403	0.01
# samples:	1	min:	0.77 mg/L		
# detects:	1	max:	0.77 mg/L		
# non-detects:	0	avg:	0.770 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Manganese (total)		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	0.0005 mg/L	<=0.05	AO	9225 Lakeshore Drive - S131 - SS#403	0.0002
# samples:	1	min:	0.0005 mg/L		
# detects:	1	max:	0.0005 mg/L		
# non-detects:	0	avg:	0.0005 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Mercury (total)		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	< 0.00002 mg/L			9225 Lakeshore Drive - S131 - SS#403	0.00002
# samples:	1	min:	< 0.00002 mg/L		
# detects:	0	max:	< 0.00002 mg/L		
# non-detects:	1	avg:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Molybdenum (total)		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	0.0003 mg/L			9225 Lakeshore Drive - S131 - SS#403	0.0001
# samples:	1	min:	0.0003 mg/L		
# detects:	1	max:	0.0003 mg/L		
# non-detects:	0	avg:	0.0003 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Monobromoacetic acid		Criteria		Sampling Point Name	Detection Limit/MDL
01/15/2016 14:00	< 0.002 mg/L			9225 Lakeshore Drive - S131 - SS#403	0.002
04/01/2016 14:00	< 0.002 mg/L			9225 Lakeshore Drive - S131 - SS#403	0.002
06/22/2016 14:20	< 0.002 mg/L			9225 Lakeshore Drive - S131 - SS#403	0.002
10/13/2016 11:35	0.002 mg/L			9225 Lakeshore Drive - S131 - SS#403	0.002
# samples:	4	min:	< 0.002 mg/L		
# detects:	1	max:	0.002 mg/L		

# non-detects:	3	avg:	0.002 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Monochloroacetic acid		Criteria	Sampling Point Name	Detection Limit/MDL
01/15/2016 14:00	0.003 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002
04/01/2016 14:00	< 0.002 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002
06/22/2016 14:20	< 0.002 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002
10/13/2016 11:35	< 0.002 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002

# samples:	4	min:	< 0.002 mg/L
# detects:	1	max:	0.003 mg/L
# non-detects:	3	avg:	0.003 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Nickel (total)		Criteria	Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	< 0.0002 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.0002

# samples:	1	min:	< 0.0002 mg/L
# detects:	0	max:	< 0.0002 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Nitrate (as N)		Criteria	Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	0.131 mg/L	<=10 MAC	9225 Lakeshore Drive - S131 - SS#403	0.010

# samples:	1	min:	0.131 mg/L
# detects:	1	max:	0.131 mg/L
# non-detects:	0	avg:	0.131 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Nitrite (as N)		Criteria	Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	< 0.010 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.010



# samples:	1	min:	< 0.010 mg/L
# detects:	0	max:	< 0.010 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

pH		Criteria		Sampling Point Name	Detection Limit/MDL
* 01/13/2016 09:30	6.95	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 01/13/2016 10:20	6.99	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 01/27/2016 10:05	6.92	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 01/27/2016 11:25	6.98	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 02/10/2016 10:30	6.98	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 02/10/2016 11:15	6.92	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 02/24/2016 08:20	6.84	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 02/24/2016 09:35	6.85	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
03/09/2016 08:30	7.17	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
03/09/2016 09:20	7.16	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 03/22/2016 12:55	6.97	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
03/22/2016 13:10	7.05	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 04/04/2016 12:45	6.94	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 04/04/2016 13:10	6.97	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 04/20/2016 08:55	6.76	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 04/20/2016 09:20	6.79	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 05/04/2016 10:45	6.92	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 05/04/2016 11:25	6.97	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	



pH		Criteria		Sampling Point Name	Detection Limit/MDL
05/17/2016 08:15	7.04	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 05/17/2016 11:30	6.91	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
05/31/2016 08:13	7.11	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
05/31/2016 08:34	7.12	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 06/14/2016 10:15	6.88	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 06/14/2016 10:45	6.88	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 06/28/2016 11:14	6.92	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 06/28/2016 11:28	6.95	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 07/12/2016 12:50	6.89	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 07/12/2016 13:15	6.88	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 07/26/2016 09:45	6.89	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 07/26/2016 10:10	6.93	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 08/10/2016 10:45	6.74	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 08/10/2016 11:00	6.91	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 08/22/2016 13:00	6.77	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 08/22/2016 13:30	6.95	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 09/07/2016 10:09	6.89	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 09/07/2016 10:25	6.90	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 09/20/2016 09:45	6.82	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 09/20/2016 10:15	6.93	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 10/05/2016 09:40	6.94	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	

pH		Criteria		Sampling Point Name	Detection Limit/MDL
* 10/05/2016 10:15	6.88	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 11/01/2016 13:20	6.73	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 11/01/2016 13:45	6.79	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 11/16/2016 10:15	6.83	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 11/16/2016 10:40	6.85	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 11/29/2016 10:15	6.82	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 11/29/2016 10:30	6.87	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
* 12/13/2016 13:30	6.96	>=7, <=10.5	User-Defined	9525 Emerald Drive - R238 - SS#406	
* 12/14/2016 11:10	6.74	>=7, <=10.5	User-Defined	9225 Lakeshore Drive - S131 - SS#403	

# samples:	48	min:	6.73
# detects:	48	max:	7.17
# non-detects:	0	avg:	6.914 (based on 48 numerical results)
# of Exceedences:	42		

Potassium (total)		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	0.67 mg/L			9225 Lakeshore Drive - S131 - SS#403	0.02

# samples:	1	min:	0.67 mg/L
# detects:	1	max:	0.67 mg/L
# non-detects:	0	avg:	0.670 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Selenium (total)		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	< 0.0005 mg/L	<=0.05	MAC	9225 Lakeshore Drive - S131 - SS#403	0.0005

# samples:	1	min:	< 0.0005 mg/L
# detects:	0	max:	< 0.0005 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)



of Exceedences: 0

Sodium (total)		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	12.7 mg/L	<=200	AO	9225 Lakeshore Drive - S131 - SS#403	0.02
# samples:	1	min:	12.7 mg/L		
# detects:	1	max:	12.7 mg/L		
# non-detects:	0	avg:	12.700 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Sulphate		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	12.9 mg/L			9225 Lakeshore Drive - S131 - SS#403	1.0
# samples:	1	min:	12.9 mg/L		
# detects:	1	max:	12.9 mg/L		
# non-detects:	0	avg:	12.900 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Temperature		Criteria		Sampling Point Name	Detection Limit/MDL
01/13/2016 09:30	7.8 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
01/13/2016 10:20	6.7 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
01/27/2016 10:05	7.0 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
01/27/2016 11:25	6.5 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
02/10/2016 10:30	6.6 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
02/10/2016 11:15	6.8 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
02/24/2016 08:20	5.0 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
02/24/2016 09:35	6.4 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
03/09/2016 08:30	5.9 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	



Temperature		Criteria		Sampling Point Name	Detection Limit/MDL
03/09/2016 09:20	6.8 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
03/22/2016 12:55	8.0 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
03/22/2016 13:10	5.8 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
04/04/2016 12:45	7.2 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
04/04/2016 13:10	6.9 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
04/20/2016 08:55	7.1 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
04/20/2016 09:20	7.8 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
05/04/2016 10:45	9.4 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
05/04/2016 11:25	8.3 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
05/17/2016 08:15	9.6 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
05/17/2016 11:30	8.7 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
05/31/2016 08:13	10.3 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
05/31/2016 08:34	8.5 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
06/14/2016 10:15	12.2 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
06/14/2016 10:45	9.9 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
06/28/2016 11:14	10.6 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
06/28/2016 11:28	12.1 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
07/12/2016 12:50	12.7 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
07/12/2016 13:15	10.5 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
07/26/2016 09:45	11.6 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
07/26/2016 10:10	13.4 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	

Temperature		Criteria		Sampling Point Name	Detection Limit/MDL
08/10/2016 10:45	14.0 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
08/10/2016 11:00	11.1 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
08/22/2016 13:00	14.0 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
08/22/2016 13:30	10.5 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
09/07/2016 10:09	13.9 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
09/07/2016 10:25	10.4 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
09/20/2016 09:45	10.3 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
09/20/2016 10:15	12.6 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
10/05/2016 09:40	10.0 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
10/05/2016 10:15	12.7 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
11/01/2016 13:20	10.8 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
11/01/2016 13:45	9.5 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
11/16/2016 10:15	9.5 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
11/16/2016 10:40	10.9 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
11/29/2016 10:15	8.5 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
11/29/2016 10:30	9.4 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	
12/13/2016 13:30	6.9 degrees C	<=15	AO	9525 Emerald Drive - R238 - SS#406	
12/14/2016 11:10	8.1 degrees C	<=15	AO	9225 Lakeshore Drive - S131 - SS#403	

# samples:	48	min:	5.0 degrees C
# detects:	48	max:	14.0 degrees C
# non-detects:	0	avg:	9.358 degrees C (based on 48 numerical results)
# of Exceedences:	0		



Total Coliforms (counts)		Criteria		Sampling Point Name	Detection Limit/MDL
01/13/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
01/13/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
01/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
01/27/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
02/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
02/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
02/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
02/24/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
03/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
03/09/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
03/22/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
03/22/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
04/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
04/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
05/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
05/04/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
05/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
05/17/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
05/31/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
05/31/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
06/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1

Total Coliforms (counts)		Criteria		Sampling Point Name	Detection Limit/MDL
06/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
06/28/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
06/28/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
07/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
07/12/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
07/26/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
07/26/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
08/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
08/10/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
08/22/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
08/22/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
09/07/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
09/07/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
09/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
09/20/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
10/05/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
10/05/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
10/18/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
10/18/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
11/01/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
11/01/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1

Total Coliforms (counts)		Criteria		Sampling Point Name	Detection Limit/MDL
11/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
11/16/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
11/29/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
11/29/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
12/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9225 Lakeshore Drive - S131 - SS#403	1
12/14/2016 00:00	< 1 counts/100mL	<=10, OG, P	User-Defined	9525 Emerald Drive - R238 - SS#406	1
# samples:	48	min:	< 1 counts/100mL		
# detects:	0	max:	< 1 counts/100mL		
# non-detects:	48	Geometric Mean:	n/a (based on 0 numerical results)		
# of Exceedences:	0				

Total Dissolved Solids / TDS (computed)		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	88.1 mg/L			9225 Lakeshore Drive - S131 - SS#403	1.00
# samples:	1	min:	88.1 mg/L		
# detects:	1	max:	88.1 mg/L		
# non-detects:	0	avg:	88.100 mg/L (based on 1 numerical results)		
# of Exceedences:	0				

Total Trihalomethanes / TTHM		Criteria		Sampling Point Name	Detection Limit/MDL
01/15/2016 14:00	8 ug/L	<=100	User-Defined	9225 Lakeshore Drive - S131 - SS#403	4
04/01/2016 14:00	10 ug/L	<=100	User-Defined	9225 Lakeshore Drive - S131 - SS#403	4
06/22/2016 14:20	7 ug/L	<=100	User-Defined	9225 Lakeshore Drive - S131 - SS#403	4
10/13/2016 11:35	5 ug/L	<=100	User-Defined	9225 Lakeshore Drive - S131 - SS#403	4
# samples:	4	min:	5 ug/L		
# detects:	4	max:	10 ug/L		
# non-detects:	0	avg:	7.500 ug/L (based on 4 numerical results)		

of Exceedences: 0

Trichloroacetic acid		Criteria	Sampling Point Name	Detection Limit/MDL
01/15/2016 14:00	0.003 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002
04/01/2016 14:00	0.005 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002
06/22/2016 14:20	0.002 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002
10/13/2016 11:35	< 0.002 mg/L		9225 Lakeshore Drive - S131 - SS#403	0.002

# samples:	4	min:	< 0.002 mg/L
# detects:	3	max:	0.005 mg/L
# non-detects:	1	avg:	0.003 mg/L (based on 3 numerical results)
# of Exceedences:	0		

Turbidity		Criteria		Sampling Point Name	Detection Limit/MDL
01/13/2016 09:30	0.12 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
01/13/2016 10:20	0.11 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
01/27/2016 10:05	0.16 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
01/27/2016 11:25	0.09 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
02/10/2016 10:30	0.10 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
02/10/2016 11:15	0.06 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
02/24/2016 08:20	0.13 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
02/24/2016 09:35	0.08 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
03/09/2016 08:30	0.17 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
03/09/2016 09:20	0.06 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
03/22/2016 12:55	0.07 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
03/22/2016 13:10	0.11 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	



Turbidity		Criteria		Sampling Point Name	Detection Limit/MDL
04/04/2016 12:45	0.06 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
04/04/2016 13:10	0.12 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
04/20/2016 08:55	0.08 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
04/20/2016 09:20	0.09 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
05/04/2016 10:45	0.07 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
05/04/2016 11:25	0.06 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
05/17/2016 08:15	0.06 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
05/17/2016 11:30	0.06 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
05/31/2016 08:13	0.14 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
05/31/2016 08:34	0.10 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
06/14/2016 10:15	0.09 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
06/14/2016 10:45	0.15 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
06/28/2016 11:14	0.42 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
06/28/2016 11:28	0.24 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
07/12/2016 12:50	0.12 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
07/12/2016 13:15	0.10 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
07/26/2016 09:45	0.14 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
07/26/2016 10:10	0.10 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
08/10/2016 10:45	0.15 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
08/10/2016 11:00	0.05 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
08/22/2016 13:00	0.10 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	

Turbidity		Criteria		Sampling Point Name	Detection Limit/MDL
08/22/2016 13:30	0.06 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
09/07/2016 10:09	0.24 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
09/07/2016 10:25	0.11 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
09/20/2016 09:45	0.21 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
09/20/2016 10:15	0.21 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
10/05/2016 09:40	0.06 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
10/05/2016 10:15	0.09 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
11/01/2016 13:20	0.13 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
11/01/2016 13:45	0.10 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
11/16/2016 10:15	0.11 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
11/16/2016 10:40	0.14 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
11/29/2016 10:15	0.12 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
11/29/2016 10:30	0.15 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	
12/13/2016 13:30	0.10 NTU	<=1	User-Defined	9525 Emerald Drive - R238 - SS#406	
12/14/2016 11:05	0.10 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	0.10
12/14/2016 11:10	0.12 NTU	<=1	User-Defined	9225 Lakeshore Drive - S131 - SS#403	

# samples:	49	min:	0.05 NTU
# detects:	49	max:	0.42 NTU
# non-detects:	0	avg:	0.119 NTU (based on 49 numerical results)
# of Exceedences:	0	95th percentile:	0.240 NTU

Uranium (total)		Criteria		Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05	< 0.00002 mg/L	<=0.02	MAC	9225 Lakeshore Drive - S131 - SS#403	0.00002



# samples:	1	min:	< 0.00002 mg/L
# detects:	0	max:	< 0.00002 mg/L
# non-detects:	1	avg:	n/a (based on 0 numerical results)
# of Exceedences:	0		

Zinc (total)	Criteria	Sampling Point Name	Detection Limit/MDL
12/14/2016 11:05 0.013 mg/L	<=5 AO	9225 Lakeshore Drive - S131 - SS#403	0.004

# samples:	1	min:	0.013 mg/L
# detects:	1	max:	0.013 mg/L
# non-detects:	0	avg:	0.013 mg/L (based on 1 numerical results)
# of Exceedences:	0		

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, U=non-detect, OR=over-range, OG=overgrown, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

* Indicates Criteria is exceeded



Turbidity		Criteria		Detection Limit/MDL	Sampling Point Name
01/06/2016 09:45	0.05 NTU	<=1	User-Defined		W-201-1
01/06/2016 10:35	0.13 NTU	<=1	User-Defined		W-201-2
01/06/2016 10:45	0.12 NTU	<=1	User-Defined		W-201-3
01/20/2016 08:40	0.07 NTU	<=1	User-Defined		W-201-1
01/20/2016 09:00	0.08 NTU	<=1	User-Defined		W-201-2
01/20/2016 09:10	0.09 NTU	<=1	User-Defined		W-201-3
02/03/2016 08:40	0.11 NTU	<=1	User-Defined		W-201-1
02/03/2016 08:55	0.57 NTU	<=1	User-Defined		W-201-3
02/03/2016 09:20	0.12 NTU	<=1	User-Defined		W-201-2
02/17/2016 09:50	0.04 NTU	<=1	User-Defined		W-201-1
02/17/2016 10:10	0.08 NTU	<=1	User-Defined		W-201-2
02/17/2016 10:20	0.15 NTU	<=1	User-Defined		W-201-3
03/02/2016 09:40	0.05 NTU	<=1	User-Defined		W-201-1
03/02/2016 09:55	0.06 NTU	<=1	User-Defined		W-201-2
03/02/2016 10:05	0.27 NTU	<=1	User-Defined		W-201-3
03/30/2016 12:25	0.06 NTU	<=1	User-Defined		W-201-1
03/30/2016 12:45	0.08 NTU	<=1	User-Defined		W-201-2
03/30/2016 12:55	0.13 NTU	<=1	User-Defined		W-201-3
04/13/2016 09:30	0.06 NTU	<=1	User-Defined		W-201-1
04/13/2016 09:40	0.07 NTU	<=1	User-Defined		W-201-2
04/13/2016 09:50	0.15 NTU	<=1	User-Defined		W-201-3
04/27/2016 09:58	0.1 NTU	<=1	User-Defined		W-201-1
04/27/2016 10:15	0.61 NTU	<=1	User-Defined		W-201-2
04/27/2016 10:21	0.24 NTU	<=1	User-Defined		W-201-3
05/11/2016 13:15	0.07 NTU	<=1	User-Defined		W-201-1
05/11/2016 13:25	0.08 NTU	<=1	User-Defined		W-201-2
05/25/2016 09:00	0.06 NTU	<=1	User-Defined		W-201-1
05/25/2016 09:15	0.06 NTU	<=1	User-Defined		W-201-2
05/25/2016 09:30	0.12 NTU	<=1	User-Defined		W-201-3
06/06/2016 11:00	0.14 NTU	<=1	User-Defined		W-201-1
06/06/2016 11:05	0.18 NTU	<=1	User-Defined		W-201-2
06/06/2016 11:35	0.17 NTU	<=1	User-Defined		W-201-3
06/21/2016 09:00	0.08 NTU	<=1	User-Defined		W-201-1
06/21/2016 09:10	0.05 NTU	<=1	User-Defined		W-201-2
06/21/2016 09:20	0.38 NTU	<=1	User-Defined		W-201-3
07/05/2016 12:15	0.06 NTU	<=1	User-Defined		W-201-1
07/05/2016 12:40	0.05 NTU	<=1	User-Defined		W-201-2



Turbidity		Criteria		Detection Limit/MDL	Sampling Point Name
07/05/2016 13:00	0.08 NTU	<=1	User-Defined		W-201-3
07/20/2016 09:30	0.02 NTU	<=1	User-Defined		W-201-1
07/20/2016 09:34	0.17 NTU	<=1	User-Defined		W-201-2
07/20/2016 09:53	0.22 NTU	<=1	User-Defined		W-201-3
08/03/2016 09:15	0.09 NTU	<=1	User-Defined		W-201-1
08/03/2016 09:25	0.08 NTU	<=1	User-Defined		W-201-2
08/03/2016 09:45	0.17 NTU	<=1	User-Defined		W-201-3
08/17/2016 12:30	0.16 NTU	<=1	User-Defined		W-201-1
08/17/2016 12:50	0.33 NTU	<=1	User-Defined		W-201-2
08/17/2016 13:05	0.22 NTU	<=1	User-Defined		W-201-3
08/31/2016 08:35	0.07 NTU	<=1	User-Defined		W-201-1
08/31/2016 08:55	0.06 NTU	<=1	User-Defined		W-201-2
08/31/2016 09:15	0.12 NTU	<=1	User-Defined		W-201-3
09/14/2016 12:50	0.08 NTU	<=1	User-Defined		W-201-1
09/14/2016 13:00	0.05 NTU	<=1	User-Defined		W-201-2
09/14/2016 13:20	0.19 NTU	<=1	User-Defined		W-201-3
09/28/2016 08:15	0.12 NTU	<=1	User-Defined		W-201-1
09/28/2016 08:35	0.06 NTU	<=1	User-Defined		W-201-2
09/28/2016 08:45	0.15 NTU	<=1	User-Defined		W-201-3
10/12/2016 12:05	0.13 NTU	<=1	User-Defined		W-201-1
10/12/2016 12:15	0.12 NTU	<=1	User-Defined		W-201-2
10/12/2016 12:30	0.32 NTU	<=1	User-Defined		W-201-3
10/25/2016 10:23	0.10 NTU	<=1	User-Defined		W-201-1
10/25/2016 10:30	0.12 NTU	<=1	User-Defined		W-201-2
10/25/2016 10:40	0.17 NTU	<=1	User-Defined		W-201-3
11/09/2016 13:15	< 0.10 NTU	<=1	User-Defined	0.10	W-201-1
11/09/2016 13:15	0.09 NTU	<=1	User-Defined		W-201-1
11/09/2016 13:30	< 0.10 NTU	<=1	User-Defined	0.10	W-201-2
11/09/2016 13:30	0.08 NTU	<=1	User-Defined		W-201-2
11/09/2016 13:40	0.20 NTU	<=1	User-Defined		W-201-3
11/09/2016 13:40	0.20 NTU	<=1	User-Defined	0.10	W-201-3
11/23/2016 13:05	0.11 NTU	<=1	User-Defined		W-201-1
11/23/2016 13:25	0.07 NTU	<=1	User-Defined		W-201-2
11/23/2016 13:40	0.30 NTU	<=1	User-Defined		W-201-3
12/07/2016 08:00	0.12 NTU	<=1	User-Defined		W-201-1
12/07/2016 08:15	0.12 NTU	<=1	User-Defined		W-201-2
12/07/2016 08:30	0.23 NTU	<=1	User-Defined		W-201-3

samples: 74 **min:** 0.02 NTU



# detects:	72	max:	0.61 NTU
# non-detects:	2	avg:	0.138 NTU (based on 72 numerical results)
# of Exceedences:	0	95th percentile:	0.348 NTU

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, U=non-detect, OR=over-range, OG=overgrown,
TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

< means less than lower detection limit shown

> means greater than upper detection limit shown

« means detected & less than number shown

» means detected & greater than number shown

* **Indicates Criteria is exceeded**