



ENGINEERING DEPARTMENT

CONTRACT NUMBER: T076
CONTRACT TITLE: Nesters Impound Yard Infrastructure Services
ADDENDUM NUMBER.: 3
ADDENDUM ISSUE DATE: July 9, 2019
TENDER CLOSING DATE: **July 11, 2019 at 2:00pm local time**

Tenderers are advised that Addendum No. 3 to *Contract T076* is hereby issued by the *Owner*. This addendum shall form part of the *Contract Documents* and is to be read, interpreted and coordinated with all other parts. The following revisions supersede the information contained in the original *Contract Documents* and preceding addendums. The cost of all *Work* herein shall be included in the Unit Prices tendered in the *Schedule of Quantities and Prices*.

GENERAL

This Addendum is comprised of the following attached pages:

1. Questions and Answers

QUESTIONS & ANSWERS

Q1: Please clarify the item 26.01 "35mm RPVC Empty Ducting": Is there a pull box at the first lighting base from the existing cabinet?

A1: *There is no junction box / pull box at the first lighting base from the existing cabinet. A junction box might need to be installed there when the future security system is installed.*

END OF ADDENDUM #3