



INFRASTRUCTURE SERVICES

RFQ NUMBER: T076-2021

RFQ TITLE: Nesters Impound Yard Infrastructure Services – Phase 2 Lighting Installation

ADDENDUM NUMBER.: 1

ADDENDUM ISSUE DATE: July 27, 2021

RFQ CLOSING DATE: **August 5, 2021 at 2:00pm local time**

Contractors are advised that Addendum No. 1 to Request for Quotation (RFQ) T076-2021 is hereby issued by the *Owner*. This addendum shall form part of the RFQ documents and is to be read, interpreted and coordinated with all other parts. The following revisions supersede the information contained in the original RFQ documents and preceding addendums. The cost of all *Work* herein shall be included in the Quote Form in the *Schedule of Quantities and Prices*.

QUESTIONS & ANSWERS

Q1: Would the RMOW accept alternatives to the Hubbell flood lights.

A1: The Owner has no objections on alternative flood lights, as long as they can be mounted on the side arms. Contractor is required to submit the alternative flood lights for approval prior to installation.

Q2: Were the ground plates and wires installed in phase #1 of this project?

A2: The ground plate and bond wires for ground plate have been installed for each concrete base during Phase 1 works.

END OF ADDENDUM #1