

August 28th, 2024**A – Addendum #3****RFP – 2024 WWTP Dewatering Polymer Procurement****The following information is to be used as a reference:**

Testing Values					
Date (mm/dd/yyyy)	MLSS (mg/l)	WAS Solids Concentration (m³/day)	Primary Solids Concentration (m³/day)	Centrifuge Avg. Flow Rate (l/s)	DAF Avg. Flow Rate (l/s)
08/13/2024	984	55.31	59.34	5.8	11.04
08/14/2024	966	54.92	61.80	5.8	11.06
08/15/2026	978	37.78	39.89	6.0	11.06
08/16/2024	976	57.15	63.59	6.0	11.05
08/19/2024	1094	42.07	56.13	5.7	11.05
08/20/2024	1110	47.45	64.05	5.7	11.05
08/21/2024	1076	40.89	57.06	5.8	10.97
08/22/2024	1066	38.19	56.22	5.8	11.05
08/23/2024	1006	42.68	56.48	5.8	11.06

QUESTION	ANSWER
MLSS Solids Concentration	Please see the table above for values.
Primary Solids Concentration	Please see the table above for values.
WAS Concentration	Please see the table above for values.
Average sludge flow rates (L/S) into the centrifuge (combined WAS & Fermenter)	Please see the table above for values.
Average sludge flow rates (L/S) into the DAFT	Please see the table above for values.

End of Addendum