

NOTES:

- CULVERT TO BE SIZED TO CARRY DITCH DESIGNED FLOWS. LENGTH 2.0m C/W CONCRETE HEADWALLS
- COMPACT BEDDING TO 95% MODIFIED PROCTOR
- FOR INSTALLATION OF VALVE BOX SEE RMOW STANDARD DWG W3
- APPLY AN APPROVED CORROSION PROTECTION SYSTEM TO ALL BURIED FERROUS FITTINGS, FLANGES, FASTENERS, ETC. SUCH AS "DENSO" PETROLATUM TAPE SYSTEM; INCLUDING PASTE, PROFILING MASTIC AND TAPE AS PER MANUFACTURER'S INSTRUCTIONS, OTHER CORROSION PROTECTION SYSTEMS MAY BE USED UPON APPROVAL OF THE RMOW.

APPROVED HYDRANTS:

- T.C.I.W. C-71P EXTENDED BODY COMPRESSION TYPE HYDRANT
- CANADA VALVE "CENTURY"
- CLOW CANADA "BRIGADIER M93"



RESORT MUNICIPALITY of WHISTLER STANDARD HYDRANT ASSEMBLY

DRAWN BY: BL	DATE: JANUARY 2018
SCALE: N.T.S.	DWG. NO.: W4