

Addendum 2

ISSUE DATE: October 12, 2023

CLIENT NAME: Resort Municipality of Whistler

FROM: Chelsey Roberts, AScT, Resort Municipality of Whistler

RE: South Whistler Water Upgrade

Contract E20307

In accordance with the provision contained in the "Instructions to Tenderers" for Contract No. E20307, Addendum No. 2 is hereby issued.

The following changes, additions, and/or deletions are hereby made a part of the Contract Documents for the above noted Contract, Invitation for Tender as fully and completely as if the same were fully set forth therein:

Revise the following Instruction to Tenderers

IT 3.0 Tender Closing Date: October 24th, 2023

Revise 01 61 03 1.1.2.5 as follows:

.5 Section 26 05 81 - Motors

Questions

- Q1. Can the location of silt fencing be confirmed?
- A1. Refer to MMCD 01 57 01 1.2.4.1.1.
- Q2. What is the standard of acceptance for the MCCs.
- A2. Standard of acceptance for the MCC in P279 shall be either Allan Bradley, ABB, Schneider Electric or Eaton. The standard of acceptance for internal components shall be as per the individual specifications provided.
- Q3. Can you please advise as I seem to be missing section 40 73 00 pressure instruments it is missing from tender doc's
- A3. Please review Division 26 29 04 Transmitters and Indicators (electrical division) to see if that answers your questions.

Drawings

Replace the following drawings


- A005 P291 South Whistler Booster Pump Station and Water Treatment Facility | Architectural Details Sheet 1
- S004 P291 South Whistler Booster Pump Station and Water Treatment Facility | Wall Plan & Reinforcement/Roof Plan




M006 P291 – South Whistler Booster Pump Station and Water Treatment Facility | HVAC Schedules & Details


Non-Mandatory Site Visit Attendee

- Whistler Excavations Ltd.
- Coast Mountain Excavation Ltd.
- Carver Construction Ltd.
- Coast Mountain Custom Homes Ltd.
- TM Builders
- SCG Process Solutions
- Aggressive Pump & Supply Ltd.











PHASE 2

2023

WALL PLAN & REINFORCEMENT / ROOF PLAN

FILENAME 10299470-S001-006.dwg

S004

SCALE AS NOTED

UNIT HEATER SCHEDULE										
NO.	LOCATION	MANUFACT'R	MODEL	CAPACITY	ELEC	CTRIC	٩L	AIR FLOW	FAN	REMARKS
				kW	V	PH.	CY.	CFM	HP	
UH-1A, UH-2A	PUMP ROOM	OUELLET	OAS07536AM	7.5	600	3	60	700	1/30	1
UH-3A, UH-4A	CAUSTIC ROOM	OUELLET	OAS07536AM	7.5	600	3	60	700	1/30	1

REMARKS:

1. COMPLETE WITH REMOTE WALL-MOUNTED THERMOSTAT.

NO.	MANUFACTURER	SERVICE	MODEL	SIZE	REMARKS
IL-1	RUSKIN	PUMP ROOM AIR INTAKE	ELF 375 DXH	712x712	1, 2
IL-2	RUSKIN	CAUSTIC ROOM AIR INTAKE	ELF 375 DXH	712x712	1, 2
EL-1	RUSKIN	PUMP ROOM AIR EXHAUST	ELF 375 DXH	508x508	1, 2
EL-2	RUSKIN	CAUSTIC ROOM AIR EXHAUST	ELF 375 DXH	300x300	1, 2
EL-3	RUSKIN	CAUSTIC ROOM AIR EXHAUST	ELF 375 DXH	508x508	1, 2

REMARKS:

- 1. COMPLETE WITH BIRD SCREEN.
- 2. ALUMINUM CONSTRUCTION, DURANAR XL COATED

MOTORIZED DAMPER SCHEDULE									
NO.	LOCATION	SERVICE	MANUFACTURER	MODEL	P.D.	MATERIAL	BLADE	ACTUATOR	REMARKS
					(Pa)				
MD-1B	PUMP ROOM	AIR INTAKE	TAMCO	9000SC	12	ALUMINUM	PARALLEL	BELIMO	1
MD-3B	CAUSTIC ROOM	AIR INTAKE	TAMCO	9000SC	12	ALUMINUM	PARALLEL	BELIMO	1

REMARKS

1. BELIMO SPRING RETURN ACTUATOR, POWER CLOSE, FAIL OPEN.


NO.	LOCATION	MANUFACTURER	MODEL	TYPE	L/s	S.P.	FRPM	EL	ECTF	RICAL		REMARK
						(Pa)		HP	V	PH.	CY.	
EF-1A	PUMP ROOM	GREENHECK	SE1-14-436-VG	SIDEWALL PROPELLER	1000	90	1725	FRAC.	120	1	60	1, 2, 3
EF-2A	CAUSTIC ROOM	FANTECH	FR150	INLINE EXHAUST	100	62	2630	FRAC.	120	1	60	1, 3
EF-3A	CAUSTIC ROOM	GREENHECK	SE1-14-436-VG	SIDEWALL PROPELLER	1000	90	1725	FRAC.	120	1	60	1,

EMARKS:

- COMPLETE WITH WALL COLLAR, AND MOTOR SIDE GUARD.
 COMPLETE WITH VARI-GREEN MOTOR REMOTE WALL MOUNTED SPEED DIAL.
- 3. SEE ELECTRICAL DIV.16. FOR RATING DETAILS *

DE-HUMI	IDIFIER EQUIPMENT S	CHEDULE										
NO.	LOCATION	DESCRIPTION	MANUFACTURER	MODEL	EXTRACTION	S.P.	FRPM	EI	LECT	RICA	L	REMARKS
					(L/D)	(Pa)		kW	V	PH.	CY.	
								ĺ				
DHM-1	PUMP ROOM	WALL HUNG DE-HUMIDIFIER UNIT	EBAC	CD 100 E	46	-	-	1.1	120	1	60	
								1				
REMARKS:												

1. DEHUMIDIFER CONDENSATE DRAIN SHALL BE PIPED TO THE CLOSEST FLOOR DRAIN.





			PROJECT MANAGER	M. DAY
			CIVIL	MD
			STRUCTURAL	
			ARCHITECTURAL	WB
			PROCESS	MM
			MECHANICAL	MM
2	2023-10-13	ADDENDUM #2	ELECTRICAL	
0	2023-09-19	ISSUED FOR TENDER	INSTRUMENTATION	MM
ISSUE	DATE	DESCRIPTION	PROJECT NUMBER	E20307
			·	•



SOUTH WHISTLER WATER SUPPLY PHASE 2

2023

P291 - SOUTH WHISTLER BOOSTER PUMP STATION AND WATER TREATMENT FACILITY

HVAC SCHEDULES & DETAILS

FILENAME 10299470-M01-201-M006.dwg SHEET

SCALE AS NOTED MO06