
Addendum 3

ISSUE DATE: October 19, 2023

CLIENT NAME: Resort Municipality of Whistler

FROM: Chelsey Roberts, AScT, Resort Municipality of Whistler

RE: **South Whistler Water Upgrade
Contract E20307**

In accordance with the provision contained in the “Instructions to Tenderers” for Contract No. E20307, Addendum No. 3 is hereby issued.

The following changes, additions, and/or deletions are hereby made a part of the Contract Documents for the above noted Contract, Invitation for Tender as fully and completely as if the same were fully set forth therein:

Section 26 29 23 11 – Variable Frequency Drive, **2.1.1.11** to be replaced with:
“Standard of Acceptance: ABB ACQ580 or Allan Bradley Powerflex 753”

Section 26 29 23 11 – Variable Frequency Drive, **2.1.1.12** to be added:
“2.1.1.12: The tendered design is based on the ABB ACQ580 Variable Frequency Drives. Should the Contractor select to use the AB Powerflex 753 VFDs, the Contractor shall provide an alternate design for incorporating the AB VFDs with the same logic and design intent as the ABB VFDs.”

Section 40 12 00 – Compressed Air System, 2.2.1.1.6 to be replaced with:
“2.2.1.1.6 Maximum sound: 69 dB”
