

---

## Addendum 5

---

**ISSUE DATE:** October 23, 2023

**CLIENT NAME:** Resort Municipality of Whistler

**FROM:** Chelsey Roberts, AScT, Resort Municipality of Whistler

**RE:** **South Whistler Water Upgrade  
Contract E20307**

---

In accordance with the provision contained in the "Instructions to Tenderers" for Contract No. E20307, Addendum No. 5 is hereby issued.

The following changes, additions, and/or deletions are hereby made a part of the Contract Documents for the above noted Contract, Invitation for Tender as fully and completely as if the same were fully set forth therein:

---

Delete the section of 09 96 00 3.1.1.3 in its entirety.

---

Question:

Q: Can you please confirm the required number of portable fire extinguishers?

A: Multi-Purpose Dry Chemical - Pressure Type

Description: ammonium phosphate, powder type, heavy duty steel cylinder, baked enamel finish, squeeze grip handle with positive on/off valve, hose and nozzle, mounting brackets.

Capacity: 4.5 kg.

ULC Rating: minimum rating of 6A:80B:C.

Classification: Class A, B, and E fires.

Qty: 2

Location: Chemical Room, Electrical Room

---

Q: Can you please also confirm the product for interior surfaces of the tank Trench/pit and the Pipe trench?

In S003:

Sikafloor CR is called out for the Tank trench

SikaGard 62 is called out for the Pipe trench

But in 09 67 23 all concrete surfaces bellow curb are called out to be Stonekote HT4 by Stonecor; Primer HT Primer.

A: Sika products are an approved equal to the standard of acceptance

---