

Nov 27th, 2023

Addendum 2

Request for Quotation 5330-02-1024 – Whistler Parkades Lot D Beam Repair.

The Documents for this work are revised as noted herein. All such revisions become a part of the work and shall be included in your Tender. No consideration will be allowed for extras due to the tenderer not being familiar with this addendum.

REFERENCE: Questions/notes

QUESTION & ANSWER:

Q. Can you provide any structural drawings to gain a comprehensive understanding of the load-bearing structure for shoring engineer.

A. Available Base Building Drawings have been issued as part of Addendum No. 1

Q. Can you provide list of approved concrete repaired material?

A. Please see the attached PDF for a new specification section that outlines requirements for pre-packaged concrete materials, including approved products.

Q. Can you verify if the inverted beam can support its own weight during the repairs, or if we need to do 'spot shoring' that can be moved around to fix certain areas of the beam segmentally.

A. Shoring Engineer to review and provide shoring requirements to support the beam during repairs.

Q. Can you verify if the level above only has regular parkade live loads (~50spf).

A. Correct – see general notes in the drawings.

Q. Can you clarify if Resort municipality of Whistler will arrange moving all sprinkler pipes and electrical conduits within near proximity of inverted beam.

A. Yes, this task will be undertaken by the RMOW / sub- contractors.

Q. Will Resort municipality of Whistler provide their electrician to connect our temporary electrical panel to existing elec. panel?

A. Yes, this section of works can be undertaken by the RMOW.

Q. Is Hazmat report available to verify presence or possibility of lead paint on beam?

A. We don't think we (RMOW) have had a report undertaken in this area. If required, can we arrange for one.

Q. Item 1.5 under instructions to Bidders states the need to submit a CCDC 11 with the bid submission, however this is not listed under Item 4 Submittals of the Bid Form. Please advise if the full CCDC 11 document needs to be submitted with the bid submission, or if there are only some sections of it that are required (and if so, which ones), or if it is not required at all.

A. Contractor to include complete CCDC 11 as part of the bid submission.

End of Addendum