<u>GENERAL NOTES:</u>

- 1. THE GENERAL NOTES AND TYPICAL DETAILS ARE APPLICABLE TO ALL PARTS OF THE PROJECT AND SHALL BE READ IN CONJUNCTION WITH THE DRAWINGS.
- 2. USE ONLY THE LATEST ISSUES OF ANY GOVERNMENT CODES, STANDARDS OR REGULATIONS MENTIONED IN THE FOLLOWING NOTES, UNLESS OTHERWISE INDICATED.
- NEW STRUCTURAL ELEMENTS SHOWN ON THESE DRAWINGS ARE DESIGNED IN ACCORDANCE WITH THE REQUIREMENTS OF LATEST BRITISH COLUMBIA BUILDING CODE (2018). ALL CONSTRUCTION, EXCEPT WHERE NOTED OTHERWISE, SHALL COMPLY WITH THAT SAME CODE. DESIGN LOADS ARE AS FOLLOWS:
- SCALE LOADING:

80ft SCALE: 266kN (59.87 kips) PER BASE PLATE, TOTAL 8 BASE PLATES 40ft SCALE: 200kN (45.20 kips) PER BASE PLATE, TOTAL 4 BASE PLATES

SCALE LOADING AS PER WESTERN SCALE COMPANY LTD. DRAWINGS:

80ft SCALE: DRAWING No. 227396, FOUNDATION - 80'x11' 100 TONNE 4 SECTION ELIMINATOR TRUCK SCALE FLUSH CONCRETE DECK BOLTED G/R, SHEET 1/1, DATED 2023.JAN.06

- 40ft SCALE: DRAWING No. 227393, FOUNDATION 40'x11', 50 TONNE 2 SECTION ELIMINATOR TRUCK SCALE FLUSH CONCRETE DECK, SHEET 1/1, DATED 2023.JAN.06
- 4. DRAWINGS AND DETAILS ARE INTENDED TO SHOW THE END RESULT OF DESIGN. MODIFICATIONS TO THE DESIGN NECESSARY TO SUIT SITE DIMENSIONS OR CONDITIONS SHALL BE SUBMITTED TO CONSULTANT FOR APPROVAL BEFORE PROCEEDING.
- 5. FOR DETAILS AND DIMENSIONS NOT GIVEN ON STRUCTURAL DRAWINGS SEE CIVIL, ARCHITECTURAL, MECHANICAL AND ELECTRICAL DRAWINGS. VERIFY LOCATIONS AND DIMENSIONS OF ALL OPENINGS, PIPE SLEEVES, ETC. AS REQUIRED WITH THE MECHANICAL AND ELECTRICAL CONTRACTORS
- 6. DO NOT CUT THROUGH, CORE-DRILL OR OTHERWISE ALTER ANY EXISTING OR NEW PART OF THE STRUCTURE WITHOUT PRIOR APPROVAL OF CONSULTANT.
- 7. THE SCHEDULING OF ALL WORK, INCLUDING ACCESSIBILITY, FLAGGING AND LOGISTICS SHALL BE COORDINATED AND AGREED WITH THE OWNER PRIOR TO COMMENCEMENT.
- 8. ANY DEVIATION FROM THE SEQUENCE OF WORK INDICATED ON THE DRAWINGS MUST BE
- 9. DO NOT EXCEED THE DESIGN LOADINGS INDICATED ON THESE DRAWINGS DURING
- 10. ALL DESIGN LOADINGS INDICATED ON THESE DRAWINGS ARE SPECIFIED (i.e. UNFACTORED SERVICE) LOADINGS UNLESS OTHERWISE INDICATED.
- 11. DO NOT SCALE THE DRAWINGS.

CONSTRUCTION.

APPROVED BY THE CONSULTANT.

- 12. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO SAFEGUARD ALL EXISTING STRUCTURES AFFECTED BY THIS CONSTRUCTION. ON ANY NEW STRUCTURE, DO NOT EXCEED THE DESIGN LOADINGS INDICATED ON THESE DRAWINGS.
- 13. MAKE ADEQUATE PROVISIONS FOR CONSTRUCTION STRESSES AND FOR SUFFICIENT TEMPORARY BRACING AND SHORING TO KEEP THE STRUCTURE PLUMB AND LEVEL DURING ALL PHASES OF WORK. ANY BRACING MEMBERS SHOWN ON STRUCTURAL DRAWINGS ARE THOSE REQUIRED FOR THE FINISHED STRUCTURE AND MAY NOT BE ADEQUATE FOR ERECTION PURPOSES.
- 14. ALL LOADING FOR CONNECTIONS AND BRACES SHOWN ON THESE DRAWINGS ARE THE CRITICAL FACTORED FORCES, UNLESS OTHERWISE INDICATED.
- 15. ALL DIMENSIONS SHOWN ARE IN mm, UNLESS OTHERWISE INDICATED
- 16. ALL DIMENSIONS TO BE VERIFIED WITH FIELD MEASUREMENTS. PRIOR TO SHOP DRAWING FABRICATION.
- 17. PROVIDE A MINIMUM OF 48 HOURS OF NOTICE FOR A FIELD REVIEW.
- 18. SHOP DRAWING REVIEW WILL BE TURNED AROUND IN ONE WEEK FROM THE DATE RECEIVED AT THE CONSULTANT'S OFFICE.
- 19. THE CONTRACTOR SHALL REMOVE AND DISPOSE OF ALL CONSTRUCTION WASTE AND SURPLUS MATERIALS OFF SITE. USE OF ONSITE FACILITY FOR THE DISPOSAL OF CONSTRUCTION WASTE AND SURPLUS MATERIAL IS NOT PERMITTED.

EQUIPMENT SUPPORT:

1. SUPPORT FOR THE EQUIPMENT DESIGNED AND SUPPLIED BY OTHER DISCIPLINES (MECHANICAL, ELECTRICAL AND PIPING) SHALL BE DESIGNED BY PROFESSIONAL ENGINEERS THE LOCATIONS OF THE POINT LOADS FOR LOADS AND EFFECTS ACCORDING TO THE BCBC. SHALL BE REVIEWED WITH MORRISON HERSHFIELD (MH). SUBMIT SHOP DRAWINGS FOR REVIEW BY MH.

CONCRETE:

- 1. ALL CONCRETE MATERIALS AND WORKMANSHIP TO CONFORM TO CSA-A23.1-19 & CSA-A23.2-19.
- 2. CONCRETE FORMWORK, FALSEWORK AND ACCESS SCAFFOLDING TO CONFORM TO CSA-S269.1-16 AND CSA-S269.2-16.
- 3. REFER TO ARCHITECTURAL AND MECHANICAL DRAWINGS FOR SIZE AND LOCATION OF CURBS AND PADS. REINFORCE AS PER TYPICAL DETAILS UNLESS OTHERWISE NOTED.
- 4. ALL CONCRETE SHALL BE NORMAL DENSITY, UNLESS NOTED OTHERWISE, CONFORMING TO THE FOLLOWING:

LOCATION	EXPOSURE CLASS	CEMENT TYPE	MAX. W/C RATIO	AIR	MIN. f'c 28 DAYS (MPa)	AGGR. SIZE (mm)	SLMP (mm)
FOUNDATIONS	C1	MS	0.4	5-8	30	20 (MAX.)	80 +/- 30
SLAB ON GRADE	C1	MS	0.4	5-8	30	20 (MAX.)	80 +/- 30

- 5. ALL CONCRETE WHICH WILL BE SUBJECTED TO FREEZING AND THAWING OR SUBJECTED TO APPLICATIONS OF DEICING CHEMICAL IS TO CONTAIN ENTRAINED AIR IN ACCORDANCE WITH THE REQUIREMENTS OF CSA STANDARD A23.1.
- 6. SUBMIT MIX DESIGNS FOR EACH CLASS OF CONCRETE TO BE USED ON THE PROJECT.
- 7. ADMIXTURES THAT CONTAIN CHLORIDES SHALL NOT BE USED.
- 8. UNLESS NOTED OTHERWISE, PROVIDE THE FOLLOWING CLEAR CONCRETE COVER TO REINFORCING STEEL:

LOCATION
CONCRETE CAST AGAINST EARTH
BEAMS AND GIRDERS
FORMED CONCRETE EXPOSED TO EARTH OF WEATHER
ORMED SLABS AND WALLS NOT EXPOSED TO EARTH OF WEATHEI

- 9. THE EXTERIOR FACE OF THE FINISHED CONCRETE SHALL BE EVEN, FREE OF HONEYCOMBS, OR OTHER DEFECTS CAUSED BY THE FORMWORK. FILL HONEYCOMBS WITH A PATCHING MORTAR. GRIND DOWN ANY ROUGH EDGES.
- 10. NO HOLES SHALL BE MADE THROUGH CONCRETE WORK OTHER THAT THOSE INDICATED ON THE STRUCTURAL DRAWINGS, WITHOUT APPROVAL FROM THE CONSULTANT.
- 11. UNLESS SHOWN OTHERWISE, ALL EXISTING CONCRETE SUBSTRATES TO BE BONDED TO NEW CONCRETE SHALL BE INTENTIONALLY ROUGHENED TO A FULL AMPLITUDE OF 6 mm AND A FREQUENCY NOT EXCEEDING 25mm AND SHALL BE CLEANED OF ALL DIRT, RUST AND LAITANCE. DO NOT CUT EXISTING REINFORCING BARS THAT INTERSECT JOINTS OF NEW-TO-EXISTING CONCRETE. PREPARED SURFACES OF EXISTING CONCRETE SHALL BE THOROUGHLY WETTED DOWN WITH POTABLE WATER FOR NOT LESS THAN ONE (1) HOUR PRIOR TO PLACEMENT OF CONCRETE. PUDDLES AND/OR FREE WATER SHALL BE BLOWN CLEAR OF THE REPAIR AREA IMMEDIATELY BEFORE PLACEMENT OF CONCRETE. CONCRETE SUBSTRATE MUST BE CLEAN, SOUND, AND IN A SATURATED SURFACE DRY CONDITION AT TIME OF APPLICATION. TEMPERATURE OF SLAB AND AIR TEMPERATURE MUST NOT BE BELOW +10°C AT BONDED OVERLAYS.
- 12. PROVIDE 20mm CHAMFER AT ALL EXPOSED CORNERS UNLESS OTHERWISE NOTED.
- 13. ALL OPENINGS SHALL BE FORMED OR SLEEVED PRIOR TO PLACING CONCRETE
- 14. PROVIDE ADDITIONAL REINFORCING AT OPENINGS AS SHOWN OR DIRECTED BY CONSULTANT.
- 15. OBTAIN CONSULTANT'S APPROVAL FOR ANY OPENINGS REQUIRED BUT NOT SHOWN ON STRUCTURAL DRAWINGS,
- 16. CURE CONCRETE WALLS WITH WATER SPRAY FOR THREE DAYS. ALTERNATIVELY, KEEP THE FORMS IN PLACE AND WET THE TOP OF WALL FOR THREE DAYS. 17. DO NOT COMPACT SOIL AGAINST THE FOUNDATION WALLS UNTIL THE CONCRETE REACHES ITS

CONCRETE ANCHORS:

- 1. VERIFY LOCATIONS BY A NON-DESTRUCTIVE METHOD SUCH AS GPR, BEFORE DRILLING HOLES IN CONCRETE.
- 2. DO NOT CUT REBAR.

SPECIFIED STRENGTH

- PATCH UP UNUSED HOLES IN CONCRETE WITH CONCRETE PATCHING MORTAR.
- 4. DRILL HOLES IN THE STRUCTURAL STEEL TO BE ANCHORED ONLY AFTER CONFIRMING THE LOCATION OF HOLES IN THE CONCRETE SUBSTRATE. RESTORE UNUSED HOLES IN THE STEEL MEMBER WITH PLUG WELDS.

REINFORCING STEEL:

- 1. CONFORM TO THE REQUIREMENTS OF CSA STANDARD A23.1-14 & A23.3-14.
- 2. REINFORCING STEEL SHALL BE DEFORMED BAR CONFORMING TO CSA STANDARD G30.18-09 (R2014), GRADE 400R, UNLESS OTHERWISE NOTED.
- 3. WELDED WIRE FABRIC SHALL HAVE A MINIMUM YIELD STRENGTH OF 450 MPa AND SHALL CONFORM TO CSA STANDARD G30.5-M1983 (WITHDRAWN***). SUPPLY IN FLAT SHEETS ONLY.
- REINFORCING STEEL IS TO BE DETAILED. BENT AND PLACED IN ACCORDANCE 4. WITH THE R.S.I.C REINFORCING STEEL MANUAL OF STANDARD PRACTICE SUBMIT SHOP DRAWINGS INDICATING ALL DETAILS OF REINFORCING STEEL PLACEMENT.
- PROVIDE CHAIRS, SPACER BARS, SUPPORT BARS AND OTHER ACCESSORIES 5. TO SUPPORT REINFORCING IN ACCORDANCE WITH A23.1-14 AND A23.3-14. ALL THE WIRE, CHAIRS AND BAR SUPPORTS FOR FOUNDATIONS AND FOR EXPOSED CONCRETE SHALL BE NONMETALLIC OR COATED.
- PROVIDE ONE 15M NOSING BAR FOR ALL SILLS, LEDGES, AND STEPS, UNLESS 6. OTHERWISE NOTED.
- 7. PROVIDE CLASS 'B' TENSION LAP SPLICES U.N.O. ALL SPLICE LOCATIONS SHALL BE TO THE APPROVAL OF THE CONSULTANT.
- 8. DOWELS TO EXISTING CONCRETE SHALL USE THE HILTI HY-150 DOWELING SYSTEM. COMPLY WITH MANUFACTURER'S WRITTEN INSTRUCTIONS.
- 9. PROVIDE MATCHING DOWELS TO PIERS OR WALLS FROM FOOTINGS, WITH CLASS 'B' LAP.
- 10. PROVIDE ONE 15M TOP AND BOTTOM REINFORCING BARS AT ALL EDGES OF SLABS. THIS REINFORCING MAY BE PROVIDED BY MODIFYING THE BARS SHOWN ON PLAN OR SCHEDULE, OR BY PROVIDING ADDITIONAL REINFORCING.
- 11. LAP SPLICES IN WELDED WIRE MESH SHALL NOT BE LESS THAN 200mm, AS MEASURED BETWEEN THE OUTERMOST CROSS-WIRES OF EACH FABRIC SHEET. 12. LAP SPLICES LENGTH:

SPLICE LENGTH SPLICE LENGTH BAR BAR (mm) (mm) 10M 600 25M 1500 1700 15M 800 30M 20M 900 35M 2100

SPECIFIED COVER (mm)
75
40
50
40

<u>GROUT:</u>

1. NON-SHRINK GROUT: PREMIXED CEMENTIOUS COMPOUND, NONMETALLIC AGGREGATES, 50 MPa COMPRESSIVE STRENGTH AT 28 DAYS.

CORES & OPENINGS:

- 1. CORES OR OPENINGS ARE NOT TO EXCEED 75mm DIA. UNLESS NOTED ON DRAWINGS OR APPROVED BY CONSULTANT IN WRITING.
- 2. DO NOT CUT OR CORE IN ANY NEW OR EXISTING STRUCTURAL MEMBERS OTHER THAN WHERE SHOWN ON STRUCTURAL DRAWINGS.
- 3. LOCATE REINF. STEEL STEEL WITH GROUND PENETRATING RADAR (GPR) PRIOR TO CUTTING. PROVIDE CONSULTANT WITH DRAWING OR RADARGRAM DEPICTING LOCATION OF REINF. STEEL IN RELATIONSHIP TO THE PROPOSED CORE/OPENING FOR REVIEW PRIOR TO CUTTING
- 4. DO NOT CUT ANY REINF. STEEL OR EMBEDDED SERVICES IN CONCRETE. DO NOT CORE THROUGH CONCRETE COLUMNS, BEAMS, CAPITALS, DROP PANELS. UNLESS NOTED, PROVIDE AT LEAST 75mm CLEAR SPACE BETWEEN NEW CORES, 400mm BETWEEN NEW CORE & EXIST. OPENINGS, SLEEVES OR CORES.
- 5. DO NOT CUT OR DAMAGE REINFORCING STEEL OR EMBEDDED SERVICES IN EXISTING CONCRETE OR MASONRY STRUCTURE. LOCATE ALL REINFORCING STEEL AND SERVICES PRIOR TO DRILLING, CORING OR CUTTING.
- 6. FOR NEW RECTANGULAR OPENINGS IN CONC. PROVIDE ROUNDED CORNERS.
- 7. TOUCH-UP ENDS OF CUT REBAR WITH 2 COATS OF ZINC-RICH PAINT
- 8. OPENINGS AND SLEEVES:
- 8.1. ALL OPENINGS SHALL BE FORMED OR SLEEVED PRIOR TO PLACING CONCRETE 8.2. PROVIDE ADDITIONAL REINFORCING AT OPENINGS AS SHOWN OR DIRECTED BY
- CONSULTANT 8.3. OBTAIN CONSULTANT'S APPROVAL FOR ANY OPENINGS REQUIRED BUT NOT SHOWN ON STRUCTURAL DRAWINGS.

QUALITY CONTROL

- 1. WHEN SPECIFIED OR REQUESTED BY THE CONSULTANT, PROVIDE 3 COPIES OF FABRICATION AND ERECTION DRAWINGS PRIOR TO FABRICATION. ALLOW UP TO TEN WORKING DAYS FOR REVIEW BY CONSULTANT.
- 2. IN ADDITION TO CONTRACTOR'S QUALITY CONTROL PROGRAM, INDEPENDENT TESTING AND INSPECTION MAY BE PERFORMED BY THE OWNER OR THE OWNER'S REPRESENTATIVE.
- 3. SUBMIT SHOP DRAWING BEARING STAMP OF A QUALIFIED PROFESSIONAL ENGINEER REGISTERED IN THE PROVINCE OF BRITISH COLUMBIA.

GEOTECHNICAL REPORT:

- 1. FOOTINGS SHALL BE SUPPORTED ON A MINIMUM 150mm BED CRUSHED GRAVEL BED, UNLESS DIRECTED OTHERWISE BY FRONTERA GEOTECHNICAL INC. USE 19mm MINUS CRUSHED GRAVEL COMPACTED TO 100 PERCENT STANDARD PROCTOR DENSITY (ASTM D698). SEE FRONTERA GEOTECHNICAL INC. REPORT DATED NOVEMBER 17, 2022, FILE : 1935 FOR ADDITIONAL REQUIREMENTS. EXTEND THE GRAVEL BED 300mm BEYOND THE EDGES OF FOOTINGS.
- 2. FACTORED ULS BEARING PRESSURE = 300 kPa (ENGINEERED FILL) = 750 kPa (BEDROCK)
- 3. THE SLAB ON GRADE SHALL BE SUPPORTED ON A COMPACTED BASE AS APPROVED BY FRONTERA GEOTECHNICAL INC.
- 4. COMPACT FILL WITHIN 1200mm OF THE FOUNDATION WALLS WITH A1000 POUND PLATE TAMPER.
- 5. FOUNDATIONS DESIGNED IN ACCORDANCE WITH GEOTECHNICAL REPORT PREPARED BY FRONTERA GEOTECHNICAL INC. DATED NOVEMBER 17, 2022, FILE : 1935. COPY OF REPORT IS AVAILABLE TO THE CONTRACTOR.
- 6. COORDINATE WITH FRONTERA GEOTECHNICAL INC. FOR WORK RELATING TO THE INSTALLATION OF FOUNDATION, INSPECTION AND ACCEPTANCE OF WORK.

	D	2023-08-30		:	SSUED FOR TE	ENDER	
	A	2023-03-31		[SSUED FOR TE	ENDER	
		YYYY-MM-DD		SUB	MISSION INFO	RMATION	
	DISCL	AIMER:					
	THIS I REPRO	DRAWING IS PRO ODUCED IN ANY I ISSION OF MORR	TECTED E MANNER, RISON HEF	BY COPYRIGH OR FOR ANY RSHFIELD LIMI	F LAW, AND SH PURPOSE, EX TED. CONTRA	HOULD NOT BE CEPT BY WRITTE ACTOR SHALL VE	EN
	AND E AND/C	E RESPONSIBLE OR OMISSIONS TO	FOR ALL MORRIS	DIMENSIONS ON HERSHFIE	AND REPORT	ANY ERRORS	
		STAMP			PERMIT	TO PRACTICE	
1							
				•			
			ř.	Reso	rt Mur	ncipali	ty of
				WF	l I S	T	R
		P	MO	RRISC	N HE	RSHFI	ELD
			Unit ?	10 /224	Still Cro	ek Drivo	
		Bu Tel:	urnaby : 604-4	, British (154-0402	Columbia	V5C 6S7	3
	PROJ	IECT					
				RMC	W		
			Tra	nsfer	Static	on	
	DRAV	VING					
			ST	RUCI	URAL	-	
			GEN	IERAL		ΞS	
	DEST	201	,			SCALE	
	DESI	JH		2023-F	EB-15	JUALE	
	DRAV	VN ERG		PROJECT NC 2203). 084.00		
	CHEC	KED		DRAWING NO)	l	VERSION
	APPR				S00		D

เก





L LL	

2023-08-30	ISSUED FOR TENDER
2023-05-23	POST TENDER ADDENDUM 1
2023-03-31	ISSUED FOR TENDER
YYYY-MM-DD	SUBMISSION INFORMATION
	2023-08-30 2023-05-23 2023-03-31 YYYY-MM-DD

DISCLAIMER:

THIS DRAWING IS PROTECTED BY COPYRIGHT LAW, AND SHOULD NOT BE REPRODUCED IN ANY MANNER, OR FOR ANY PURPOSE, EXCEPT BY WRITTEN PERMISSION OF MORRISON HERSHFIELD LIMITED. CONTRACTOR SHALL VERIFY AND BE RESPONSIBLE FOR ALL DIMENSIONS AND REPORT ANY ERRORS AND/OR OMISSIONS TO MORRISON HERSHFIELD LIMITED.





MORRISON HERSHFIELD

Unit 310, 4321 Still Creek Drive Burnaby, British Columbia V5C 6S7 Tel: 604-454-0402 Fax: 604-454-0403

PROJECT

RMOW **Transfer Station**

DRAWING

SECTIONS

	DATE 2023-FE	B-15	SCALE	
	PROJECT NO. 22030	84.00		
CHECKED	DRAWING NO			VERSION
APPROVED		S02		D



Image: State of the state		YYYY-MM-DD	SUBMISSION INFORMATI	ION
STAMP PERMIT TO PRACTICE STAMP PERMIT TO PRACTICE STAMP PERMIT TO PRACTICE Resort Municipality of WHISTLEED WHISTLEED WHISTLEED WHISTLEED WHISTLEED WHISTLEED WHISTLEED STAMP PROVED STAMP PERMIT TO PRACTICE STAMP STAMP PERMIT TO PRACTICE STAMP PERMIT TO PRACTICE STAMP STAM		DISCLAIMER: THIS DRAWING IS PROT REPRODUCED IN ANY M PERMISSION OF MORRIS AND BE RESPONSIBLE F AND/OR OMISSIONS TO	ECTED BY COPYRIGHT LAW, AND SHOULD ANNER, OR FOR ANY PURPOSE, EXCEPT E SON HERSHFIELD LIMITED. CONTRACTOR OR ALL DIMENSIONS AND REPORT ANY EI MORRISON HERSHFIELD LIMITED.	NOT BE 3Y WRITTEN SHALL VERIFY RRORS
Image: State - edit, 50 time 2 state - edit, 50 time - 50 tim	N	STAMP	PERMIT TO PR	ACTICE
Image: State of the state			Resort Munici	pality of LER
AB PROJECT PROJECT RMOW Transfer Station DRAWING DRAWING 40ft SCALE FOUNDATION PLAN, SECTIONS AND APRON WALL ELEVATIONS DESIGN JH 2023-FEB-15 DRAWING DRAWING CHECKED DRAWING NO VERS ASDRY - 40x11, 50 TOME 2 SECTOMELIMINATOR TRUCK SALE FLISH CONCRETE DEX, TITLE RAWINGS			MORRISON HERS Jnit 310, 4321 Still Creek D naby, British Columbia V5 604-454-0402 Fax: 604-45	HFIELD Drive C 6S7 54-0403
FUNDATION - 40x11', 50 TONKE 2 SECTIONFELIMINATOR TRUCK SCALE FLUSH CONCRETE DECK, TITLE RAWINGS		PROJECT	RMOW Transfer Station	
FOUNDATION - 40'x11', 50 TONNE 2 SECTION?ELIMINATOR TRUCK SCALE FLUSH CONCRETE DECK, DESIGN DATE SCALE FOUNDATION - 40'x11', 50 TONNE 2 SECTION?ELIMINATOR TRUCK SCALE FLUSH CONCRETE DECK, DRAWN PROJECT NO. 2203084.00 VERS FOUNDATION - 40'x11', 50 TONNE 2 SECTION?ELIMINATOR TRUCK SCALE FLUSH CONCRETE DECK, CHECKED DRAWING NO VERS ASSEMBLY - 40'x11', 50 TONNE 2 SECTION?ELIMINATOR TRUCK SCALE FLUSH CONCRETE DECK, APPROVED DRAWING NO VERS RAWINGS APPROVED DRAWING NO SO3 E	L L	DRAWING FOUND AND AP	40ft SCALE ATION PLAN, SEC RON WALL ELEVA	TIONS TIONS
FOUNDATION - 40'x11', 50 TONNE 2 SECTION?ELIMINATOR TRUCK SCALE FLUSH CONCRETE DECK, CHECKED DRAWING NO VER ASSEMBLY - 40'x11', 50 TONNE 2 SECTION?ELIMINATOR TRUCK SCALE FLUSH CONCRETE DECK, APPROVED SO3 L TITLE APPROVED APPROVED L L L		DESIGN JH DRAWN ERG	DATE 2023-FEB-15 SCAL PROJECT NO. 2203084.00	E
	FOUNDATION - 40'x11', 50 TONNE 2 SECTION?ELIMINATOR TRUCK SCALE FLUSH CONCRETE DECK, ASSEMBLY - 40'x11', 50 TONNE 2 SECTION?ELIMINATOR TRUCK SCALE FLUSH CONCRETE DECK, TITLE RAWINGS	CHECKED JH APPROVED	DRAWING NO	VERSIC

ISSUED FOR TENDER 2023-08-30 2023-05-23 POST TENDER ADDENDUM 1 ISSUED FOR ADDENDUM No. 2 2023-04-18 A 2023-03-31 ISSUED FOR TENDER





