

The following addendum supersedes information contained in drawings and specifications issued for the project to the extent referenced. This Addendum forms part of the Tender Documents and is subject to all of the conditions set out in the contract conditions.

1. DRAWINGS – MECHANICAL

1.1 Drawing No.: M0.01

.1 Add: Heat Pump Schedule

- .1 Proposed modular heat pumps shall be shipped individually and assembled on site to ensure they fit through the entrance to the mechanical room.

END OF MECHANICAL ADDENDUM NO. 2


Regards,



Jarvis Xiao, EIT, EMIT

Building Performance Specialist - Vancouver, BC

Attachment(s): N/A



PROFESSIONAL'S SEAL &
SIGNATURE