

Jan 29th, 2024

## Addendum 1

## Request for Quotation 5330-02-1027 – Public Works Yard Lunchroom HVAC Install

The Documents for this work are revised as noted herein. All such revisions become a part of the work and shall be included in your Tender. No consideration will be allowed for extras due to the tenderer not being familiar with this addendum.

**REFERENCE:** Questions/notes

**QUESTION & ANSWER:**

**Q.** Confirmation that the Lunchroom heat pump system, is to be wall mounted.

**A.** Yes location within the lunchroom wall backing on the main set of stairs.

**Q.** Confirmation that the Lunchroom heat pump system, dose not require, return and fresh air fresh ducting.

**A.** No requitement for the new heat pump system to have return and fresh air fresh ducting, heating – cooling to remote heads only.

**Q.** Confirmation that the Lunchroom, will need an extract fan.

**A.** Replace existing Ex Fan within the ceiling void above coffee makers, to be controlled via a local on-off timer switch, pick up existing ductwork.

**Q.** The new heat pump system to have a second head in the adjoining small managers office.

**A.** Please allow for a second head to supply the Manager of Resort Operations office including for local controller.

**Note** the RMOW, to run in any electrical feeds to the heat pump and extract fan only.

End of Addendum