

ADDENDUM No.3

Owner: Resort Municipality of Whistler
(NAME OF OWNER)

Contract: 2024 Sewer and Water Valve and Fitting Repairs
(TITLE OF CONTRACT)

Reference No. E20508-E32006
(OWNER'S CONTRACT REFERENCE NO.)

To All Tenderers:

Date: February 12, 2024

This addendum shall form part of the original documents for the above noted contract and all other segments of the contract shall remain in force except as noted below:

1. Questions and Answers

The following questions have been received from Contractors. Responses are provided below. Any cost implications of the responses provided are to be included in the tender price.

Q1: Is it possible to confirm the minimum pressure rating required for the sanitary forcemain bypass?

A1: *The minimum pressure rating required for the sanitary forcemain bypass (Form of Tender - Item 1.21) is 90 psi.*

All tenderers shall acknowledge receipt of Addendum #3 (one (1) page) by signing in the space provided and submitting this signed addendum with the tender. Tenders submitted without acknowledgment of this addendum may be considered incomplete.

Receipt acknowledged and conditions agreed _____ day of _____, 2024

Tenderer

Signature

END ADDENDUM #3