

ADDENDUM No.4

**Owner:** Resort Municipality of Whistler  
(NAME OF OWNER)

**Contract:** 2024 Sewer and Water Valve and Fitting Repairs  
(TITLE OF CONTRACT)

**Reference No.** E20508-E32006  
(OWNER'S CONTRACT REFERENCE NO.)

To All Tenderers:

Date: February 15, 2024

This addendum shall form part of the original documents for the above noted contract and all other segments of the contract shall remain in force except as noted below:

**1. Questions and Answers**

The following questions have been received from Contractors. Responses are provided below. Any cost implications of the responses provided are to be included in the tender price.

**Q1: Operating pressure of the sewer forcemain?**

A1: *56-57 psi with both SLS 88 HP Pumps running at the same time. The third larger 250HP pump will be locked out for the duration of the bypass.*

**Q2: Maximum or test pressure of the sanitary sewer forcemain?**

A2: *See Addendum #3.*

**Q3: Stainless or mild steel hardware?**

A3: *Stainless steel for all sewer and water hardware.*

**Q4: If steel pipe, is it stainless or carbon steel?**

A4: *We don't anticipate steel pipe on this Contract.*

**Q5: If HDPE, what is the DR rating?**

A5: *DR11 for S2-10a & S2-10b.*

**Q6: What type is the PVC pipe?**

A6: *See general notes on Contract Drawings.*

**Q7: What type are the 400 mm long radius Bends for Form of Tender Items 1.11 to 1.16 (TYT or MJ)?**

A7: *Unknown.*

All tenderers shall acknowledge receipt of Addendum #4 (one (1) page) by signing in the space provided and submitting this signed addendum with the tender. Tenders submitted without acknowledgment of this addendum may be considered incomplete.

Receipt acknowledged and conditions agreed \_\_\_\_\_ day of \_\_\_\_\_, 2024

\_\_\_\_\_  
Tenderer

\_\_\_\_\_  
Signature

END ADDENDUM #4