

March 19th, 2024

Addendum 2

Request for Quotation Addendum 1 - 5330-02-1030 – Fire Hall No 3 Roof Replacement.

The Documents for this work are revised as noted herein. All such revisions become a part of the work and shall be included in your Tender. No consideration will be allowed for extras due to the tenderer not being familiar with this addendum.

REFERENCE: Questions/notes

QUESTION & ANSWER:

1, Q. Could you send me the architectural drawings of the building?

A. As per the site meeting, we have no as fit drawings or any drawings on record that show the existing build up.

2, Q. What is the slope required for the SopraISO slope package? 1% slope or 2% slope.

A. Please allow for 2% and will be reviewed and confirmed once on site.

3, Q. The Sopraboard (overlay board) does not come on a 3/8" thickness. The options would be 1/8", 3/16", and 1/4". Could you advise which one we should allow for the project.

A. Please allow for 1/4".

4, Q. Are we going to be able to park on-site.

A. Please assume that you can park on the site.

5, Q. Are we going to be able to place a garbage bin on-site (in the parking area)?

A. Please assume that a waste bin can be placed within the parking area.

6, Q. Could you confirm if access to the roof will be through the stairwell?

A. Yes, access to the roof can be through the stairwell, but only for staff and hand tools only.

End of Addendum